



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

| | |
|---|---|
| Title - Sujet West Wall Repair- Dorchester Pen. | |
| Solicitation No. - N° de l'invitation EC016-181083/A | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client EC016-181083 | Date 2017-08-24 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-4170 | |
| File No. - N° de dossier PWB-7-40055 (004) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-21 | Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB | Buyer Id - Id de l'acheteur pwb004 |
| Telephone No. - N° de téléphone (506) 636-4541 () | FAX No. - N° de FAX (506) 636-4376 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

This Solicitation Amendment No. two (2) is raised to include the following addendum no. 2.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 2.

1. DRAWINGS

.1 Clarification to Drawing E-1

Under “KEYED NOTES AND ELECTRICAL NOTES”, add the following text to the noted paragraphs.

Add the following line to Paragraph 1. :
MAKE INTERCONNECTIONS AS REQUIRED.

Add the following line to Paragraph 2, 6, 9 and 11. :
TERMINATE ALL FIBER STRANDS ON AN INDUSTRIAL GRADE PATCH PANELS.

.2 Clarification to Drawing E-2

Under “ELECTRICAL NOTES AND SPECIFICATIONS”, replace the following paragraph:

TERMINATIONS:

FIBRE OPTIC CABLES SHALL BE TERMINATED TO SC PHYSICAL CONTACT CONNECTORS SHALL BE ABLE TO SUSTAIN A MINIMUM OF 200 MATING CYCLES PER EIA/TIA-455-21 WITHOUT VIOLATING SPECIFICATIONS. THESE CONNECTORS WILL TERMINATE WITHIN INTERCONNECT SLEEVES TO FACILITATE PATCHING IN PATCH PANELS. THE MAXIMUM OPTICAL ATTENUATION PER PAIR OF MATED CONNECTORS SHALL NOT EXCEED 0.75 DB.

With this one:

TERMINATIONS:

FIBRE OPTIC CABLES SHALL BE TERMINATED TO SC PHYSICAL CONTACT CONNECTORS SHALL BE ABLE TO SUSTAIN A MINIMUM OF 200 MATING CYCLES PER EIA/TIA-455-21 WITHOUT VIOLATING SPECIFICATIONS. THESE CONNECTORS WILL TERMINATE WITHIN INTERCONNECT SLEEVES TO FACILITATE PATCHING IN PATCH PANELS. THE MAXIMUM OPTICAL ATTENUATION PER PAIR OF MATED CONNECTORS SHALL NOT EXCEED 0.75 DB. TERMINATE ALL FIBER STRANDS ON AN INDUSTRIAL GRADE PATCH PANEL WITH A MINIMUM OF 5% SPARE CAPACITY. THE PATCH PANEL SHALL BE LOCATED IN THE EXISTING RACKS. CONFIRM MOUNTING AND LOCATIONS ON SITE.