



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Services**

**3, passage du Chien-d 'Or
Quebec, QC
G1R 3Z8**

INVITATION TO TENDER
APPEL D'OFFRES

AMENDMENT #2 TO:

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
3, passage du Chien-d 'Or
Quebec, QC, G1R 3Z8

Title-Sujet Rehabilitation of the ventilation systems at the National Historic Site of the Forges du St-Maurice		Date August 25th, 2017					
Solicitation No. - No. de l'invitation 5P201-17-5059		Client Ref. No. – No. de réf du client.					
GETS Reference No. – No de reference de SEAG							
Solicitation Closes L'invitation prend fin – at – à 2:00 PM on – le August 30th 2017		Time Zone Fuseau horaire - EASTERN DAYLIGHT TIME (EDT)					
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>							
Address Inquiries to: - Adresser toute demande de renseignements à : Josée Gagnon, josee.gagnon@pc.gc.ca							
Telephone No. - No de téléphone 418 648-2502		Fax No. – No de FAX: 418 649-6971					
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein							
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - No de téléphone: _____ Facsimile No. - N° de télécopieur: _____ Email - Courriel : _____							
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur <table style="width:100%; border:none;"> <tr> <td style="width:50%; border-top:1px solid black; text-align:center;">Name / Nom</td> <td style="width:50%; border-top:1px solid black; text-align:center;">Title / Titre</td> </tr> <tr> <td style="width:50%; border-top:1px solid black; text-align:center;">Signature</td> <td style="width:50%; border-top:1px solid black; text-align:center;">Date</td> </tr> </table>				Name / Nom	Title / Titre	Signature	Date
Name / Nom	Title / Titre						
Signature	Date						



Amendment #2

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE DETAILS TO THE TECHNICAL SPECIFICATIONS.

YOU MUST CONSIDER THE INFORMATION IN THE ANSWERS BELOW, IN THE EVALUATION OF YOUR BID.

Q7. For loads connected to the existing pannel « CDS sous-sol», « CDS Haut-fourneau » and « B », Are all required circuit breakers available and re-used? The only new ones to be provided for existing pannels are those of notes 6 and 9; That's right?

A7. Provide only the circuit breakers requested from the drawings. Many existing breakers are re-used as a part of the project.

Q8. The new pannel « CDS/1 » in Haut-fourneau is supplied by the existing transformer 75 KVA but this one is already supplied a pannel. Can you provide me with details of the new connection (and modification of the existing one)

A8. The existing CDS pannel is to be demolished and the existing loads transferred to the CDS / 1 pannel. See panel grid for loads to be refilled.

Q9. What does note 2 mean? (Fournir et installer une provision de cadenassage sur tous les disjoncteurs impliqués dans ce projet)

A9. A lockout supply is two trays mounted on each side of the circuit breaker to allow the installation of a padlock.

Q10. For magnetic starters not marked 5 below, no fuses or circuit breakers are required (starter). That's right?

A10. The starters always come with fuses, contactor and overload relays.

Q11. Are the reference product marks indicating a required quality? Are other manufacturers' equivalents acceptable?

A11. Products matching the reference are accepted.



Q12. Some equipment have combined magnetic starters and others are "uncombined". It's OK?

A12. Indeed, there are handsets and uncombined. Provide as shown on plans.

End of section.

THE BID CLOSING DATE REMAINS WEDNESDAY, THE 30TH OF AUGUST 2PM EDT.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

**Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.
Fax: 418 649-6971.**