



REFER TO CCN #2 FOR ALL REQUIREMENTS.

CAFETERIA NOT IN THIS CONTRACT (EXCEPT SWITCHES)

NOTE: LPI-9 AND RPH-12 RESERVED FOR THIS AREA.

ALL FIXTURES REQUIREMENTS IDENTIFIED IN THE TENDER PACKAGE.

ALL FIXTURES REQUIREMENTS IDENTIFIED IN THE TENDER PACKAGE.

### BASEMENT FLOOR PLAN

SCALE: 1/8" = 1'-0"

#### LIGHTING LEGEND:

(REFER TO MAIN LEGEND ON DRAWING E-31)

- A1 - 1-LAMP, 4' X 5", SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 1 TYPE F1 LAMP AND WRAP AROUND LENS.
- A3 - 3-LAMP, 4' X 14", SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND WRAP AROUND LENS. CHAIN SUSPENDED.
- A4 - 3-LAMP, 4' X 2'; SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND A FRAMED LENS. PENDANT MOUNTED.
- A6 - 3-LAMP, 4' X 2'; SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND A DEEP CELL PARABOLIC LENS. PENDANT MOUNTED.
- B4 - RECESSED; 3-LAMP, FLUORESCENT FIXTURE C/W 3 TYPE F1 LAMPS AND FRAMED LENS.
- B6 - RECESSED; 3-LAMP, FLUORESCENT FIXTURE C/W 3 TYPE F1 LAMPS AND A DEEP CELL PARABOLIC LENS.

- C1 - 4'; SINGLE TUBE, FLUORESCENT STRIP LIGHT. C/W 1 TYPE F1 LAMP.
- C2 - 4'; 2-LAMP FLUORESCENT STRIP LIGHT. C/W 2 TYPE F1 LAMPS.
- C3 - 2'; SINGLE LAMP, FLUORESCENT STRIP LIGHT. C/W 1 TYPE F1 LAMP.
- D1 - SURFACE MOUNTED, FLUORESCENT WALL SCONCE C/W PL-13 LAMPS. (FOUNTAIN)
- D2 - RECESSED CEILING MOUNTED WALL WASHER FIXTURE. C/W 2 PL-7 LAMPS. MOUNTED ABOVE FOUNTAIN.
- E5 - WALL MOUNTED (SURFACE), 4' X 8" FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS. MOUNTED 1'-0" BELOW CEILING.
- F1 - PENDANT MOUNTED; INDUSTRIAL TYPE 2-LAMP, FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS AND A SLOTTED REFLECTOR.
- V1 - 2-LAMP, SURFACE MOUNTED VAPOUR PROOF FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS.
- I4 - RECESSED, 2 LAMP FLUORESCENT FIXTURE C/W 2-13W PL LAMPS.
- I4 - WALL OR CEILING MOUNTED EXIT LIGHT. RESPECTIVELY.
- S1 - 200W, 347V SURFACE MOUNTED. METAL HALIDE FIXTURE.

#### NOTES:

- DIV.16 CONTRACTOR TO CONFIRM EXACT LOCATION OF ALL FIXTURES ON SITE WITH DIV.1 CONTRACTOR AND ENGINEER PRIOR TO INSTALLATION.
- EXISTING LIGHTING IN TUNNEL TO REMAIN. TUNNEL NOT SHOW FOR CLARITY. PROVIDE NEW SWITCH AND CIRCUITRY FOR TUNNEL LIGHTING.
- EXISTING LIGHTING IN OLD OIL STORAGE TO REMAIN. OLD OIL STORAGE ROOM NOT SHOW FOR CLARITY. PROVIDE NEW SWITCH AND CIRCUITRY. ROOM IS LOCATED UNDER ROOM 032.
- ALL EXIT AND EMERGENCY LIGHTS IN BASEMENT TO BE ON CIRCUIT ELP 2-11.

5. SWITCHES SHOWN IN ROOMS 005, 006, 009, 010, 024, 023 AND THE JANITORS ROOM ADJACENT TO 023, AS WELL AS THE MASTER SWITCH SHOWN IN THE ELEVATOR LOBBY HAVE BEEN SUPPLIED UNDER CCN#E.

FIT-UP REQUIREMENTS DELETION AND ADDITIONS OF SWITCHES.		OCT. 1991
revisions		date
<div><div>A</div><div>C</div><div>A</div><div>B</div><div>C</div></div>		
project <b>G.O.C.B. BEDFORD ROW HALIFAX, N.S.</b>		
drawing <b>BASEMENT FLOOR PLAN LIGHTING</b>		
designed <b>G.C. HICKS</b> conçu		
drawn <b>W.SZUBIELSKI</b> dessiné		
date <b>7/2/91</b> examiné		
approved <b>[Signature]</b> approuvé		
Tender <b>[Signature]</b> Soumission		
PWC Project Manager Administrateur de projets TPC		
project number <b>800769</b> no. du projet		
drawing no. <b>E-2</b> no. du dessin		