



# LIGHTING LEGEND:

(REFER TO MAIN LEGEND ON DRAWING E-31)

- A1 - 1-LAMP, 4' X 5", SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 1 TYPE F1 LAMP AND WRAP AROUND LENS.
- A3 - 3-LAMP, 4' X 14", SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND WRAP AROUND LENS. CHAIN SUSPENDED.
- A4 - 3-LAMP, 4' X 2'; SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND A FRAMED LENS. PENDANT MOUNTED.
- A6 - 3-LAMP, 4' X 2'; SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND A DEEP CELL PARABOLIC LENS. PENDANT MOUNTED.
- B4 - RECESSED; 3-LAMP, FLUORESCENT FIXTURE C/W 3 TYPE F1 LAMPS AND FRAMED LENS.
- B6 - RECESSED; 3-LAMP, FLUORESCENT FIXTURE C/W 3 TYPE F1 LAMPS AND A DEEP CELL PARABOLIC LENS.

- C1 - 4'; SINGLE TUBE, FLUORESCENT STRIP LIGHT. C/W 1 TYPE F1 LAMPS.
- C2 - 4'; 2-LAMP FLUORESCENT STRIP LIGHT. C/W 2 TYPE F1 LAMPS.
- C3 - 2'; SINGLE LAMP, FLUORESCENT STRIP LIGHT. C/W 1 TYPE F1 LAMPS.
- D1 - SURFACE MOUNTED, FLUORESCENT WALL SCONCE C/W PL-13 LAMPS. (FOUNTAIN)
- D2 - RECESSED CEILING MOUNTED WALL WASHER FIXTURE. C/W 2 PL-7 LAMPS. MOUNTED ABOVE FOUNTAIN.
- E5 - WALL MOUNTED (SURFACE), 4' X 8" FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS. MOUNTED 1'-0" BELOW CEILING.
- F1 - PENDANT MOUNTED; INDUSTRIAL TYPE 2-LAMP, FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS AND A SLOTTED REFLECTOR.
- V1 - 2-LAMP, SURFACE MOUNTED VAPOUR PROOF FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS.
- I4 - RECESSED, 2 LAMP FLUORESCENT FIXTURE C/W 2-13W PL LAMPS.
- I1 - WALL OR CEILING MOUNTED EXIT LIGHT. RESPECTIVELY.
- S1 - 200W, 347V SURFACE MOUNTED. METAL HALIDE FIXTURE.

## SECOND FLOOR PLAN

SCALE: 1/8" = 1'-0"

D3 SAME AS D2 EXCEPT DOWNLIGHT ONLY.

## NOTES:

1. ALL EMERGENCY AND EXIT LIGHTING ON THE SOUTH SIDE OF COLUMN D TO BE ON CIRCUIT ELP2-3.
2. ALL EMERGENCY AND EXIT LIGHTING ON THE NORTH SIDE OF COLUMN D TO BE ON CIRCUIT ELP2-10.
3. ALL LIGHTING TO BE INSTALLED USING MODULAR WIRING SYSTEM (SEE SPECIFICATION).
4. EACH PAIR OF 3-LAMP FIXTURES SHALL HAVE 3-2 LAMP BALLASTS, WIRE ACCORDINGLY.
5. DIV16 CONTRACTOR TO CONFIRM EXACT LOCATION OF ALL FIXTURES ON SITE WITH DIV.1 CONTRACTOR AND ENGINEER PRIOR TO INSTALLATION.
6. SWITCHES SHOWN IN ROOMS #203, #204, #206, #207, #210, #211, #212, #215 AS WELL AS THE MASTER SWITCH SHOWN IN THE ELEVATOR LOBBY #252 HAVE BEEN SUPPLIED UNDER CCN I-E.

FIT-UP REQUIREMENTS  
DELETION, ADDITIONS,  
AND RELOCATIONS OF  
SWITCHES AND LIGHT  
FIXTURES.

revisions  
A detail no.  
no. du détail  
B location drawing no.  
sur dessin no.  
C drawing no.  
dessin no.

project  
G.O.C.B.  
BEDFORD ROW  
HALIFAX, N.S.

drawing  
dessein  
SECOND FLOOR PLAN  
LIGHTING

ELECTRICAL

designed  
G.C. HICKS  
conçu  
date  
W. SZUBIELSKI  
dessiné  
date  
reviewed  
examined  
date  
approved  
approved  
date  
Tender  
Soumission  
PWC Project Manager  
Administrateur de projets TPC  
project number  
no. du projet  
800769  
drawing no.  
no. du dessin  
E-4