

PUMP SCHEDULE															
PUMP NO.	APPLICATION	PUMP LOCATION	PUMP TYPE	PUMP SIZE	FLOW RATE G.P.M.	HEAD FT.	MOTOR H.P.	ELECT. DATA	STARTER	STARTER LOCATION	CONTROLS	REMARKS	SUCTION GUIDE MODEL	INCREASER SIZE AT DISCH. mm	TRIPLE DUTY VALVE MODEL
P-1	BOILER N° 1 CIRCULATOR	BOILER ROOM	VERTICAL IN-LINE CENTRIFUGAL	3 x 3 x 8	350	30	5	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	24 V. CONTACT CLOSURE FROM DDC	ARMSTRONG SERIES 4360 OR EQUAL 1750 RPM	S6 43	3 x 4	FTD 44
P-2	BOILER N° 2 PRIMARY CIRCULATOR	BOILER ROOM	VERTICAL IN-LINE CENTRIFUGAL	3 x 3 x 6	350	30	5	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	24 V. CONTACT CLOSURE FROM DDC	ARMSTRONG SERIES 4360 OR EQUAL 1750 RPM	S6 43	3 x 4	FTD 44
P-3	PERIMETER HEAT CIRCULATOR	BOILER ROOM	VERTICAL IN-LINE CENTRIFUGAL	4 x 4 x 8	350	62	10	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	24 V. CONTACT CLOSURE FROM DDC	ARMSTRONG SERIES 4360 OR EQUAL 1750 RPM	S6 54	4 x 5	FTD 55
P-4	PERIMETER HEAT CIRCULATOR	BOILER ROOM	VERTICAL IN-LINE CENTRIFUGAL	4 x 4 x 6	350	62	10	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	24 V. CONTACT CLOSURE FROM DDC	ARMSTRONG SERIES 4360 OR EQUAL 1750 RPM	S6 54	4 x 5	FTD 55
P-5	HX-C-1 SHELL SIDE PUMP	BOILER ROOM	VERTICAL IN-LINE CENTRIFUGAL	4 x 4 x 8	200	30	5	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	24 V. CONTACT CLOSURE FROM DDC	ARMSTRONG SERIES 4360 OR EQUAL 1750 RPM	S6 54	4 x 5	FTD 55
P-6	GLYCOL HEATING CIRCULATOR	BOILER ROOM	VERTICAL IN-LINE CENTRIFUGAL	4 x 4 x 8	200	60	7 1/2	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	24 V. CONTACT CLOSURE FROM DDC	ARMSTRONG SERIES 4360 OR EQUAL 1750 RPM	S6 54	4 x 5	FTD 55
P-7	GLYCOL FILL PUMP	BOILER ROOM	BASE MOUNTED CENTRIFUGAL	1 1/4 x 6	10	150	3	575/60/3	COMB. MAGNETIC C/W HOD KIT	BOILER ROOM	MANUAL	ARMSTRONG SERIES 4030 3500 RPM	S6 54	4 x 5	FTD 55

EXPANSION TANK SCHEDULE (DIAPHRAM TYPE)				
LEGEND	SERVICE	TYPE	D/A	HEIGHT
EX-1	HYDRONIC HEATING	VERTICAL FLOOR MOUNTED	36"	68"
EX-2	HYDRONIC HEATING	VERTICAL FLOOR MOUNTED	36"	68"
EX-3	GLYCOL HEATING	VERTICAL FLOOR MOUNTED	36"	56"

UNIT HEATER SCHEDULE									
LEGEND	HEAT. CAP. LOW SPEED	AIR QUANTITY		WATER PD. FT.	MOTOR HP	RPM	REMARKS		
		CFM	SP						
A	11-1 MBH	175		.01	.035	700	DUNHAM BUSH CUH 100 STYLE W-3		
B	11-1 MBH	175		.01	.035	700	DUNHAM BUSH CUH 100 STYLE C-27		
C	11-9 MBH	350		.02	1/3	1550	DUNHAM BUSH H 100 C		
D	64-0 MBH	600		1-08	1/8	1100	DUNHAM BUSH H 400 C		
E	25-0 MBH	1400		2-42	1/30	1550	DUNHAM BUSH H 175 C		

PUMP SCHEDULE

UNIT HEATER SCHEDULE

revision

date

A

C

A

B

C

A: sheet no.

B: location/drawing no.

C: drawing no.

D: revision no.

project

G.O.C.B. BEDFORD ROW HALIFAX, N.S.

drawing

dessin

SCHEDULES

designed

date

drawn

date

revised

date

approved

date

checked

date

submitted

date

P. DUMARESQ

L. DEVEAU

*L. Deveau*

*06/16*

*06/16*

*06/16*

*06/16*

*06/16*

*06/16*

*06/16*

*06/16*

614362

MH-14