

Remarks	Power: 120/208 V 3 ø 4 W										PANEL PP9A										SYM. IC.: 10000 A										Remarks
	# OF CKTS.: 42										LOCATION ELEC. ROOM 405										MAINS: 225 A										
	INCOMING:																				MAIN BKR: N/A A										
	Designation				CKT #	Watts	BKR	PHASE			BKR	Watts	CKT#	Designation																	
	PRINTER				1	500	20	X			EX		2	EXISTING LOAD																	
	EXISTING LOAD				3		EX	X			EX		4	EXISTING LOAD																	
	EXISTING LOAD				5		EX		X		15	1440	6	PILT RECEPTACLES																	
	CLIENT RELATIONS RECEPTACLES				7	1440	15	X			15	1440	8	PILT RECEPTACLES																	
	CLIENT RELATIONS RECEPTACLES				9	1440	15		X		15	1440	10	PILT RECEPTACLES																	
	CLIENT RELATIONS RECEPTACLES				11	720	15			X		15	1440	12	PILT RECEPTACLES																
	APPRAISALS RECEPTACLES				13	1440	15	X			15	1440	14	OAS RECEPTACLES																	
	APPRAISALS RECEPTACLES				15	1440	15		X		15	1440	16	OAS RECEPTACLES																	
	BUSINESS CENTRE RECEPTACLES				17	240	20		X		15	1440	18	OAS RECEPTACLES																	
	BUSINESS CENTRE RECEPTACLES				19	480	20	X			15	1440	20	OAS RECEPTACLES																	
	BUSINESS CENTRE RECEPTACLES				21	480	20		X		15	1440	22	OAS RECEPTACLES																	
	VIDEO CONFERENCING				23	240	20			X		15	1440	24	OAS RECEPTACLES																
	A&PMS RECEPTACLES				25	1440	15	X			15	1440	26	OWNER/INVESTOR RECEPTACLES																	
	PLOTTER/COPPIER				27	480	20		X		15	720	28	OWNER/INVESTOR RECEPTACLES																	
	QUIET ROOMS				29	480	15			X		15	1440	30	OPEN OFFICE RECEPTACLES																
	ENVIRONMENTAL SERVICES				31	1440	15	X			15	1440	32	OPEN OFFICE RECEPTACLES																	
	ENVIRONMENTAL SERVICES				33	720	15		X		15	1440	34	BUSINESS MANAGEMENT																	
	BUSINESS MANAGEMENT				35	1440	15			X		15	1440	36	BUSINESS MANAGEMENT																
	BUSINESS MANAGEMENT				37	1440	15	X			15	1440	38	BUSINESS MANAGEMENT																	
	BUSINESS CENTRE RECEPTACLES				39	720	20		X		20	240	40	BUSINESS CENTRE RECEPTACLES																	
	APPRAISALS RECEPTACLES				41	720	15		X				42																		
FEEDER:							SOURCE:																								
Remarks:												Phase A Total				16820	W	140.2				A									
												Phase B Total				12000	W	100.0				A									
												Phase C Total				12480	W	104.0				A									
												TOTAL				41300	W	114.8				A									