


- NOTES:**

1. USE OF COMMON NEUTRALS NOT PERMITTED.
2. INSTALL 4 POWER OUTLETS ON THESE COLUMNS
SEE DETAIL ON DRAWING NO. E-26
3. INSTALL 3 POWER OUTLETS ON THESE COLUMNS
SEE DETAIL ON DRAWING NO.E-26
4. CABINET UNIT HEATERS, CUH-9 & CUH-10 ARE
WIRED WITH 2 12RWOXLP6 IN 1/2" EMT TO
CIRCUIT PPH-19. MOUNT THE MANUAL STARTER
NEXT TO THE UNIT HTR
5. DEVICE BOX AND CIRCUITRY FOR HAND DRYER.
HAND DRYERS BY DIV.1.

FIFTH FLOOR PLAN

SCALE: $\frac{1}{8}'' = 1' - 0''$

	FIT UP & F.C.C. REQUIREMENTS	91-1
revisions		da

A detail no.
no. du détail

B location drawing no.
sur dessin no.

C drawing no.
dessin no.

project

**G.O.C.B.
BEDFORD ROW
HALIFAX, N. S.**

proj

drawing

FIFTH FLOOR PLAN

POWER

ELECTRICAL

designed **A.C. HICKS** conq

drawn **W. SZUBIELSKI** dessin

reviewed *[Signature]* examined *[Signature]*
date *[Signature]* date *[Signature]*

date	10 June 1976
approved	approved

Tender Levi Soumission

PWC Project Manager	Administrateur de projets TR
project number	no. du proj
800760	

drawing no. **5 10** no. du dess

E-16