



NOTES CONT'D :

TYPE C2 FIXTURES TO BE MOUNTED  
IN VALANCE. SUPPLY TYPE K-12 LENS.  
LENS CUT TO SUIT.

SIXTH FLOOR PLAN

SCALE:  $\frac{1}{8}'' = 1' - 0''$

**NOTES:**

1. ALL EMERGENCY AND EXIT LIGHTING FOR THIS FLOOR ON CIRCUIT ELP2-7.
2. SEE DRAWING E-7 FOR INSTALLATION DETAIL OF BRIDGE AND ATRIUM LIGHTING.
3. ALL LIGHTING TO BE INSTALLED USING MODULAR WIRING SYSTEM. (SEE SPECIFICATION )
4. EACH PAIR OF 3 - 1 AMP FIXTURES HAVE 3 - 2 AMP BALLASTS, WIRE ACCORDINGLY.
5. DIV.6 CONTRACTOR TO CONFIRM EXACT LOCATION OF ALL FIXTURES ON SITE WITH DIV.1 CONTRACTOR AND ENGINEER PRIOR TO LOCATION.
6. SWITCHES SHOWN IN ROOMS \*605,\*606,\*608,\*609 AS WELL AS THE MASTER SWITCH SHOWN IN THE ELEVATOR LOBBY \*630 HAVE BEEN SUPPLIED UNDER CCN I-E.