



LIGHTING LEGEND:

(REFER TO MAIN LEGEND ON DRAWING E-31)

- A1 - 1-LAMP, 4' X 5", SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 1 TYPE F1 LAMP AND WRAP AROUND LENS.
- A3 - 3-LAMP, 4' X 14", SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND WRAP AROUND LENS. CHAIN SUSPENDED.
- A4 - 3-LAMP, 4' X 2'; SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND A FRAMED LENS. PENDANT MOUNTED.
- A6 - 3-LAMP, 4' X 2'; SURFACE MOUNTED FLUORESCENT FIXTURE. C/W 3 TYPE F1 LAMPS AND A DEEP CELL PARABOLIC LENS. PENDANT MOUNTED.
- B4 - RECESSED; 3-LAMP, FLUORESCENT FIXTURE C/W 3 TYPE F1 LAMPS AND FRAMED LENS.
- B6 - RECESSED; 3-LAMP, FLUORESCENT FIXTURE C/W 3 TYPE F1 LAMPS AND A DEEP CELL PARABOLIC LENS.

- C1 - 4'; SINGLE TUBE, FLUORESCENT STRIP LIGHT. C/W 1 TYPE F1 LAMPS.
- C2 - 4'; 2-LAMP FLUORESCENT STRIP LIGHT. C/W 2 TYPE F1 LAMPS.
- C3 - 2'; SINGLE LAMP, FLUORESCENT STRIP LIGHT. C/W 1 TYPE F1 LAMPS.
- D1 - SURFACE MOUNTED, FLUORESCENT WALL SCONCE C/W PL-13 LAMPS. (FOUNTAIN)
- D2 - RECESSED CEILING MOUNTED WALL WASHER FIXTURE. C/W 2 PL-7 LAMPS. MOUNTED ABOVE FOUNTAIN.
- E5 - WALL MOUNTED (SURFACE), 4' X 8" FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS. MOUNTED 1'-0" BELOW CEILING.
- F1 - PENDANT MOUNTED; INDUSTRIAL TYPE 2-LAMP, FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS AND A SLOTTED REFLECTOR.
- V1 - 2-LAMP, SURFACE MOUNTED VAPOUR PROOF FLUORESCENT FIXTURE C/W 2 TYPE F1 LAMPS.
- I4 - RECESSED, 2 LAMP FLUORESCENT FIXTURE C/W 2-13W PL LAMPS.
- S1 - WALL OR CEILING MOUNTED EXIT LIGHT. RESPECTIVELY.
- 200W, 347V SURFACE MOUNTED. METAL HALIDE FIXTURE.

FIRST FLOOR PLAN

SCALE: 1/8" = 1'-0"

NOTES:

1. ALL EMERGENCY AND EXIT LIGHTING ON THE SOUTH SIDE OF COLUMN D TO BE ON CIRCUIT ELP2-2.
2. ALL EMERGENCY AND EXIT LIGHTING ON THE NORTH SIDE OF COLUMN D TO BE ON CIRCUIT ELP2-1.
3. ALL LIGHTING TO BE INSTALLED USING MODULAR WIRING SYSTEM. (SEE SPECIFICATION).
4. EACH PAIR OF 3-LAMP FIXTURES SHALL HAVE 3-2 LAMP BALLASTS. WIRE ACCORDINGLY.
5. IN ROOMS 105, 106, 108, 109, 113, 126, 127, 128, 142, 155, AS WELL AS THE MASTER SWITCH SHOWN IN THE ELEVATOR LOBBY HAVE BEEN SUPPLIED UNDER CCN I-E.
6. DIV.16 CONTRACTOR TO CONFIRM EXACT LOCATION OF ALL FIXTURES ON SITE WITH DIV.1 CONTRACTOR AND ENGINEER PRIOR TO INSTALLATION.
7. SWITCHES SHOWN IN ROOMS #112, #113, #125, #126, #127, #128, #142, #155, AS WELL AS THE MASTER SWITCH SHOWN IN THE ELEVATOR LOBBY HAVE BEEN SUPPLIED UNDER CCN I-E.

FIT-UP REQUIREMENTS DELETION, ADDITIONS AND RELOCATIONS OF SWITCHES AND LIGHT FIXTURES.

NOV. 1991

G.O.C.B. BEDFORD ROW HALIFAX, N.S.

FIRST FLOOR PLAN LIGHTING

ELECTRICAL

designed G.C. HICKS
 date
 drawn W.S. ZUBIELSKI
 date
 reviewed
 date
 approved
 date
 Tender
 PWC Project Manager
 project number
 800769
 drawing no. E-3