



Materiel and Procurement Services
200 Kent Street, Station 9W067
Ottawa, Ontario
K1A 0E6

FP802-170153

August 28, 2017

Subject: Invitation to Tender: FP802-170153

Title: Guyed Tower Replacement CCG Cobourg MCTS Site

Work site location: Cold Springs, ON

ADDENDUM: No. 2

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#2) is hereby issued.

Question 1:

Please advise the required twist and tilt requirements at serviceability Class I.

Answer 1:

The tower's resultant deviation from verticality must not exceed 175 mm and the twist must be below 3° with respect to the ground elevation at serviceability Class I.

All other Terms and Conditions for this requirement remain unchanged.

Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.

Yours truly,

Natasha Blackstein

Senior Contracting Officer

Tel: (613) 993-5741

E-mail: Natasha.Blackstein@dfo-mpo.gc.ca

RECEIPT ACKNOWLEDGED



Fisheries and Oceans
Canada

Pêches et Océans
Canada

Name of Company _____

Signature _____

Canada