

Project No.:
F2301-170025

August 29, 2017

The following changes to the tender documents are effective immediately and will form part of the contract documents:

This Addendum forms part of the contract documents and is to be read, interpreted, and co-ordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form. Failure to do so may subject the Bidder to disqualification. The following information supplements and/or supersedes the bid documents issued on the following date: August 15, 2017.

Architectural:

Refer to Drawing 1/A1.4: Doors & Windows Elevation

1. Window W01:
 - a. Frame to be Knock-Down Type, 45m FRR.
 - b. Remove Centre Mullion from Window Frame.
 - c. Window not required to be thermally broken.

2. Window W02:
 - a. Frame to be Knock-Down Type, 45m FRR.
 - b. Remove Centre Mullion from Window Frame.
 - c. Window not required to be thermally broken.

3. Window W03:
 - a. Frame to be Knock-Down Type, 45m FRR.
 - b. Window not required to be thermally broken.

End of Addendum