



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

004

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet East Block Scenic Drive Grasslands National Park	
Solicitation No. - No. de l'invitation 5P420-17-5233/A	Date: August 29, 2017
GETS Reference No. - No de reference de SEAG PW-17-00789796	Amendment No. - N° de la modif. 004
Solicitation Closes:	
at - á 02:00 PM	on - le September 1, 2017
Time Zone - Fuseau horaire MDT - HAR	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :	
Jen Maheu	
Telephone No. - No de téléphone (403) 292-8502	Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
See Herein - Voir ici	

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 04

This amendment is being raised to answer bidder questions from the mandatory site visit and submitted by email.

A) SITE VISIT QUESTIONS

Q1 What are the actual limits of disturbance on either side of the road?

A1 The drawings show 5 m. The mitigations allow 8.25 m on either side of the edge of road. This will be the maximum distance allowed for disturbance on either side of the road. Any incursion outside these limits will not be permitted without prior written approval by the departmental representative.

Q2 Who will the permit for construction be issued to?

A2 The permit for construction issued under the Species At Risk legislation will be issued directly to the contractor with the mitigations for the work attached. The contractor is responsible to make sure these mitigations are followed for the duration of their work. Infractions to these mitigations will be addressed directly to the permit holder.

Q3 Who will do the fence removal that was identified during the tour?

A3 Parks Canada will look after the removal of the identified section of fence prior to construction of the roadway.

Q4 Is there concerns about where the contractor obtains water for use during construction?

A4 Yes. No water is available from within the park. Please refer to Section 01 14 00 Clause 1.2.4

B) QUESTIONS SUBMITTED BY EMAIL

Q5 How are the permanent signs put in? How deep? Concrete? Etc.

A5 The Contractor shall manufacture and install permanent posts and signage in accordance with the Parks Canada – Exterior Signage Standards and Guidelines. Permanent signage for this contract shall be mounted to posts that have been installed using the Direct Embedment procedure located in Section 6.2.1 of the Parks Canada – Exterior Signage Standards and Guidelines. Flanges and coatings are considered incidental to the bid item. The Parks Canada – Exterior Signage Standards and Guidelines are available at <https://www.pc.gc.ca/en/agence-agency/bib-lib/~media/ABA2B1DBDDCB4CA099842D1CEDC81969.ashx>

Q6 For the gates, do they tie into an existing fence or what?

A6 The Swing Gate at STA: 50+025 and Livestock Guard at STA: 0+025 are located where no existing fence is present, so the Contractor shall not be required to tie these items to fences. The Livestock Guard on the Access Road located at the Park Boundary (STA: 50+532) will be required to be tied into the existing barbed wire fence by the Contractor. Any additional posts, wire or other items required to tie the Livestock Guard to the existing fence are considered incidental to the item as per Section 32 31 26 - Clause 1.2.4.

All other terms and conditions remain unchanged.