



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Snowsheds Drainage Glacier National Park	
Solicitation No. - No. de l'invitation 5P420-17-5252/A	Date: August 29, 2017
GETS Reference No. - No de reference de SEAG PW-17-00791249	Amendment No. - N° de la modif. 002
Solicitation Closes:	
at - á 02:00 PM	on - le September 6, 2017
Time Zone - Fuseau horaire MDT - HAR	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :	
Jen Maheu	
Telephone No. - No de téléphone (403) 292-8502	Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
See Herein - Voir ici	

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 02

This amendment is being raised to answer bidder questions and make changes to the tender package.

A) BIDDER QUESTIONS

Q1 What is the equipment weight limit for working on each snow shed?

A1 *31,000 lbs operating weight for tracked vehicles, minimum track length of 2.9 m and track gauge of 1.78 m*

Q2 When does it typically start to snow at Roger's pass? When will the seasonal shut down commence for 2017?

A2 *Refer to Specification Section 01 11 00 Summary of Work 1.7.5.5. Contractor shall access public weather records and make their own determination in regards to typical weather patterns.*

Q3 When will the contractor be expected to commence work in the spring?

A3 *Refer to Specification Section 01 11 00 Summary of Work 1.7.5.6. Although no guarantee is provided, this has typically occurred in early June.*

Q4 Can PCA please provide a stockpile location for the Type D to Stockpile and Type D Unsuitable? It's impossible to price without knowing the location and distance of the haul.

A4 *Delete Section 31 24 13 Clause 1.6.3 in its entirety and replace with "Contractor may stockpile surplus Type D material that is suitable for use as embankment fill, and screened Stripping material at the East Gate Landslide area at approximately Trans-Canada Highway KM 3. The Contractor shall dispose of all material that is unsuitable for use as embankment fill at a location provided by them outside the Parks at their cost."*

Q5 The Specified liner is a proprietary product to Colas Canada, who only limit their company ACP Applied Products to install. There are other products out there that are better and much cheaper. Can Parks Canada specify an actual specification, such as a permeability, life cycle, etc. of a product so PCA and tax payers get the best value?

A5 *The Bituminous Geomembrane ES2 Liner is a reference product for baseline technical requirements rather than a specified product. In accordance with Specification Section 31 32 20 alternative BGM products shall meet or exceed, tested to ASTM Standards, the reference product's characteristics. ASTM Technical Data sheets for the ES2 Liner are publicly available for reference. Contractor proposed alternative products shall be submitted for review prior to Solicitation Close.*

B) TENDER PACKAGE CHANGES

Section 31 24 13

Delete: Section 31 24 13 Clause 1.6.3 in its entirety

Replace with: Contractor may stockpile surplus Type D material that is suitable for use as embankment fill, and screened Stripping material at the East Gate Landslide area at approximately Trans-Canada Highway KM 3. The Contractor shall dispose of all material that is unsuitable for use as embankment fill at a location provided by them outside the Parks at their cost.

All other terms and conditions remain unchanged.