



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

005

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet East Block Scenic Drive Grasslands National Park	
Solicitation No. - No. de l'invitation 5P420-17-5233/A	Date: August 31, 2017
GETS Reference No. - No de reference de SEAG PW-17-00789796	Amendment No. - N° de la modif. 005
Solicitation Closes:	
at - á 02:00 PM	on - le September 6, 2017
Time Zone - Fuseau horaire MDT - HAR	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :	
Jen Maheu	
Telephone No. - No de téléphone (403) 292-8502	Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
See Herein - Voir ici	

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 05

This amendment is being raised to change the solicitation closing date and answer additional bidder questions from the mandatory site visit.

A) BID CLOSING DATE

The closing date for tender 5P420-17-5233/A, titled *East Block Scenic Drive - Grasslands National Park*, is extended from September 1, 2017 until September 6, 2017 at 2:00PM Mountain Daylight Time (MDT).

B) SITE VISIT QUESTIONS

Q7 Where should waste be removed to?

A7 Please refer to Section 01 14 00 – Clause 1.14 as well as Section 01 35 43. The Contractor shall be responsible for the storage and transport of all waste material to an approved facility outside of the Park.

Q8 Does the contract require the contractor supply of aggregates?

A8 Yes, the tender documents refer to the EPS specification which included the incidental supply of aggregates.

Q9 Can the Asphalt plant be set up in the Park?

A9 No, please refer to Section 32 12 16 – Clause 3.3

Q10 If the Asphalt Plant is set up in a private pit, or any other location outside of the park, do the emissions restrictions have to be followed?

A10 Yes, please refer to Section 32 12 16 – Clause 3.3

Q11 Can interim stockpiles be located within the Park or at Poverty Ridge?

A11 Yes, as long as the stockpile locations are approved by the ESO, and all remediation of the areas occurs following the completion of the project. Stockpiling of any materials in park, outside of the Poverty Ridge site, must be kept within the disturbed ROW for the project and have prior written approval from the ESO.

Q12 Can topsoil stockpiles be located outside of the limit of disturbance?

A12 The contractor is responsible for planning their operations. The disturbed areas can not exceed the limit of disturbance without the prior consent of the ESO, and only then once the mitigations are followed. Stockpiles will be permitted at the Poverty Ridge area, but also must follow the requirements of the ESO and must be remediated to the satisfaction of the ESO.

Q13 Is surplus common excavation considered waste?

A13 No. Surplus common excavation, should it exist in the project, shall remain within the Park.

Q14 The subdrain quantity doesn't match the length of the road. What are the locations of the subdrain?

A14 The areas that subdrain is to be installed is shown on the bottom of the profile in the drawings.

Q15 When installing the subdrains, are drainage basins to below the frost level included in the unit length?

A15 Yes, this work would be considered incidental to the item.

Q16 Does the limit of disturbance remain at 8.25m from the edge of pavement where the parking lots and laybys are located?

A16 Yes, the limit of disturbance follows the edge of pavement.

Q17 In areas where the escarpment are within 8.25m of the edge of pavement, can the contractor reduce the limit of disturbance on the side of the escarpment and widen it on the other side of the road?

A17 No, in these areas the limit of disturbance shall remain at 8.25m unless the contractor applies for an increased disturbed area and provides accepted mitigation measures as determined by the ESO.

Q18 What is the completion date?

A18 Please refer to the Addenda for the project as the completion date has been modified.

Q19 Are the Viewpoints and pathways to the viewpoints included in this contract?

A19 No, the viewpoints and pathways to the viewpoints are a separate project.

Q20 Where does the excess material from the Scenic Roadway excavation go to?

A20 The project is mass balanced to accept the excavated material from the Scenic Road in the South Access Road.

Q21 Where does the Geotextile go on the road?

A21 Please refer to the typical section for the Scenic Road which shows the location of the geotextiles between the compacted subcut and the granular.

Q22 Is the entire road subcut?

A22 Yes

Q23 Should unforeseen items arise, or large rocks be encountered, how will PCA handle these situations?

A23 The Prime Cost Sum is included to allow for such unforeseen circumstances. Please refer to Section 01 21 00, and note that as per Clause 1.2 The Prime Cost Sum is not a sum due to the Contractor, rather payment will be made against it for miscellaneous work. Should PCA elect not to use the Prime Cost Sum for the unforeseen items, other options such as change orders are possible.

All other terms and conditions remain unchanged.