



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Admin Building Enclosure Renewal	
Solicitation No. - N° de l'invitation EZ899-180045/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2017-09-01
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8145	
File No. - N° de dossier PWY-7-40124 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-13	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - Gulf of Georgia Cannery - Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-180045/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
006
File No. - N° du dossier
pwy-7-40124

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

This Solicitation Amendment 006 is raised to incorporate Addendum No. 4.

Please find following Addendum No. 4.

All other terms and conditions remain unchanged.

*The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents*

Amend/revise the Standard Contract Documents as follows:

1.0 CHANGES AND CLARIFICATIONS

1.1 Can specifications for masonry be provided?

There is no new masonry on the project. Refer to the structural drawings and section 03 30 53 - Miscellaneous Cast-In-Place Concrete – of the technical specifications for additional information on masonry reinforcing, grout, and fastening requirements.

1.2 What is the make-up of the existing roofing on the Administration Building?

Assume the existing roof assembly of the Administration Building is as follows:

- 2-ply SBS membrane
- Protection board
- Tongue and groove ship-lap decking
- 38 x 286mm joists
- Batt insulation with kraft paper facing within joist cavity
- Interlocking 305 x 305mm fiberboard acoustic ceiling tile fastened to wood strapping at underside of joists (typical), or gypsum board ceiling (mech. room. and archive room), or interlocking 305 x 305mm fiberboard acoustic ceiling tile fastened to wood strapping at underside of joists inside suspended T-bar ceiling cavity (where indicated on A-1.3).

1.3 The SBS specifications indicate ballast and paver underlay – can this be clarified if it is required?

Ballast and pavers are not required for the project.

END OF ADDENDUM No. 4