
PART 1 **GENERAL**

1.1 **RELATED SECTIONS**

- .1 Section 01 74 21 – Construction/Demolition Waste Management and Disposal.
- .2 Section 01 45 00 - Quality Control.
- .3 Section 01 51 00 - Temporary Utilities.
- .4 Section 07 26 00 –Vapour Retarders.

1.2 **REFERENCES**

- .1 American Society for Testing and Materials (ASTM)
 - .1 ASTM D1621, Standard Test Method for Compressive Properties of Rigid Cellular Plastics.
 - .2 ASTM D1622, Standard Test Method for Apparent Density of Rigid Cellular Plastics.
 - .3 ASTM D1623, Standard Test Method for Tensile and Tensile Adhesion Properties of Rigid Cellular Plastics.
 - .4 ASTM D2842, Standard Test Method for Water Absorption of Rigid Cellular Plastics.
 - .5 ASTM E96, Standard Test Methods for Water Vapour Transmission of Materials.
 - .6 ASTM E2178, Standard Test Method for Air Permeance of Building Materials.
- .2 Canadian Urethane Foam Contractors' Association Inc. (CUFCA)
- .3 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S101, Fire Endurance Tests of Building Construction and Materials.
 - .2 CAN/ULC-S102, Surface Burning Characteristics of Building Materials and Assemblies.
 - .3 CAN/ULC-S705.1, Standard for Thermal Insulation Spray Applied Rigid Foam, Medium Density, Material Specification.
 - .4 CAN/ULC-S705.2, Standard for Thermal Insulation Spray Applied Rigid Foam, Medium Density, Installer's Responsibilities-Specification.

1.3 **SUBMITTALS**

- .1 Product Data:
 - .1 Submit manufacturer's printed product data literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.

- .2 Submit two copies of WHMIS MSDS – Material Safety Data Sheets.
- .2 Test Reports
 - .1 Submit certified test reports, from approved independent testing laboratories verifying qualities of insulation meet or exceed requirements of this specification.
 - .2 Submit test reports in accordance with CAN/ULC-S101 for fire endurance and CAN/ULC-S102 for surface burning characteristics.
 - .3 Submit manufacturer's installation instructions and special handling criteria, installation sequence and cleaning procedures.

1.4 QUALITY ASSURANCE

- .1 Installer to conform to CUFGA Quality Assurance Program or an equivalent recognized quality assurance and training program.
- .2 Qualifications:
 - .1 Installer: person specializing in sprayed insulation installations with minimum 5 years experience approved by manufacturer.
 - .2 Manufacturer: company with minimum 5 years experience in producing of material used for work required for this project, with sufficient production capacity to produce and deliver required units without causing delay in work.

1.5 MOCK-UP

- .1 Construct mock-up in accordance with Section 01 45 00 - Quality Control.
- .2 Construct mock-up 10 m² minimum, of spray in place urethane foam insulation including one inside corner and one outside corner. Mock-up may be part of finished work.
- .3 Allow two (2) working days for inspection of mock-up by Owner's Representative before proceeding with waterproofing work.

1.6 SAFETY REQUIREMENTS

- .1 Protect workers as recommended by CAN/ULC-S705.2 and manufacturer's recommendations:
 - .1 Workers must wear gloves, respirators, dust masks, eye protection, protective clothing when applying foam insulation.
 - .2 Workers must not eat, drink or smoke while applying foam insulation.

1.7 PROTECTION

- .1 Ventilate area in accordance with Section 01 51 00 - Temporary Utilities.
- .2 Ventilate area to receive insulation by introducing fresh air and exhausting air continuously during and 24 hours after application to maintain non-toxic, unpolluted, safe working conditions.

- .3 Provide temporary enclosures to prevent spray and noxious vapours from contaminating air beyond application area.
- .4 Protect adjacent surfaces and equipment from damage by overspray, fall-out, and dusting of insulation materials.
- .5 Dispose of waste foam daily in location designated by Owner's Representative and decontaminate empty drums in accordance with foam manufacturer's instructions.

1.8 ENVIRONMENTAL REQUIREMENTS

- .1 Apply insulation only when surfaces and ambient temperatures are within manufacturers' prescribed limits.

1.9 WARRANTY

- .1 Provide a written guarantee, signed and issued in the name of the owner, stating the sprayed polyurethane foam insulation shall remain free from defects in materials and workmanship for a period of one (1) year from the date of Substantial Completion.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Insulation: spray polyurethane open cell foam to CAN/ULC-S705.1, thickness and RSI Value as indicated on drawings.
 - .1 Initial thermal resistance: minimum RSI 2.5 per 50 mm.
 - .2 Long term thermal resistance: minimum RSI 2.0 per 50 mm.
 - .3 Density: 0.000016 kg/m³ or less, to ASTM D1622.
 - .4 Air barrier properties: to ASTM E2178.
 - .1 @75 Pa: maximum 0.05 L/s.
 - .5 Water Vapour Permeance, to ASTM E96:
 - .1 50 mm thick: maximum 60 ng/(Pa.s.m²).
 - .6 Tensile Strength: minimum 200 kPa, to ASTM D1621.
 - .7 Flame Spread: to CAN/ULC-S102, in accordance with the latest edition of the National Building Code.
 - .8 Water Absorption by volume: maximum 4%, to ASTM D2842.
- .2 Primers: in accordance with manufacturer's recommendations for surface conditions.

PART 3 **EXECUTION**

3.1 **MANUFACTURER'S INSTRUCTIONS**

- .1 Comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 **APPLICATION**

- .1 Apply insulation to clean surfaces in accordance with CAN/ULC-S705.2 and manufacturer's printed instructions.
- .2 Use primer where recommended by manufacturer.
- .3 Apply sprayed foam insulation in thickness as indicated to seal all openings in exterior wall envelope to produce a continuous air/vapour barrier.

3.3 **FIELD QUALITY CONTROL**

- .1 Manufacturer's Field Services:
 - .1 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.

3.4 **CLEANING**

- .1 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

PART 1 **GENERAL**

1.1 **RELATED WORK**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 35 43 - Environmental Procedures.
- .3 Section 01 45 00 - Quality Control.
- .4 Section 01 61 00 - Common Product Requirements.
- .5 Section 01 74 11 - Cleaning.
- .6 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .7 Section 01 78 00 - Closeout Submittals.
- .8 Section 06 10 00 - Rough Carpentry.
- .9 Section 07 62 00 - Sheet Metal Flashing and Trim.
- .10 Section 07 92 00 - Joint Sealants.

1.2 **REFERENCES**

- .1 American Society for Testing and Materials (ASTM)
 - .1 ASTM C 1177/C1177M, Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing.
- .2 Canadian General Standards Board (CGSB).
 - .1 CGSB 37-GP-19M, Cement, Plastic, Cutback Tar.
 - .2 CAN/CGSB-37.29, Rubber- Asphalt Sealing Compound.
 - .3 CAN/CGSB - 51.33 Vapour Barrier Sheet, Excluding Polyethylene, for Use in Building Construction.
- .3 Canadian Roofing Contractor's Association (CRCA)
 - .1 CRCA Specification Manual.
- .4 Underwriters Laboratories' of Canada (ULC)
 - .1 CAN/ULC-S701, Thermal Insulation, Polystyrene, Boards and Pipe Covering.
 - .2 CAN/ULC-S702.2, Standard for Mineral Fibre Thermal Insulation for Buildings.
 - .3 CAN/ULC-S704, Thermal Insulation, Polyurethane and Polyisocyanurate Boards, Faced.

1.3 SHOP DRAWINGS

- .1 Indicate in shop drawings flashings, control joints, and all required roofing materials.

1.4 STORAGE AND HANDLING

- .1 Refer to Section 01 61 00 - Common Product Requirements for storage and handling requirements.
- .2 Store materials off-ground in weatherproof storage.
- .3 Store materials in upright position. Store membrane rolls with selvage edge up, store as per manufacturer's requirements to meet warranty.
- .4 Remove only in quantities required for same day use.
- .5 Place plywood runways over work to protect work and enable work flow.
- .6 Store sealants at +5°C minimum.

1.5 ENVIRONMENTAL REQUIREMENTS

- .1 Do not install roofing when temperature remains below -18°C for torch application, or to manufacturers' recommendations for mop application.
- .2 Minimum temperature for solvent-based adhesive is -5°C.
- .3 Install roofing on dry deck, free of snow and ice, use only dry materials and apply only during weather that will not introduce moisture into roofing system.

1.6 PROTECTION

- .1 Fire Extinguishers: maintain one stored pressure rechargeable type with hose and shut-off nozzle, ULC labeled for A, B and C class protection. Size 9 kg on roof per torch applicator, within 10 m of torch applicator.
- .2 Contractor to provide safety person on site at all times during the roofing process and shall remain on site two (2) hours after work has ceased or after torching has stopped. Safety person shall scan the perimeter and roof penetration details with a hand held infrared gun.

1.7 WARRANTY

- .1 Provide a written guarantee signed and issued in the name of The Owner by the Roofing System Manufacturer stating that roofing membrane is free from manufacturing defects and that the system will stay in place and remain leak proof for a period of ten (10) years from date of Substantial Certificate of Completion, subject to the standard limitations and conditions of the manufacturer.

- .2 Provide a written guarantee, signed and issued in the name of the Owner by the Contractor, stating that the roofing application has been performed in compliance with the plans and specifications, and for two (2) years from the date of Substantial Certificate of Completion, the Contractor shall repair, at no expense to the Owner, any defects which result of a failure to comply with the plans and specifications.
- .3 Defective work shall include, but not limited to: leaking, wind uplift, delamination of roofing materials, reduction of thermal value due to moisture in insulation, crazing and ridging.
- .4 Warranty to be non-prorated.

1.8 COMPATIBILITY

- .1 Compatibility between components of roofing system is essential. Provide written declaration to Departmental Representative stating that materials and components, as assembled in system, meet this requirement.

1.9 QUALITY ASSURANCE

- .1 Membrane: applied by applicator acceptable to Departmental Representative and approved by manufacturer for application of its products.
- .2 Manufacturer's representative:
 - .1 Inspect roofing system at the start of construction, midway and as required for commissioning. Additional inspections may be carried out at the discretion of the Roofing System Manufacturer.
 - .2 Provide technical assistance where required to correct installation of roofing system.
- .3 Refer to Section 01 33 00 – Submittal Procedures and Section 01 45 00 - Quality Control for submission procedures.
- .4 Submit laboratory test reports certifying compliance of bitumens and membranes with specification requirements.

1.10 MOCK-UP

- .1 If requested construct mock-up in accordance with Section 01 45 00 - Quality Control.
- .2 Mock up to be 10 m² minimum size showing typical membrane lap joint, one inside and one outside corner parapet flashing. Insulation and fastening method, air/vapour barrier lap, gypsum board and fastening method and workmanship.
- .3 Allow two (2) working days for inspection of mock-up by Departmental Representative before proceeding with roofing work.
- .4 Accepted mock up may form part of completed work.

PART 2 **PRODUCTS**

2.1 **COVER BOARD COMPONENTS**

- .1 Cover Board: Nonstructural, glass mat faced gypsum panel with water-resistant core to ASTM C1177, 6.35 mm thick.
- .2 Asphalt Recover Board: Semi-rigid asphalt roofing substrate composed of mineral core between glass fibre mats, 1200 x 1500mm sheets, minimum thickness 3.0 mm.
- .2 Two layers of Asphalt Recover Board:
 - .1 Two layers of Asphalt Recover Board: Semi-rigid asphalt roofing substrate composed of mineral core between glass fibre mats, 1200 x 1500mm sheets, minimum thickness 3.0 mm each.

2.2 **BASE SHEET**

- .1 Base Sheet: Base sheet: to CGSB-37.56-M, Styrene-Butadiene-Styrene (SBS) elastomeric polymer, prefabricated sheet, non woven, polyester reinforcement, weighing 180 g/m².
 - .1 Type 2, fully adhered.
 - .2 Class P-plain surfaced.
 - .3 Grade 2.
 - .4 Top and bottom surfaces:
 - .1 Polyethylene/polyethylene.
 - .5 Base sheet membrane properties:
 - .1 Strain energy (longitudinal/transversal): 9.0/7.0 kN/m.
 - .2 Breaking strength (longitudinal/transversal): 17.0/12.5 N/5 cm.
 - .3 Ultimate elongation (longitudinal/transversal): 60/65 %.
 - .4 Tear resistance: 60 N.
 - .5 Cold bending at -30 degrees C : no cracking.
 - .6 Static puncture resistance: > 400.
 - .7 Dimensional Stability: -0.3 / 0.3 %.

2.3 **CAP SHEET**

- .1 Cap sheet: to CGSB-37.56-M, Styrene-Butadiene-Styrene (SBS) elastomeric polymer, prefabricated sheet, glass, polyester reinforcement, weighing 250 g/m².
 - .1 Type 2, fully adhered.
 - .2 Class G-granule surfaced.
 - .3 Grade 2.
 - .4 Bottom surface polyethylene.
 - .5 Colour to match adjacent Concession Stand unless otherwise indicated.

- .6 Cap sheet membrane properties:
 - .1 Strain energy (longitudinal/transversal): 10.0/10.0 kN/m.
 - .2 Breaking strength (longitudinal/transversal): 18.0/10.0 kN/m.
 - .3 Ultimate elongation (longitudinal/transversal): 60/65 %.
 - .4 Tear resistance: 75 N.
 - .5 Cold bending at -30 degrees C: No cracking.
 - .6 Static puncture resistance: > 420.
 - .7 Dimensional Stability: -0.8 / -0.2 %.
- .2 Minimum total thickness if base sheet and cap sheet combined to be 5.8 mm. Cap sheet and base sheet to be of same manufacturer.
- .3 Install contrasting colour cap sheet, 2.0 m wide, along the entire perimeter of all roof sections. Contrasting colour cap sheet to be installed over cap sheet. Colour to be as per Departmental Representative selection from manufacturer's standard colour range.

2.4 BASE SHEET FLASHING

- .1 To CGSB-37.56-M, Type 2, Class C, Grade 2, non-woven polyester reinforced 180g/m², self-adhesive membrane with polyethylene top face and release film under face.

2.5 SEALERS

- .1 Mastic made of synthetic rubbers, plasticized with bitumen and solvents with aluminum pigments to provide greater resistance to U.V.

2.6 PRIMERS

- .1 For self-adhesive membranes: A blend of elastomeric bitumen, volatile solvents and adhesive enhancing resins used to prime porous and non-porous substrates such as gypsum board, wood, concrete or metal to enhance the adhesion of self-adhesive membranes at temperatures above -10°C.
- .2 For heat welded membranes: A blend of elastomeric bitumen, volatile solvents and adhesive enhancing additives used to prime concrete or metal substrates to enhance the adhesion of torch-applied membranes.

2.7 FASTENERS

- .1 Fasteners: minimum #14 mechanical fasteners made of case-hardened carbon steel with corrosion resistance coating, complying with FM standards. 75 mm diameter round or hexagon stress plates complying with CSA B35.3 and FM 4470 approval standards, diameter and lengths as required to suit total assembly thickness. Ensure fasteners have the following deck penetration:
 - .1 For concrete decks: minimum 25 mm.

- .2 For wood decks: minimum 25 mm.
 - .3 For metal decks: minimum 19 mm and maximum 25 mm longer than assembly being secured. Fasteners to engage metal deck top flange. At gymnasium locations, fastener points of all fasteners to be removed.
- .2 Roofing adhesive: single-component, moisture cured, solvent free polyurethane adhesive, dispensed from a portable disposable pre-pressurized container.

PART 3 EXECUTION

3.1 WORKMANSHIP

- .1 Do roofing work in accordance with applicable, standard in Canadian Roofing Contractors Association (CRCA) Roofing Specifications Manual, except where specified otherwise.

3.2 PROTECTION

- .1 Cover walls and adjacent work where materials hoisted or used.
- .2 Use warning signs and barriers. Maintain in good order until completion of work.
- .3 Clean off drips and smears of bituminous material immediately.
- .4 Dispose of rain water off roof and away from face of building. Refer to Section 01 35 43 - Environmental Procedures for site drainage requirements.
- .5 Protect roof from traffic and damage.
- .6 At end of each day's work or when stoppage occurs due to inclement weather, provide protection for completed work and materials out of storage.
- .7 Take necessary measures ensuring no penetration of the elements will occur to the building after commencement of work, including but not limited to water.

3.3 EXAMINATION ROOF DECKS

- .1 Examine roof decks and immediately inform the Departmental Representative in writing of defects.
- .2 Prior to commencement of work ensure:
 - .1 Decks are firm, straight, smooth, dry, and free of snow, ice or frost, and swept clean of dust and debris.
 - .2 Plywood and lumber nailer plates have been installed to deck, walls and parapets as indicated.
- .3 Do not install roofing materials during rain or snowfall.

3.4 EXPOSED MEMBRANE ROOFING APPLICATION (WOOD DECK)

- .1 Cover Board Components:
 - .1 Loosely lay cover board over wood deck.
 - .2 Place boards in parallel rows with ends staggered and in firm contact with one another.
 - .3 Cut end boards to suit.
 - .4 Mechanically fasten asphalt recover board over cover board with plates and fasteners.
 - .5 Fit boards tight together. Stagger joints between asphalt recover board and cover board. Install fasteners/adhesive based on design wind uplift securement requirements, for the building site location, for insulation and cover board, using FMRC approved fasteners placed in accordance with manufacturer's recommendations.

- .2 Base Sheet Application:
 - .1 Starting at low point of roof, perpendicular to slope, unroll base sheet, align and reroll from both ends.
 - .2 Unroll and torch base sheet onto recover board taking care not to burn membrane or its reinforcement.
 - .3 Lap sheets 75 mm minimum for side and 150 mm minimum for end laps.
 - .4 Application to be free of blisters, wrinkles and fishmouths.

- .3 Cap Sheet Application:
 - .1 Starting at low point on roof, perpendicular to slope, unroll cap sheet, align and reroll from both ends.
 - .2 Unroll and torch cap sheet onto base sheet taking care not to burn membrane or its reinforcement.
 - .3 Lap sheets 75 mm minimum for side laps and 150 mm minimum for end laps. Offset joints in cap sheet 300 mm minimum from those in base sheet.
 - .4 Application to be free of blisters, fishmouths and wrinkles.
 - .5 Do membrane application in accordance with manufacturer's recommendations.

- .4 Flashings:
 - .1 Complete installation of flashing base sheet stripping prior to installing membrane cap sheet.
 - .2 Torch, base and cap sheet onto substrate in 1 metre wide strips.
 - .3 Lap flashing base sheet to membrane base sheet minimum 150 mm and seal by torch welding.
 - .4 Lap flashing cap sheet to membrane cap sheet 250 mm minimum and torch weld.
 - .5 .Provide 75 mm minimum side lap and seal.

- .6 Properly secure flashings to their support, without sags, blisters, fishmouths or wrinkles.
- .7 Do work in accordance with manufacturer's recommendations.

3.5 ROOF PENETRATIONS

- .1 Install roof drain pans, vent stack covers and other roof penetration Flashings and seal to membrane in accordance with the manufacturer's recommendations and details.
- .2 All new roof drains and relocated roof drains to be installed by certified plumber. Coordinate installation and relocation of roof drains so that work can be inspected by Departmental Representative prior to commencement of remaining roof work.

3.6 CLEANING

- .1 Perform in accordance with Section 01 74 11 - Cleaning.
- .2 Check drains to ensure cleanliness and proper function, and remove debris, equipment and excess material from site.

END OF SECTION

PART 1 **GENERAL**

1.1 **RELATED SECTIONS**

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 – Construction/Demolition Waste Management and Disposal.
- .3 Section 06 10 00 – Rough Carpentry.
- .4 Section 07 92 00 – Joint Sealants.

1.2 **REFERENCES**

- .1 The Aluminum Association Inc. (AA)
 - .1 Aluminum Sheet Metal Work in Building Construction.
 - .2 AA DAF45, Designation System for Aluminum Finishes.
- .2 American Society for Testing and Materials (ASTM International)
 - .1 ASTM A653/A653M, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
 - .2 ASTM A792/A792M, Standard Specification for Steel Sheet, 55% Aluminum-Zinc Alloy-Coated by the Hot-Dip Process.
 - .3 ASTM D523, Standard Test Method for Specular Gloss.
 - .4 ASTM D822, Standard Practice for Filtered Open-Flame Carbon-Arc Exposures of Paint and Related Coatings.
- .3 Canadian General Standards Board (CGBS)
 - .1 CAN/CGSB-37.5, Cutback Asphalt Plastic Cement.
- .4 Canadian Roofing Contractors Association (CRCA)
 - .1 Roofing Specifications Manual.
- .5 Canadian Standards Association (CSA International)
 - .1 CSA A123.3, Asphalt Saturated Organic Roofing Felt.
 - .2 CSA B111, Wire Nails, Spikes and Staples.

1.3 **SAMPLES**

- .1 Submit duplicate 50 x 50 mm samples of each type of sheet metal material, colour and finish.

PART 2 **PRODUCTS**

2.1 **SHEET METAL MATERIALS**

- .1 Aluminum-zinc alloy coated steel sheet: to ASTM A792/A792M, commercial quality, grade 33 with AZ150 coating, regular spangle surface, 0.60 mm base metal thickness. Pre-painted to CGSB –GP-71.

2.2 **PREFINISHED STEEL SHEET**

- .1 Prefinished sheet with factory applied polyvinylidene fluoride.
 - .1 Class F1S
 - .2 Colour as selected by Departmental Representative from manufacturer's standard range.
 - .3 Specular gloss: 30 units +/- 5 in accordance with ASTM D523.
 - .4 Coating thickness: not less than 22 micrometres.
 - .5 Resistance to accelerated weathering for caulk rating of 8, colour fade 5 units or less and erosion rate less than 20 % to ASTM D822 as follows:
 - .1 Outdoor exposure period 2500 hours.
 - .2 Humidity resistance exposure period 5000 hours.

2.3 **ACCESSORIES**

- .1 Isolation coating: alkali resistant bituminous paint.
- .2 Plastic cement: to CAN/CGSB 37.5.
- .3 Underlay for metal flashing: No. 15 perforated asphalt felt to CSA A123.3.
- .4 Sealants: Section 07 92 00 – Joint Sealants.
- .5 Cleats: of same material, and temper as sheet metal, minimum 50 mm wide. Thickness same as sheet metal being secured.
- .6 Fasteners: of same material as sheet metal, to CSA B111, ring thread flat head roofing nails of length and thickness suitable for metal flashing application.
- .7 Washers: of same material as sheet metal, 1 mm thick with rubber packings.
- .8 Touch-up paint: as recommended by prefinished material manufacturer.

2.4 **FABRICATION**

- .1 Fabricate metal flashings and other sheet metal work in accordance with applicable CRCA 'FL' series details as indicated.

- .2 Fabricate aluminum flashings and other sheet aluminum work in accordance with Aluminum Association Aluminum Sheet Metal Work in Building Construction.
- .3 Form pieces in 2400 mm maximum lengths. Make allowance for expansion at joints.
- .4 Hem exposed edges on underside 12 mm. Mitre and seal corners with sealant.
- .5 Form sections square, true and accurate to size, free from distortion and other defects detrimental to appearance or performance.
- .6 Apply isolation coating to metal surfaces to be embedded in concrete or mortar.

2.5 METAL FLASHINGS

- .1 Form flashings, copings and fascias to profiles indicated of 0.60 mm thick prefinished steel.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install sheet metal work in accordance with CRCA FL series details and as detailed.
- .2 Use concealed fastenings except where approved before installation.
- .3 Provide underlay under sheet metal. Secure in place and lap joints 100 mm.
- .4 Counterflash bituminous flashings at intersections of roof with vertical surfaces and curbs. Flash joints using S-lock forming tight fit over hook strips, as detailed.
- .5 Lock end joints and caulk with sealant.

END OF SECTION

PART 1 GENERAL

1.1 RELATED WORK

- .1 Fire stopping and smoke seals within mechanical assemblies (i.e inside ducts, dampers) and electrical assemblies (i.e. inside cable trays) are specified in Division 23 and 26 respectively.
- .2 Coordinate work of this section with other sections as required to properly execute the work and as necessary maintain satisfactory progress of the work of other sections.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 – Submittal Procedures.
- .2 Section 01 45 00 – Quality Control.

1.3 REFERENCES

- .1 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN-S115, Fire Tests of Firestop Systems.

1.4 DEFINITIONS

- .1 Fire Stop Material: device intended to close off opening or penetration during fire or materials that fill openings in wall or floor assembly where penetration is by cables, cable trays, conduits, ducts and pipes and poke-through termination devices, including electrical outlet boxes along with their means of support through wall or floor openings.
- .2 Single Component Fire Stop System: fire stop material that has Listed Systems Design and is used individually without use of high temperature insulation or other materials to create fire stop system.
- .3 Multiple Component Fire Stop System: exact group of fire stop materials that are identified within Listed Systems Design to create on site fire stop system.
- .4 Tightly Fitted; (ref: NBC Part 3.1.9.1.1 and 9.10.9.6.1): penetrating items that are cast in place in buildings of noncombustible construction or have "0" annular space in buildings of combustible construction.
 - .1 Words "tightly fitted" should ensure that integrity of fire separation is such that it prevents passage of smoke and hot gases to unexposed side of fire separation.

1.5 SUBMITTALS

- .1 Prior to start of work submit the following:

- .1 Duplicate 300 x 300 mm samples showing actual firestop material proposed for project.
- .2 Shop drawings to show proposed material, reinforcement, anchorage, fastenings and method of installation. Construction details should accurately reflect actual job conditions.
- .3 Manufacturer's engineering judgement identification number and drawing details when no ULC or cUL system is available. Engineering judgement must include both project name and contractor's name who will install firestop system as described in drawing.
- .4 Manufacturer's product data for materials and prefabricated devices, providing descriptions are sufficient for identification at job site. Include manufacturer's printed instructions for installation. Include manufacturer's specifications, training letter, and technical data for each material including the composition and limitations, documentation of ULC or CUL firestop systems to be used.
- .5 Material safety data sheets provided with product delivered to job site.

1.6 MOCK-UP

- .1 Construct mock-up in accordance with Section 01 45 00 – Quality Control.
- .2 Construct mock-up showing service penetrations, fire separation and floor assemblies. Mock-up may be part of finished work.
- .3 Allow two (2) working days for inspection of mock-up by Departmental Representative before proceeding with membrane work.

1.7 MANUFACTURER'S REPRESENTATIVE

- .1 A manufacturer's representative is to be on site during initial installation of firestop systems to train appropriate contractor personnel in proper selection and installation procedures and at commissioning stage to certify acceptance completed installation. Training will be done as per manufacturer's written recommendations published in their literature and drawing details.

1.8 QUALITY ASSURANCE

- .1 All fire stopping materials for this project to be supplied by a single manufacturer.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Use only firestop products that have been ULC or cUL tested for specific fire-rated construction conditions conforming to construction assembly type, penetrating item type, annular space requirements and fire-rating involved for each separate instance.

- .2 Fire stopping and smoke seal systems: in accordance with CAN-S115.
 - .1 Asbestos-free materials and systems capable of maintaining an effective barrier against flame, smoke and gases in compliance with requirements of CAN-S115 and not to exceed opening sizes for which they are intended.
 - .2 Firestop system rating: as indicated on drawings.
- .3 Service penetration assemblies: certified and tested by ULC or cUL in accordance with CAN-S115.
- .4 Service penetration firestop components: certified and tested by ULC or cUL in accordance with CAN-S115.
- .5 Fire-resistance rating of installed fire stopping assembly in accordance with NBC.
- .6 Non-curing, re-penetrable intumescent sealants, caulking or putty material for use with flexible cables or cable bundles.
- .7 Fire stopping and smoke seals at openings around penetrations for pipes, ductwork and other mechanical items requiring sound and vibration control: elastomeric seal. Consult with Departmental Representative and damper manufacturer prior to installation ULC or cUL firestop systems that might hamper the performance of fire dampers as it pertains to duct work.
- .8 Intumescent sealants or caulking materials for use with combustible items (penetrants consumed by high heat and flame) including insulated metal pipe, PVC jacketed, flexible cable or cable bundles and plastic pipe. No silicone based firestop are allowed to be applied on plastic pipes.
- .9 Primers: to manufacturer's recommendation for specific material, substrate, and end use.
- .10 Water (if applicable): potable, clean and free from injurious amounts of deleterious substances.
- .11 Damming and backup materials, supports and anchoring devices: to manufacturer's recommendations, and in accordance with tested assembly being installed as acceptable to authorities having jurisdiction.
- .12 Sealants for vertical joints: non-sagging.

PART 3 **EXECUTION**

3.1 **PREPARATION**

- .1 Examine sizes and conditions of voids to be filled to establish correct thicknesses and installation of materials. Ensure that substrates and surfaces are clean, dry and frost free.

- .2 Prepare surfaces in contact with fire stopping materials and smoke seals to manufacturer's instructions.
- .3 Maintain insulation around pipes and ducts penetrating fire separation without interruption to vapour barrier.
- .4 Mask where necessary to avoid spillage and over coating onto adjoining surfaces; remove stains on adjacent surfaces.

3.2 INSTALLATION

- .1 Install fire stopping and smoke seal material and components in accordance with ULC certification or UL Products Certified for Canada (CUL) and manufacturer's instructions.
- .2 Seal holes or voids made by through penetrations, poke-through termination devices, and unpenetrated openings or joints to ensure continuity and integrity of fire separation are maintained.
- .3 Provide temporary forming as required and remove forming only after materials have gained sufficient strength and after initial curing.
- .4 Tool or trowel exposed surfaces to a neat finish.
- .5 Remove excess compound promptly as work progresses and upon completion.

3.3 INSPECTION

- .1 Notify Departmental Representative when ready for inspection and prior to concealing or enclosing firestopping materials and service penetration assemblies.

3.4 SCHEDULE

- .1 Firestop and smoke seal at:
 - .1 Penetrations through fire-resistance rated masonry, concrete, and gypsum board partitions and walls.
 - .2 Edge of floor slabs at curtain wall and precast concrete panels.
 - .3 Perimeter of fire-resistance rated masonry and gypsum board partitions.
 - .4 Intersection of fire-resistance rated masonry and gypsum board partitions.
 - .5 Control and sway joints in fire-resistance rated masonry and gypsum board partitions and walls.
 - .6 Penetrations through fire-resistance rated floor slabs, ceilings and roofs.
 - .7 Openings and sleeves installed for future use through fire separations.
 - .8 Around mechanical and electrical assemblies penetrating fire separations.

- .9 Rigid ducts: greater than 129 cm²: fire stopping to consist of bead of fire stopping material between retaining angle and fire separation and between retaining angle and duct, on each side of fire separation.

3.5 CLEAN UP

- .1 Remove excess materials and debris and clean adjacent surfaces immediately after application.
- .2 Remove temporary dams after initial set of fire stopping and smoke seal materials.

END OF SECTION

Part 1 General

1.1 SECTION INCLUDES

- .1 Materials, preparation and application for caulking and sealants.
- .2 Text to complete other various Sections containing sealant or caulking specifications.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Submittal Procedures.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 01 45 00 - Quality Control.
- .4 Section 01 61 00 - Common Product Requirements.

1.3 REFERENCES

- .1 American Society for Testing and Materials International, (ASTM)
 - .1 ASTM C919-02, Standard Practice for Use of Sealants in Acoustical Applications.
- .2 Canadian General Standards Board (CGSB)
 - .1 CGSB 19-GP-5M-1984, Sealing Compound, One Component, Acrylic Base, Solvent Curing (Issue of 1976 reaffirmed, incorporating Amendment No. 1).
 - .2 CAN/CGSB-19.13-M87, Sealing Compound, One-component, Elastomeric, Chemical Curing.
 - .3 CGSB 19-GP-14M-1984, Sealing Compound, One Component, Butyl-Polyisobutylene Polymer Base, Solvent Curing (Reaffirmation of April 1976).
 - .4 CAN/CGSB-19.17-M90, One-Component Acrylic Emulsion Base Sealing Compound.
 - .5 CAN/CGSB-19.24-M90, Multi-component, Chemical Curing Sealing Compound.
 - .6 CAN/CGSB-37.5-M89, Cutback Asphalt Plastic Cement
- .3 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Protection Act, 1999 (CEPA).
- .4 General Services Administration (GSA) - Federal Specifications (FS)
 - .1 FS-SS-S-200-E(2)1993, Sealants, Joint, Two-Component, Jet-Blast-Resistant, Cold Applied, for Portland Cement Concrete Pavement.
- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

- .6 Transport Canada (TC)
 - .1 Transportation of Dangerous Goods Act, 1992 (TDGA).

1.4 SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Manufacturer's product to describe.
 - .1 Caulking compound.
 - .2 Primers.
 - .3 Sealing compound, each type, including compatibility when different sealants are in contact with each other.
- .3 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
- .4 Submit duplicate samples of each type of material and colour.
- .5 Cured samples of exposed sealants for each color where required to match adjacent material.
- .6 Submit manufacturer's instructions in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Instructions to include installation instructions for each product used.

1.5 QUALITY ASSURANCE/MOCK-UP

- .1 Construct mock-up in accordance with Section 01 45 00 - Quality Control.
- .2 Construct mock-up to show location, size, shape and depth of joint s complete with back-up material, primer, caulking and sealant.
- .3 Mock-up will be used:
 - .1 To judge workmanship, substrate preparation, operation of equipment and material application.
- .4 Locate where directed where indicated.
- .5 Allow 24 hours for inspection of mock-up by Departmental Representative before proceeding with sealant work.
- .6 When accepted, mock-up will demonstrate minimum standard of quality required for this Work. Approved mock-up may remain as part of finished Work.

1.6 DELIVERY, STORAGE, AND HANDLING

- .1 Deliver, handle, store and protect materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver and store materials in original wrappings and containers with manufacturer's seals and labels, intact. Protect from freezing, moisture, water and contact with ground or floor.

1.7 WASTE MANAGEMENT AND DISPOSAL

- .1 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .2 Collect and separate for disposal corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .3 Place materials defined as hazardous or toxic in designated containers.
- .4 Handle and dispose of hazardous materials in accordance with the CEPA, TDGA, Regional and Municipal regulations.
- .5 Unused sealant material must not be disposed of into sewer system, into streams, lakes, onto ground or in other location where it will pose health or environmental hazard.
- .6 Divert unused joint sealing material from landfill to official hazardous material collections site approved by Departmental Representative .
- .7 Empty plastic joint sealer containers are not recyclable. Do not dispose of empty containers with plastic materials destined for recycling.
- .8 Fold up metal banding, flatten, and place in designated area for recycling.

1.8 PROJECT CONDITIONS

- .1 Environmental Limitations:
 - .1 Do not proceed with installation of joint sealants under following conditions:
 - .1 When ambient and substrate temperature conditions are outside limits permitted by joint sealant manufacturer or are below 4.4 degrees C.
 - .2 When joint substrates are wet.
- .2 Joint-Width Conditions:
 - .1 Do not proceed with installation of joint sealants where joint widths are less than those allowed by joint sealant manufacturer for applications indicated.
- .3 Joint-Substrate Conditions:
 - .1 Do not proceed with installation of joint sealants until contaminants capable of interfering with adhesion are removed from joint substrates.

1.9 ENVIRONMENTAL REQUIREMENTS

- .1 Comply with requirements of Workplace Hazardous Materials Information System (WHMIS) regarding use, handling, storage, and disposal of hazardous materials; and regarding labelling and provision of Material Safety Data Sheets (MSDS) acceptable to Labour Canada.
- .2 Conform to manufacturer's recommended temperatures, relative humidity, and substrate moisture content for application and curing of sealants including special conditions governing use.

- .3 Ventilate area of work as directed by Departmental Representative by use of approved portable supply and exhaust fans.

Part 2 Products

2.1 SEALANT MATERIALS

- .1 Do not use caulking that emits strong odours, contains toxic chemicals or is not certified as mould resistant in air handling units.
- .2 When low toxicity caulks are not possible, confine usage to areas which offgas to exterior, are contained behind air barriers, or are applied several months before occupancy to maximize offgas time.
- .3 Where sealants are qualified with primers use only these primers.

2.2 SEALANT MATERIAL DESIGNATIONS

- .1 Urethanes One Part.
 - .1 Non-Sag to CAN/CGSB-19.13, Type 2, MCG-2-25 MCG-2-40, colour to match adjacent finish.
- .2 Silicones One Part.
 - .1 To CAN/CGSB-19.13.
 - .2 Mildew resistant: .
- .3 Acrylic Latex One Part.
 - .1 To CAN/CGSB-19.17.
- .4 Acoustical Sealant.
 - .1 To ASTM C919.
- .5 Preformed Compressible and Non-Compressible back-up materials.
 - .1 Polyethylene, Urethane, Neoprene or Vinyl Foam.
 - .1 Extruded closed cell foam backer rod.
 - .2 Size: oversize 30 to 50 %.
 - .2 High Density Foam.
 - .1 Extruded closed cell polyvinyl chloride (PVC), extruded polyethylene, closed cell, Shore A hardness 20, tensile strength 140 to 200 kPa, extruded polyolefin foam, 32 kg/m³ density, or neoprene foam backer, size as recommended by manufacturer.
- .6 Wet or Dry Plastic Roof Cement
 - .1 Solvent type rubberized, plastic cement made of asphalt, synthetic rubber, fibre and fillers.

- .2 To be flexible, water and weather resistant.
- .3 Colour: Black
- .4 To dry tough and elastic.
- .5 Suitable for wet or dry application.

2.3 SEALANT SELECTION

- .1 Seal interior perimeters of exterior openings as detailed on drawings: Sealant type: CAN/CGSB-19.13-M87.
- .2 Interior control and expansion joints in floor surfaces:
- .3 Perimeters of interior frames, as detailed and itemized:
- .4 Perimeter of fixtures e.g. sinks, vanities:

2.4 Exposed interior control joints in drywall: JOINT CLEANER

- .1 Non-corrosive and non-staining type, compatible with joint forming materials and sealant recommended by sealant manufacturer.
- .2 Primer: as recommended by manufacturer.

Part 3 Execution

3.1 PROTECTION

- .1 Protect installed Work of other trades from staining or contamination.

3.2 SURFACE PREPARATION

- .1 Examine joint sizes and conditions to establish correct depth to width relationship for installation of backup materials and sealants.
- .2 Clean bonding joint surfaces of harmful matter substances including dust, rust, oil grease, and other matter which may impair Work.
- .3 Do not apply sealants to joint surfaces treated with sealer, curing compound, water repellent, or other coatings unless tests have been performed to ensure compatibility of materials. Remove coatings as required.
- .4 Ensure joint surfaces are dry and frost free.
- .5 Prepare surfaces in accordance with manufacturer's directions.

3.3 PRIMING

- .1 Where necessary to prevent staining, mask adjacent surfaces prior to priming and caulking.

- .2 Prime sides of joints in accordance with sealant manufacturer's instructions immediately prior to caulking.

3.4 BACKUP MATERIAL

- .1 Apply bond breaker tape where required to manufacturer's instructions.
- .2 Install joint filler to achieve correct joint depth and shape, with approximately 30% compression.

3.5 MIXING

- .1 Mix materials in strict accordance with sealant manufacturer's instructions.

3.6 APPLICATION

- .1 Sealant.
 - .1 Apply sealant in accordance with manufacturer's written instructions.
 - .2 Mask edges of joint where irregular surface or sensitive joint border exists to provide neat joint.
 - .3 Apply sealant in continuous beads.
 - .4 Apply sealant using gun with proper size nozzle.
 - .5 Use sufficient pressure to fill voids and joints solid.
 - .6 Form surface of sealant with full bead, smooth, free from ridges, wrinkles, sags, air pockets, embedded impurities.
 - .7 Tool exposed surfaces before skinning begins to give slightly concave shape.
 - .8 Remove excess compound promptly as work progresses and upon completion.
- .2 Curing.
 - .1 Cure sealants in accordance with sealant manufacturer's instructions.
 - .2 Do not cover up sealants until proper curing has taken place.
- .3 Cleanup.
 - .1 Clean adjacent surfaces immediately and leave Work neat and clean.
 - .2 Remove excess and droppings, using recommended cleaners as work progresses.
 - .3 Remove masking tape after initial set of sealant.

END OF SECTION