

Part 1 General

1.1 REFERENCES

- .1 Underwriter's Laboratories of Canada (ULC)
 - .1 CAN/ULC-S524-06, Standard for the Installation of Fire Alarm Systems.
 - .2 CAN/ULC-S537-04, Verification of Fire Alarm Systems.

1.2 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Submit device testing and verification report.

Part 2 Products

2.1 WIRING

- .1 Copper conductors.
- .2 To initiating circuits, and in accordance with manufacturer's requirements.
- .3 To speaker circuits: in accordance with manufacturer's requirements.

2.2 AUTOMATIC ALARM INITIATING DEVICES

- .1 Heat/ smoke detectors: Existing on site.

2.3 AUDIBLE SIGNAL DEVICES

- .1 Speakers: Existing on site.

Part 3 Execution

3.1 INSTALLATION

- .1 Disconnect, reconnect and/or relocate and reconnect existing devices to CAN/ULC-S524.
- .2 Splices are not permitted.
- .3 Ensure that wiring is free of opens, shorts or grounds, before system testing and handing over.

3.2 FIELD QUALITY CONTROL

- .1 Perform tests and verify in accordance with Section 26 05 00 - Common Work Results for Electrical and to CAN/ULC-S537.

END OF SECTION