



NOTES.

(1) ALL CIRCUIT BREAKERS ARE TWO POLE AND ARE CALIBRATED AT 40°C.

(2) IF CIRCUIT BREAKERS ARE REPLACED BY 50°C CIRCUIT BREAKERS THEY MUST BE DERATED BY 13%.

(3) SPACES IN DISTRIBUTION PANEL FOR TWO 2 POLE 15KV CIRCUITS AND TWO 2 POLE 30KV CIRCUITS. BREAKERS NOT FITTED IN PANEL

(4) CIRCUIT BREAKER NUMBERS IDENTIFIED THUS ① ETC. BEAR SAME NUMBERS IN PANEL BOARD.

DATE		15/3/77		REVISIONS		BY CH		DWG NO	
4 ADDED		NEUTRAL		WIRE WAS		FUSED IN		DISC. SW.	
3.5 NUMBERS		ADDED NOTE		PF		RF			
<p>60020-A2</p>									