



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Admin Building Enclosure Renewal	
Solicitation No. - N° de l'invitation EZ899-180045/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2017-09-01
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8145	
File No. - N° de dossier PWY-7-40124 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-13	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - Gulf of Georgia Cannery - Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-180045/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
006
File No. - N° du dossier
pwy-7-40124

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 006 is raised to incorporate Addendum No. 4.

Please find following Addendum No. 4.

All other terms and conditions remain unchanged.

*The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents*

Amend/revise the Standard Contract Documents as follows:

1.0 CHANGES AND CLARIFICATIONS

1.1 Can specifications for masonry be provided?

There is no new masonry on the project. Refer to the structural drawings and section 03 30 53 - Miscellaneous Cast-In-Place Concrete – of the technical specifications for additional information on masonry reinforcing, grout, and fastening requirements.

1.2 What is the make-up of the existing roofing on the Administration Building?

Assume the existing roof assembly of the Administration Building is as follows:

- 2-ply SBS membrane
- Protection board
- Tongue and groove ship-lap decking
- 38 x 286mm joists
- Batt insulation with kraft paper facing within joist cavity
- Interlocking 305 x 305mm fiberboard acoustic ceiling tile fastened to wood strapping at underside of joists (typical), or gypsum board ceiling (mech. room. and archive room), or interlocking 305 x 305mm fiberboard acoustic ceiling tile fastened to wood strapping at underside of joists inside suspended T-bar ceiling cavity (where indicated on A-1.3).

1.3 The SBS specifications indicate ballast and paver underlay – can this be clarified if it is required?

Ballast and pavers are not required for the project.

END OF ADDENDUM No. 4