



Fisheries and Oceans
Canada

Pêches et Océans
Canada

Procurement Hub – Ottawa Office,
Station 9W072, 9th Floor,
200 Kent Street,
Ottawa, Ontario K1A 0E6

September 01, 2017

ADDENDUM NO. 2

Subject: ITT Invitation to Tender No. FP802-170170
Deer Lake Warehouse Restoration

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this Addendum (#2) is to advise potential bidders that the drawings for this project in the original ITT have been amended as follows:

Insert the following: Revised Drawing 12H0301A002A2

- Refer to Drawing 12H0301A002A2
 - o Demolition Note 6, revise note to read: EXISTING ASPHALT SHINGLES, SHEATHING AND ROOF TRUSSES TO BE REMOVED, TO FACILITATE CONSTRUCTION OF NEW WALL HEIGHT EXTENSION. SHEATHING AND TRUSSES TO BE REINSTALLED AFTER WALLS HAVE BEEN HEIGHTENED AS SPECIFIED. SUPPLY AND INSTALL NEW ASPHALT SHINGLES AFTER REINSTALLATION OF SHEATHING AND TRUSSES. CONTRACTOR IS RESPONSIBLE TO REPLACE ANY SHEATHING AND/OR TRUSSES DAMAGED DURING THESE OPERATIONS.
 - o Detail 6/A2, revise note to read: EXISTING ASPHALT SHINGLES, SHEATHING AND ROOF TRUSSES TO BE REMOVED, TO FACILITATE CONSTRUCTION OF NEW WALL HEIGHT EXTENSION. SHEATHING AND TRUSSES TO BE REINSTALLED AFTER WALLS HAVE BEEN HEIGHTENED AS SPECIFIED. SUPPLY AND INSTALL NEW ASPHALT SHINGLES AFTER REINSTALLATION OF SHEATHING AND TRUSSES. CONTRACTOR IS RESPONSIBLE TO REPLACE ANY SHEATHING AND/OR TRUSSES DAMAGED DURING THESE OPERATIONS.

All other terms and conditions remain unchanged.

Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.

Yours truly,

(Original signed by)

Beverly Shawana

Senior Contracting Officer,

Financial & Materials Management Operations

RECEIPT ACKNOWLEDGED

Name of Company

Signature _____

Canada