



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Services**

**3, passage du Chien-d 'Or
Quebec, QC
G1R 3Z8**

INVITATION TO TENDER
APPEL D'OFFRES

AMENDMENT #7 TO:

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
3, passage du Chien-d 'Or
Quebec, QC, G1R 3Z8

Title-Sujet Lachine Canal Lighting Network Rehabilitation		Date September 1st, 2017											
Solicitation No. - No. de l'invitation 5P201-17-5070		Client Ref. No. – No. de réf du client.											
GETS Reference No. – No de reference de SEAG													
Solicitation Closes L'invitation prend fin – at – à 2:00 PM on – le September 6th 2017		Time Zone Fuseau horaire - EASTERN DAYLIGHT TIME (EDT)											
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>													
Address Inquiries to: - Adresser toute demande de renseignements à : Josée Gagnon, josee.gagnon@pc.gc.ca													
Telephone No. - No de téléphone 418 648-2502		Fax No. – No de FAX: 418 649-6971											
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein													
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - No de téléphone: _____ Facsimile No. - N° de télécopieur: _____ Email - Courriel : _____													
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur <table border="0"><tr><td>_____</td><td>_____</td></tr><tr><td>Name / Nom</td><td>Title / Titre</td></tr><tr><td colspan="2"> </td></tr><tr><td>_____</td><td>_____</td></tr><tr><td>Signature</td><td>Date</td></tr></table>				_____	_____	Name / Nom	Title / Titre	 		_____	_____	Signature	Date
_____	_____												
Name / Nom	Title / Titre												
_____	_____												
Signature	Date												



Amendment #7

THE PURPOSE OF THIS AMENDMENT IS TO PROVIDE DETAILS TO THE TECHNICAL SPECIFICATIONS AND THE TENDER SCHEDULE.

1. YOU MUST CONSIDER THE INFORMATION IN ADDENDUM BELOW, LOCATED IN THE ATTACHMENTS SECTION, IN THE EVALUATION OF YOUR BID.

645791 Addendum No. 4_2017-09-01.pdf

2. APPENDIX 1, 645791 - TENDER SCHEDULE - Revision 4

This amendment replaces Appendix 1 in its entirety. Tender Schedule Revision 4 must be used in your bid to be deemed admissible. Bids submitted using the initial Tender Schedule, Tender Schedule Revision 1, Tender Schedule Revision 2 or Tender Schedule Revision 3 will be evaluated as non-compliant.

Q5. In the trench between lamposts and according to symbol on the plan E0 two (2) PVC conduits of 53mm in diameter are indicated however the Payment list only represents one conduit?

A5. Change to Tender Schedule, addendum 3, addition of linear meters

Q6. Who is responsible for laboratory test for soil, compaction tests etc?

A6. The contractor is responsible (refer to section 01 29 00, addendum 4)

Q7. Where are the areas dedicated to site office use as well as areas for stockpiling materials before being transported off site?

A7. A gravel area immediately beside the Canal pathway, located at the intersection of Vézina and Saint Patrick, south side of the canal, has been designated for site office use. Note: This area will be shared with another contractor, a fence will be required to define the work site. Areas for stockpiling material will be decided on site with the Parks Canada representative.

Q8. Other points in relation to the Tender Schedule merit a separate line such as:

Environment:

Environment Protection Plan (to be a lump sum)

Sediment protection barriers (estimated in square meters)

Berms and sediments traps (unit costs)

A8. Addendum 4 modification section 01 29 00, to be include in site organization

Civil Works:

Excavation and Backfilling trenches (1st Class) priced according to linear meter

Excavation and Backfilling concrete lampost bases (1st Class) priced by square meter

See addendum 4 – change to Tender Schedule

Moreover, with the addition of these environmental measures and additional civil work, which is unpredictable in quantity, the deadline of 4 months for all the work to be completed by June 30 2018 is too short?

No answer



Q9. Does Item 2.2 Trench under pavement represent the portion of the pathway where the conduits pass under it? On the construction plans, section 1, you will see completely to the left, that the new bike path is parallel to the old one...who will install this new portion as well as other portions on the plans, the legend indicates that this item is out of contract?

A9. Yes Item 2.2 Trench under pavement represents the portion of the pathway were the conduits pass under it.

The new lampost alignment is planned in preparation for the eventual widening of the bike path to 4 meters. There is no widening of the bike path in this contract. This will be done in future projects. The New Bike Path (not in contract) is shown on the plan for information only with the following **exception**:

In order to assure adequate lighting for visitors three (3) sections of the bike path must be replaced in the present contract, as illustrated on plans E02 and E03 (sections 1,2 and 4)

Q10. What is the intended use of the temporary bicycle path?

A10. There is no temporary bicycle path in this project.

Correction Addendum 3, Section 01 29 00, Payment Procedure, 2.1.3 Supply and installing the door banners change to Supply and install Banner Support System.

THE BID CLOSING DATE REMAINS WEDNESDAY, THE 6TH OF SEPTEMBER 2017, 2PM EDT.

End of section.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

**Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.
Fax: 418 649-6971.**