



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works & Government Services
Canada/Réception des soumissions Travaux publics et
Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet BIO Warehouse Cladding	
Solicitation No. - N° de l'invitation EB144-180556/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client EB144-18-0556	Date 2017-09-07
GETS Reference No. - N° de référence de SEAG PW-SPWA-310-5638	
File No. - N° de dossier PWA-7-78040 (310)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-12	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Stevenson, Jacquelyn	Buyer Id - Id de l'acheteur pwa310
Telephone No. - N° de téléphone (902) 403-3520 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENEMENT 001

This amendment is being raised for the following reason:

Closing Date

Delete

Thursday, September 07, 2017 @ 1400hrs

Insert

Tuesday, September 12, 2017 @ 1400hrs

Questions & Answers

1. ARCHITECTURAL DRAWINGS

Drawing A5, Detail 4A: (note)

Delete: "New stainless steel gutter and galvanized liner with stainless steel neoprene washer (typical)".

Add: "New 0.91mm galvanized prepainted steel gutter colour to be Pacific Turquoise with 1.63mm galvanized metal liner. All new rainwater leaders (RWL) that are being replaced, colour to match existing building siding colour in all locations."

Drawing A2, Detail 2, Existing West Elevation: (note)

Delete: "Existing downspouts to be removed by contractor. Adjust catchment pipe to suit new RWL location by others, (all elevations, typical.)"

Add: "Existing downspouts (RWL) to be removed by contractor, on all existing elevations, line up downspouts (RWL) to coordinate with Civil Engineering catch basin locations, adjust bottom of RWL to suit, see Drawings C1 and C2."

-
2. The design intent was to achieve a 1% slope to the drain in the Buoy Tool Storage Room and in the Forklift and Battery Storage Room as shown on the drawings. Following review of the proposed Sikaflor system data sheets as an alternate, it appears that the Morritex is not designed to achieve these slope heights (as much as 2" at the perimeter). The Sikaflor Morritex Trowel System appears to be equal to the Stoncld GS for skimcoating over the leveling grout and to build the cove base but not acceptable for sloping.