
AMENDMENT # 1**ADDENDUM # 1****Atrium Glazing Replacement – RCMP “B” Division, St. John’s, NL
EA003-180945/A**

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

ADDENDUM #1**PART A – SPECIFICATIONS****1. Section 08 80 50 – Glazing****1. Revise sentence 1.1.4 to read:**

.4 Verify that existing skylight framing assembly meets the loading requirements as per NBCC and as indicated herein.

2. Add new Item 1.9 to read:

.9 Warranty:

- .1 Manufacturer’s standard 10 year warranty against failure of seals and, tint fade.
- .2 Five year no-leak warranty on skylite assembly.

3. Reword Item 2.1.3.1 to read:

.1 “..... 25 mm overall minimum thickness.”

4. Add to item 2.1.3.1.6:

.6 “.....with 0.030” (0.76 mm) interlayer.

5. Reword Item 2.1.3.2 to read:

.2 “..... 6 mm minimum each lite”.

6. Add new sentence 2.1.3.7 to read:

.7 Outboard pane colour: PPG AZURIA or acceptable alternate.

PART B – DRAWINGS1. Drawing No. A1

1. See drawing section 1/A2 for skylite slope.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
