

 <p><b>TechnoRem Inc.</b> 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p><b>TechnoRem</b></p>			
<b>Pumping Test - Water Level Data</b>			Page 1 of 5
Project: Travaux caractérisation complémentaire			
Number: PR13-79			
Client: TPSGC			
Location: Dépotoir Sambault - Saint-Isidore		Pumping Test: PO-30	Pumping Well: PO-30
Test Conducted by: TechnoRem Inc.		Test Date: 2013-09-19	Discharge: variable, average rate 0,68611 [U.S. gal/min]
Observation Well: PO-31		Static Water Level [m]: 4,63	Radial Distance to PW [m]: 0,97
	Time [min]	Water Level [m]	Drawdown [m]
1	0	4,63	0,00
2	0,5	4,6304	0,0004
3	1	4,6306	0,0006
4	1,5	4,6312	0,0012
5	2	4,6316	0,0016
6	2,5	4,6311	0,0011
7	3	4,6317	0,0017
8	3,5	4,6319	0,0019
9	4	4,6316	0,0016
10	4,5	4,6345	0,0045
11	5	4,6334	0,0034
12	7	4,6336	0,0036
13	9	4,6327	0,0027
14	11	4,6329	0,0029
15	13	4,6321	0,0021
16	15	4,6325	0,0025
17	17	4,632	0,002
18	19	4,6309	0,0009
19	21	4,6307	0,0007
20	23	4,6318	0,0018
21	25	4,6311	0,0011
22	27	4,6325	0,0025
23	29	4,6342	0,0042
24	31	4,6343	0,0043
25	33	4,6355	0,0055
26	35	4,6371	0,0071
27	37	4,6382	0,0082
28	39	4,64	0,01
29	41	4,6408	0,0108
30	43	4,6415	0,0115
31	45	4,6435	0,0135
32	47	4,6444	0,0144
33	49	4,6462	0,0162
34	51	4,6476	0,0176
35	53	4,6479	0,0179
36	55	4,6492	0,0192
37	57	4,649	0,019
38	59	4,649	0,019
39	61	4,6486	0,0186
40	63	4,6493	0,0193
41	65	4,6502	0,0202
42	70	4,6518	0,0218
43	75	4,6528	0,0228
44	80	4,6547	0,0247
45	85	4,657	0,027
46	90	4,6585	0,0285
47	95	4,6624	0,0324
48	100	4,6624	0,0324
49	105	4,6639	0,0339
50	110	4,666	0,036
51	115	4,6679	0,0379
52	120	4,67	0,04
53	125	4,6723	0,0423
54	130	4,6743	0,0443
55	135	4,6763	0,0463
56	140	4,6782	0,0482
57	145	4,6823	0,0523
58	150	4,6842	0,0542
59	155	4,6856	0,0556
60	160	4,6868	0,0568
61	165	4,6886	0,0586
62	170	4,6909	0,0609
63	175	4,6926	0,0626
64	180	4,6952	0,0652
65	185	4,6992	0,0692
66	190	4,7052	0,0752
67	195	4,7085	0,0785
68	200	4,7112	0,0812
69	205	4,7143	0,0843
70	210	4,719	0,089
71	215	4,7207	0,0907
72	220	4,7243	0,0943
73	225	4,7258	0,0958
74	230	4,7288	0,0988
75	235	4,7329	0,1029
76	240	4,737	0,107
77	245	4,7438	0,1138

 <p><b>TechnoRem Inc.</b>  <b>4701 rue Louis-B.-Mayer</b>  <b>Laval, Qc, H7P 6G5</b></p> <p><b>TechnoRem</b></p>				<p><b>Pumping Test - Water Level Data</b></p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
	Time [min]	Water Level [m]	Drawdown [m]	
78	250	4,7506	0,1206	
79	255	4,7526	0,1226	
80	260	4,753	0,123	
81	265	4,7541	0,1241	
82	270	4,7544	0,1244	
83	275	4,7526	0,1226	
84	280	4,7528	0,1228	
85	285	4,7541	0,1241	
86	290	4,7553	0,1253	
87	295	4,7572	0,1272	
88	300	4,7594	0,1294	
89	305	4,7635	0,1335	
90	310	4,765	0,135	
91	315	4,7688	0,1388	
92	320	4,7706	0,1406	
93	325	4,7725	0,1425	
94	330	4,7735	0,1435	
95	335	4,7758	0,1458	
96	340	4,7769	0,1469	
97	345	4,7781	0,1481	
98	350	4,7792	0,1492	
99	355	4,781	0,151	
100	360	4,7803	0,1503	
101	360,5	4,7805	0,1505	
102	361	4,7795	0,1495	
103	361,5	4,7795	0,1495	
104	362	4,7791	0,1491	
105	362,5	4,7785	0,1485	
106	363	4,7793	0,1493	
107	363,5	4,7793	0,1493	
108	364	4,7785	0,1485	
109	364,5	4,7782	0,1482	
110	365	4,7789	0,1489	
111	367	4,7781	0,1481	
112	369	4,7784	0,1484	
113	371	4,7778	0,1478	
114	373	4,7774	0,1474	
115	375	4,7774	0,1474	
116	377	4,7772	0,1472	
117	379	4,7785	0,1485	
118	381	4,7804	0,1504	
119	383	4,7822	0,1522	
120	385	4,7841	0,1541	
121	387	4,7844	0,1544	
122	389	4,7855	0,1555	
123	391	4,7859	0,1559	
124	393	4,7877	0,1577	
125	395	4,7875	0,1575	
126	397	4,7886	0,1586	
127	399	4,7896	0,1596	
128	401	4,7906	0,1606	
129	403	4,7913	0,1613	
130	405	4,7927	0,1627	
131	407	4,7933	0,1633	
132	409	4,7935	0,1635	
133	411	4,7947	0,1647	
134	413	4,7953	0,1653	
135	415	4,7952	0,1652	
136	417	4,7948	0,1648	
137	419	4,7956	0,1656	
138	421	4,7958	0,1658	
139	423	4,7967	0,1667	
140	425	4,7973	0,1673	
141	430	4,7993	0,1693	
142	435	4,7995	0,1695	
143	440	4,7985	0,1685	
144	445	4,7991	0,1691	
145	450	4,7992	0,1692	
146	455	4,801	0,171	
147	460	4,8014	0,1714	
148	465	4,8019	0,1719	
149	470	4,8024	0,1724	
150	475	4,8022	0,1722	
151	480	4,8015	0,1715	
152	485	4,8015	0,1715	
153	490	4,8014	0,1714	
154	495	4,8022	0,1722	
155	500	4,8017	0,1717	
156	505	4,8015	0,1715	
157	510	4,8045	0,1745	
158	515	4,8046	0,1746	
159	520	4,8062	0,1762	
160	525	4,806	0,176	
161	530	4,8057	0,1757	
162	535	4,8056	0,1756	

 <p><b>TechnoRem Inc.</b>  <b>4701 rue Louis-B.-Mayer</b>  <b>Laval, Qc, H7P 6G5</b></p> <p><b>TechnoRem</b></p>				<p><b>Pumping Test - Water Level Data</b></p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 3 of 5
	Time [min]	Water Level [m]	Drawdown [m]	
163	540	4,8047	0,1747	
164	545	4,8051	0,1751	
165	550	4,8078	0,1778	
166	555	4,8089	0,1789	
167	560	4,8079	0,1779	
168	565	4,8083	0,1783	
169	570	4,8077	0,1777	
170	575	4,8065	0,1765	
171	580	4,8049	0,1749	
172	585	4,8043	0,1743	
173	590	4,8036	0,1736	
174	595	4,802	0,172	
175	600	4,8017	0,1717	
176	605	4,8006	0,1706	
177	610	4,8005	0,1705	
178	615	4,7996	0,1696	
179	620	4,7994	0,1694	
180	625	4,7999	0,1699	
181	630	4,8002	0,1702	
182	635	4,8022	0,1722	
183	640	4,801	0,171	
184	645	4,8012	0,1712	
185	650	4,8012	0,1712	
186	655	4,8006	0,1706	
187	660	4,799	0,169	
188	665	4,804	0,174	
189	670	4,8092	0,1792	
190	675	4,81	0,18	
191	680	4,8108	0,1808	
192	685	4,8109	0,1809	
193	690	4,8097	0,1797	
194	695	4,809	0,179	
195	700	4,8093	0,1793	
196	705	4,8091	0,1791	
197	710	4,8091	0,1791	
198	715	4,8084	0,1784	
199	720	4,8082	0,1782	
200	725	4,8082	0,1782	
201	730	4,8081	0,1781	
202	735	4,8063	0,1763	
203	740	4,8051	0,1751	
204	745	4,8053	0,1753	
205	750	4,805	0,175	
206	755	4,8053	0,1753	
207	760	4,8043	0,1743	
208	765	4,8047	0,1747	
209	770	4,8049	0,1749	
210	775	4,8051	0,1751	
211	780	4,8064	0,1764	
212	785	4,8069	0,1769	
213	790	4,8071	0,1771	
214	795	4,8067	0,1767	
215	800	4,8079	0,1779	
216	805	4,8081	0,1781	
217	810	4,8084	0,1784	
218	815	4,8098	0,1798	
219	820	4,8089	0,1789	
220	825	4,8093	0,1793	
221	830	4,8106	0,1806	
222	835	4,8114	0,1814	
223	840	4,8109	0,1809	
224	845	4,8131	0,1831	
225	850	4,814	0,184	
226	855	4,8141	0,1841	
227	860	4,8144	0,1844	
228	865	4,8153	0,1853	
229	870	4,8156	0,1856	
230	875	4,8156	0,1856	
231	880	4,814	0,184	
232	885	4,815	0,185	
233	890	4,8154	0,1854	
234	895	4,8141	0,1841	
235	900	4,8109	0,1809	
236	905	4,8012	0,1712	
237	910	4,7946	0,1646	
238	915	4,7896	0,1596	
239	920	4,7887	0,1587	
240	925	4,7884	0,1584	
241	930	4,7871	0,1571	
242	935	4,7851	0,1551	
243	940	4,7845	0,1545	
244	945	4,7845	0,1545	
245	950	4,7821	0,1521	
246	955	4,7836	0,1536	
247	960	4,7859	0,1559	

 <p><b>TechnoRem Inc.</b> 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p><b>Pumping Test - Water Level Data</b></p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>	<p>Page 4 of 5</p>
	Time [min]	Water Level [m]	Drawdown [m]		
248	965	4,7852	0,1552		
249	970	4,7855	0,1555		
250	975	4,7881	0,1581		
251	980	4,7896	0,1596		
252	985	4,7892	0,1592		
253	990	4,7895	0,1595		
254	995	4,7895	0,1595		
255	1000	4,7905	0,1605		
256	1005	4,7895	0,1595		
257	1010	4,7876	0,1576		
258	1015	4,7858	0,1558		
259	1020	4,7877	0,1577		
260	1025	4,7897	0,1597		
261	1030	4,7911	0,1611		
262	1035	4,7909	0,1609		
263	1040	4,7912	0,1612		
264	1045	4,793	0,163		
265	1050	4,7945	0,1645		
266	1055	4,796	0,166		
267	1060	4,7961	0,1661		
268	1065	4,7971	0,1671		
269	1070	4,7977	0,1677		
270	1075	4,7993	0,1693		
271	1080	4,7987	0,1687		
272	1085	4,8002	0,1702		
273	1090	4,8011	0,1711		
274	1095	4,8035	0,1735		
275	1100	4,8048	0,1748		
276	1105	4,8054	0,1754		
277	1110	4,8049	0,1749		
278	1115	4,8045	0,1745		
279	1120	4,8028	0,1728		
280	1125	4,8034	0,1734		
281	1130	4,8017	0,1717		
282	1135	4,8024	0,1724		
283	1140	4,8022	0,1722		
284	1145	4,8036	0,1736		
285	1150	4,8051	0,1751		
286	1155	4,8043	0,1743		
287	1160	4,8056	0,1756		
288	1165	4,8075	0,1775		
289	1170	4,8091	0,1791		
290	1175	4,8088	0,1788		
291	1180	4,8097	0,1797		
292	1185	4,8094	0,1794		
293	1190	4,8105	0,1805		
294	1195	4,8107	0,1807		
295	1200	4,8115	0,1815		
296	1205	4,8122	0,1822		
297	1210	4,8134	0,1834		
298	1215	4,8139	0,1839		
299	1220	4,8121	0,1821		
300	1225	4,8122	0,1822		
301	1230	4,8127	0,1827		
302	1235	4,8131	0,1831		
303	1240	4,8133	0,1833		
304	1245	4,8145	0,1845		
305	1250	4,8162	0,1862		
306	1255	4,8186	0,1886		
307	1260	4,8186	0,1886		
308	1265	4,8185	0,1885		
309	1270	4,8177	0,1877		
310	1275	4,8176	0,1876		
311	1280	4,8199	0,1899		
312	1285	4,822	0,192		
313	1290	4,8212	0,1912		
314	1295	4,82	0,19		
315	1300	4,818	0,188		
316	1305	4,8176	0,1876		
317	1310	4,8169	0,1869		
318	1315	4,8172	0,1872		
319	1320	4,817	0,187		
320	1325	4,8163	0,1863		
321	1330	4,8136	0,1836		
322	1335	4,8112	0,1812		
323	1340	4,8117	0,1817		
324	1345	4,8142	0,1842		
325	1350	4,8142	0,1842		
326	1355	4,815	0,185		
327	1360	4,8142	0,1842		
328	1365	4,8138	0,1838		
329	1370	4,8141	0,1841		
330	1375	4,8135	0,1835		
331	1380	4,8136	0,1836		
332	1385	4,8137	0,1837		



**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**TechnoRem**

**Pumping Test - Water Level Data**

Page 5 of 5

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

	Time [min]	Water Level [m]	Drawdown [m]
333	1390	4,813	0,183
334	1395	4,8119	0,1819
335	1400	4,812	0,182
336	1405	4,8127	0,1827
337	1410	4,8122	0,1822
338	1415	4,8122	0,1822
339	1420	4,8115	0,1815
340	1425	4,8135	0,1835
341	1485	4,8211	0,1911
342	1545	4,8248	0,1948
343	1605	4,8344	0,2044
344	1665	4,8373	0,2073
345	1725	4,8462	0,2182



**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**TechnoRem**

**Pumping Test - Water Level Data**

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore

Pumping Test: PO-30

Pumping Well: PO-30

Test Conducted by: TechnoRem Inc.

Test Date: 2013-09-19

Discharge: variable, average rate 0,68611 [U.S. gal/min]

Observation Well: PO-30

Static Water Level [m]: 10,47

Radial Distance to PW [m]: -

	Time [min]	Water Level [m]	Drawdown [m]
1	0	10,47	0,00
2	1	12,54	2,07
3	2	13,09	2,62
4	3	13,30	2,83
5	5	13,52	3,05
6	10	13,61	3,14
7	16	14,03	3,56
8	21	13,84	3,37
9	23	16,14	5,67
10	24	17,17	6,70
11	26	18,02	7,55
12	29	18,31	7,84
13	33	18,78	8,31
14	35	18,83	8,36
15	39	18,64	8,17
16	46	18,36	7,89
17	73	18,39	7,92
18	100	18,36	7,89
19	132	18,36	7,89
20	163	18,36	7,89
21	192	18,35	7,88
22	209	18,29	7,82
23	234	18,26	7,79
24	271	18,25	7,78
25	307	18,30	7,83
26	357	18,30	7,83
27	360	18,30	7,83
28	360,5	17,70	7,23
29	361	17,12	6,65
30	361,5	16,54	6,07
31	362	16,14	5,67
32	362,5	15,77	5,30
33	363	15,35	4,88
34	365	13,85	3,38
35	367	13,27	2,80
36	369	12,51	2,04
37	372	11,71	1,24
38	376	11,33	0,86
39	382	10,92	0,45
40	387	10,77	0,30
41	398	10,59	0,12

 <p><b>TechnoRem Inc.</b> 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p><b>TechnoRem</b></p>			
<b>Pumping Test - Water Level Data</b>			Page 1 of 3
Project: Travaux caractérisation complémentaire			
Number: PR13-79			
Client: TPSGC			
Location: Dépotoir Sambault - Saint-Isidore		Pumping Test: PO-30	Pumping Well: PO-30
Test Conducted by: TechnoRem Inc.		Test Date: 2013-09-19	Discharge: variable, average rate 0,68611 [U.S. gal/min]
Observation Well: PO-29		Static Water Level [m]: 11,29	Radial Distance to PW [m]: 3,01
	Time [min]	Water Level [m]	Drawdown [m]
1	0	11,29	0,00
2	0,5	11,2904	0,0004
3	1	11,2907	0,0007
4	1,5	11,2908	0,0008
5	2	11,2914	0,0014
6	2,5	11,2912	0,0012
7	3	11,2915	0,0015
8	3,5	11,291	0,001
9	4	11,2919	0,0019
10	4,5	11,2921	0,0021
11	5	11,292	0,002
12	7	11,293	0,003
13	9	11,2984	0,0084
14	11	11,2943	0,0043
15	13	11,2949	0,0049
16	15	11,2954	0,0054
17	17	11,2962	0,0062
18	19	11,2986	0,0086
19	21	11,3016	0,0116
20	23	11,3031	0,0131
21	25	11,3043	0,0143
22	27	11,3062	0,0162
23	29	11,3078	0,0178
24	31	11,3084	0,0184
25	33	11,3095	0,0195
26	35	11,3105	0,0205
27	37	11,3109	0,0209
28	39	11,3114	0,0214
29	41	11,312	0,022
30	43	11,3129	0,0229
31	45	11,313	0,023
32	47	11,3139	0,0239
33	49	11,3151	0,0251
34	51	11,3164	0,0264
35	53	11,3165	0,0265
36	55	11,3174	0,0274
37	57	11,3179	0,0279
38	59	11,3192	0,0292
39	61	11,3195	0,0295
40	63	11,3211	0,0311
41	65	11,3219	0,0319
42	70	11,3233	0,0333
43	75	11,3253	0,0353
44	80	11,3266	0,0366
45	85	11,3285	0,0385
46	90	11,3298	0,0398
47	95	11,331	0,041
48	100	11,3312	0,0412
49	105	11,3328	0,0428
50	110	11,3337	0,0437
51	115	11,3348	0,0448
52	120	11,3357	0,0457
53	125	11,3373	0,0473
54	130	11,3394	0,0494
55	135	11,3397	0,0497
56	140	11,3404	0,0504
57	145	11,3432	0,0532
58	150	11,3435	0,0535
59	155	11,3446	0,0546
60	160	11,347	0,057
61	165	11,3473	0,0573
62	170	11,3477	0,0577
63	175	11,3483	0,0583
64	180	11,3493	0,0593
65	185	11,3501	0,0601
66	190	11,3517	0,0617
67	195	11,3516	0,0616
68	200	11,3527	0,0627
69	205	11,354	0,064
70	210	11,3554	0,0654
71	215	11,357	0,067
72	220	11,3575	0,0675
73	225	11,358	0,068
74	230	11,3599	0,0699
75	235	11,3609	0,0709
76	240	11,3619	0,0719
77	245	11,363	0,073

 <p><b>TechnoRem Inc.</b>  <b>4701 rue Louis-B.-Mayer</b>  <b>Laval, Qc, H7P 6G5</b></p> <p><b>TechnoRem</b></p>				<p><b>Pumping Test - Water Level Data</b></p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 2 of 3
	Time [min]	Water Level [m]	Drawdown [m]	
78	250	11,3644	0,0744	
79	255	11,3655	0,0755	
80	260	11,3668	0,0768	
81	265	11,3683	0,0783	
82	270	11,3695	0,0795	
83	275	11,3697	0,0797	
84	280	11,3713	0,0813	
85	285	11,3713	0,0813	
86	290	11,3717	0,0817	
87	295	11,3724	0,0824	
88	300	11,3729	0,0829	
89	305	11,3728	0,0828	
90	310	11,374	0,084	
91	315	11,375	0,085	
92	320	11,3759	0,0859	
93	325	11,3766	0,0866	
94	330	11,3779	0,0879	
95	335	11,3787	0,0887	
96	340	11,3788	0,0888	
97	345	11,3786	0,0886	
98	350	11,3789	0,0889	
99	355	11,3796	0,0896	
100	360	11,3749	0,0849	
101	360,5	11,3741	0,0841	
102	361	11,3734	0,0834	
103	361,5	11,3727	0,0827	
104	362	11,3726	0,0826	
105	362,5	11,3718	0,0818	
106	363	11,3713	0,0813	
107	363,5	11,3711	0,0811	
108	364	11,3703	0,0803	
109	364,5	11,3699	0,0799	
110	365	11,3694	0,0794	
111	367	11,3674	0,0774	
112	369	11,3664	0,0764	
113	371	11,365	0,075	
114	373	11,3638	0,0738	
115	375	11,363	0,073	
116	377	11,3617	0,0717	
117	379	11,3608	0,0708	
118	381	11,3594	0,0694	
119	383	11,3587	0,0687	
120	385	11,3579	0,0679	
121	387	11,3571	0,0671	
122	389	11,3566	0,0666	
123	391	11,3559	0,0659	
124	393	11,3552	0,0652	
125	395	11,3546	0,0646	
126	397	11,3535	0,0635	
127	399	11,353	0,063	
128	401	11,3524	0,0624	
129	403	11,3518	0,0618	
130	405	11,3516	0,0616	
131	407	11,3513	0,0613	
132	409	11,351	0,061	
133	411	11,3504	0,0604	
134	413	11,3505	0,0605	
135	415	11,3501	0,0601	
136	417	11,3496	0,0596	
137	419	11,3484	0,0584	
138	421	11,3482	0,0582	
139	423	11,3478	0,0578	
140	425	11,3475	0,0575	
141	430	11,3471	0,0571	
142	435	11,346	0,056	
143	440	11,3446	0,0546	
144	445	11,3436	0,0536	
145	450	11,3429	0,0529	
146	455	11,3427	0,0527	
147	460	11,3422	0,0522	
148	465	11,3418	0,0518	
149	470	11,3409	0,0509	
150	475	11,3402	0,0502	
151	480	11,3398	0,0498	
152	485	11,3397	0,0497	
153	490	11,338	0,048	
154	495	11,338	0,048	
155	500	11,3371	0,0471	
156	505	11,3364	0,0464	
157	510	11,3363	0,0463	
158	515	11,3345	0,0445	
159	520	11,3347	0,0447	
160	525	11,3348	0,0448	
161	530	11,3347	0,0447	
162	535	11,3334	0,0434	



**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**TechnoRem**

**Pumping Test - Water Level Data**

Page 3 of 3

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

	Time [min]	Water Level [m]	Drawdown [m]
163	540	11,3331	0,0431
164	545	11,3325	0,0425
165	550	11,3327	0,0427
166	555	11,3324	0,0424
167	560	11,3321	0,0421
168	565	11,332	0,042
169	570	11,3308	0,0408
170	575	11,3301	0,0401
171	580	11,3294	0,0394
172	585	11,3288	0,0388
173	590	11,3285	0,0385
174	595	11,3281	0,0381
175	600	11,3279	0,0379
176	605	11,3276	0,0376
177	610	11,3274	0,0374
178	615	11,3265	0,0365
179	620	11,3266	0,0366
180	625	11,326	0,036
181	630	11,3251	0,0351
182	635	11,3241	0,0341
183	640	11,3246	0,0346
184	645	11,3252	0,0352
185	650	11,3252	0,0352
186	655	11,3254	0,0354
187	660	11,3244	0,0344
188	665	11,3239	0,0339
189	670	11,3233	0,0333
190	675	11,3228	0,0328
191	680	11,3229	0,0329
192	685	11,3225	0,0325
193	690	11,3218	0,0318
194	695	11,3222	0,0322
195	700	11,3223	0,0323
196	705	11,3231	0,0331
197	710	11,3224	0,0324
198	715	11,322	0,032
199	720	11,322	0,032
200	725	11,3225	0,0325
201	730	11,3225	0,0325
202	735	11,322	0,032
203	740	11,3219	0,0319
204	745	11,3227	0,0327
205	750	11,3226	0,0326
206	755	11,3235	0,0335
207	760	11,3238	0,0338
208	765	11,3238	0,0338
209	770	11,3242	0,0342
210	775	11,3237	0,0337
211	780	11,323	0,033
212	785	11,3229	0,0329
213	790	11,3232	0,0332
214	795	11,3241	0,0341
215	800	11,3245	0,0345
216	805	11,3244	0,0344
217	810	11,3249	0,0349
218	815	11,3253	0,0353
219	820	11,3254	0,0354
220	825	11,3252	0,0352
221	830	11,3251	0,0351
222	835	11,3256	0,0356
223	840	11,3256	0,0356
224	845	11,3243	0,0343
225	850	11,3237	0,0337
226	855	11,3225	0,0325
227	860	11,322	0,032
228	865	11,323	0,033
229	870	11,324	0,034
230	875	11,3241	0,0341
231	880	11,3241	0,0341
232	885	11,3246	0,0346
233	890	11,3238	0,0338
234	895	11,3239	0,0339
235	900	11,3233	0,0333



TechnoRem

**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**Pumping Test - Water Level Data**

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore

Pumping Test: PO-30

Pumping Well: PO-30

Test Conducted by: TechnoRem Inc.

Test Date: 2013-09-19

Discharge: variable, average rate 0,68611 [U.S. gal/min]

Observation Well: PO-32

Static Water Level [m]: 13,68

Radial Distance to PW [m]: 77,93

	Time [min]	Water Level [m]	Drawdown [m]
1	0	13,68	0,00
2	56	13,69	0,01
3	127	13,69	0,01
4	227	13,69	0,01
5	347	13,68	0,00
6	407	13,68	0,00

 <p><b>TechnoRem Inc.</b> 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p><b>TechnoRem</b></p>			
<b>Pumping Test - Water Level Data</b>			Page 1 of 3
Project: Travaux caractérisation complémentaire			
Number: PR13-79			
Client: TPSGC			
Location: Dépotoir Sambault - Saint-Isidore		Pumping Test: PO-30	Pumping Well: PO-30
Test Conducted by: TechnoRem Inc.		Test Date: 2013-09-19	Discharge: variable, average rate 0,68611 [U.S. gal/min]
Observation Well: PO-33		Static Water Level [m]: 12,26	Radial Distance to PW [m]: 79,5
	Time [min]	Water Level [m]	Drawdown [m]
1	0	12,26	0,00
2	0,5	12,2603	0,0003
3	1	12,2604	0,0004
4	1,5	12,2609	0,0009
5	2	12,2611	0,0011
6	2,5	12,2613	0,0013
7	3	12,2615	0,0015
8	3,5	12,2619	0,0019
9	4	12,2621	0,0021
10	4,5	12,2618	0,0018
11	5	12,2622	0,0022
12	7	12,263	0,003
13	9	12,2641	0,0041
14	11	12,2639	0,0039
15	13	12,2647	0,0047
16	15	12,2651	0,0051
17	17	12,2653	0,0053
18	19	12,2663	0,0063
19	21	12,2665	0,0065
20	23	12,2676	0,0076
21	25	12,2671	0,0071
22	27	12,2667	0,0067
23	29	12,2678	0,0078
24	31	12,2675	0,0075
25	33	12,2673	0,0073
26	35	12,2679	0,0079
27	37	12,2678	0,0078
28	39	12,2678	0,0078
29	41	12,2679	0,0079
30	43	12,2676	0,0076
31	45	12,2671	0,0071
32	47	12,2668	0,008
33	49	12,2689	0,0089
34	51	12,2688	0,0088
35	53	12,2689	0,0089
36	55	12,2693	0,0093
37	57	12,2685	0,0085
38	59	12,2692	0,0092
39	61	12,2695	0,0095
40	63	12,27	0,01
41	65	12,2698	0,0098
42	70	12,2706	0,0106
43	75	12,2721	0,0121
44	80	12,2725	0,0125
45	85	12,2741	0,0141
46	90	12,2744	0,0144
47	95	12,2745	0,0145
48	100	12,2741	0,0141
49	105	12,2745	0,0145
50	110	12,2757	0,0157
51	115	12,2753	0,0153
52	120	12,2758	0,0158
53	125	12,2768	0,0168
54	130	12,2778	0,018
55	135	12,2786	0,0186
56	140	12,2792	0,0192
57	145	12,2805	0,0205
58	150	12,281	0,021
59	155	12,2813	0,0213
60	160	12,2826	0,0226
61	165	12,2831	0,0231
62	170	12,2835	0,0235
63	175	12,2837	0,0237
64	180	12,2841	0,0241
65	185	12,2844	0,0244
66	190	12,2851	0,0251
67	195	12,2859	0,0259
68	200	12,2872	0,0272
69	205	12,2878	0,0278
70	210	12,2888	0,0288
71	215	12,2899	0,0299
72	220	12,2906	0,0306
73	225	12,2931	0,0331
74	230	12,2934	0,0334
75	235	12,2944	0,0344
76	240	12,2945	0,0345
77	245	12,2963	0,0363

 <p><b>TechnoRem Inc.</b>  <b>4701 rue Louis-B.-Mayer</b>  <b>Laval, Qc, H7P 6G5</b></p> <p><b>TechnoRem</b></p>				<p><b>Pumping Test - Water Level Data</b></p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 2 of 3
	Time [min]	Water Level [m]	Drawdown [m]	
78	250	12,2969	0,0369	
79	255	12,2978	0,0378	
80	260	12,2989	0,0389	
81	265	12,3004	0,0404	
82	270	12,3012	0,0412	
83	275	12,3015	0,0415	
84	280	12,3027	0,0427	
85	285	12,3031	0,0431	
86	290	12,3032	0,0432	
87	295	12,3043	0,0443	
88	300	12,3047	0,0447	
89	305	12,3052	0,0452	
90	310	12,3066	0,0466	
91	315	12,3069	0,0469	
92	320	12,3082	0,0482	
93	325	12,3086	0,0486	
94	330	12,3098	0,0498	
95	335	12,3109	0,0509	
96	340	12,311	0,051	
97	345	12,3051	0,0451	
98	350	12,3023	0,0423	
99	355	12,3047	0,0447	
100	360	12,3069	0,0469	
101	360,5	12,3071	0,0471	
102	361	12,3071	0,0471	
103	361,5	12,3077	0,0477	
104	362	12,3076	0,0476	
105	362,5	12,3075	0,0475	
106	363	12,3073	0,0473	
107	363,5	12,3078	0,0478	
108	364	12,3083	0,0483	
109	364,5	12,3084	0,0484	
110	365	12,3084	0,0484	
111	367	12,3092	0,0492	
112	369	12,31	0,05	
113	371	12,3113	0,0513	
114	373	12,3119	0,0519	
115	375	12,3127	0,0527	
116	377	12,3131	0,0531	
117	379	12,3135	0,0535	
118	381	12,314	0,054	
119	383	12,314	0,054	
120	385	12,3145	0,0545	
121	387	12,3148	0,0548	
122	389	12,3151	0,0551	
123	391	12,3151	0,0551	
124	393	12,3156	0,0556	
125	395	12,3161	0,0561	
126	397	12,3157	0,0557	
127	399	12,3156	0,0556	
128	401	12,3155	0,0555	
129	403	12,3166	0,0566	
130	405	12,3172	0,0572	
131	407	12,3178	0,0578	
132	409	12,3184	0,0584	
133	411	12,3189	0,0589	
134	413	12,3187	0,0587	
135	415	12,3187	0,0587	
136	417	12,3191	0,0591	
137	419	12,3188	0,0588	
138	421	12,3186	0,0586	
139	423	12,3184	0,0584	
140	425	12,3185	0,0585	
141	430	12,3185	0,0585	
142	435	12,3181	0,0581	
143	440	12,3177	0,0577	
144	445	12,3172	0,0572	
145	450	12,3166	0,0566	
146	455	12,3162	0,0562	
147	460	12,3165	0,0565	
148	465	12,3164	0,0564	
149	470	12,3156	0,0556	
150	475	12,3153	0,0553	
151	480	12,3148	0,0548	
152	485	12,3149	0,0549	
153	490	12,3138	0,0538	
154	495	12,3133	0,0533	
155	500	12,312	0,052	
156	505	12,3113	0,0513	
157	510	12,3113	0,0513	
158	515	12,3096	0,0496	
159	520	12,3097	0,0497	
160	525	12,3094	0,0494	
161	530	12,3092	0,0492	
162	535	12,3078	0,0478	



**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**TechnoRem**

**Pumping Test - Water Level Data**

Page 3 of 3

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

	Time [min]	Water Level [m]	Drawdown [m]
163	540	12,3079	0,0479
164	545	12,3065	0,0465
165	550	12,3064	0,0464
166	555	12,3055	0,0455
167	560	12,3054	0,0454
168	565	12,3047	0,0447
169	570	12,3034	0,0434
170	575	12,3027	0,0427
171	580	12,3015	0,0415
172	585	12,3009	0,0409
173	590	12,2995	0,0395
174	595	12,299	0,039
175	600	12,2989	0,0389
176	605	12,2983	0,0383
177	610	12,2976	0,0376
178	615	12,2965	0,0365
179	620	12,2959	0,0359
180	625	12,2949	0,0349
181	630	12,2944	0,0344
182	635	12,2928	0,0328
183	640	12,293	0,033
184	645	12,293	0,033
185	650	12,2932	0,0332
186	655	12,2931	0,0331
187	660	12,2912	0,0312
188	665	12,2904	0,0304
189	670	12,2897	0,0297
190	675	12,2891	0,0291
191	680	12,2885	0,0285
192	685	12,2875	0,0275
193	690	12,2866	0,0266
194	695	12,2868	0,0268
195	700	12,2867	0,0267
196	705	12,287	0,027
197	710	12,2864	0,0264
198	715	12,285	0,025
199	720	12,2849	0,0249
200	725	12,2847	0,0247
201	730	12,2844	0,0244
202	735	12,2831	0,0231
203	740	12,2834	0,0234
204	745	12,2832	0,0232
205	750	12,2844	0,0244
206	755	12,284	0,024
207	760	12,2838	0,0238
208	765	12,2834	0,0234
209	770	12,2829	0,0229
210	775	12,2823	0,0223
211	780	12,2816	0,0216
212	785	12,2808	0,0208
213	790	12,2813	0,0213
214	795	12,282	0,022
215	800	12,282	0,022
216	805	12,2817	0,0217
217	810	12,282	0,022
218	815	12,2819	0,0219
219	820	12,2816	0,0216
220	825	12,2815	0,0215
221	830	12,2816	0,0216
222	835	12,2818	0,0218
223	840	12,2809	0,0209
224	845	12,2796	0,0196
225	850	12,2786	0,0186
226	855	12,2772	0,0172
227	860	12,277	0,017
228	865	12,2778	0,0178
229	870	12,2787	0,0187
230	875	12,2787	0,0187
231	880	12,2783	0,0183
232	885	12,279	0,019
233	890	12,2781	0,0181
234	895	12,2779	0,0179
235	900	12,2773	0,0173



TechnoRem

**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**Pumping Test - Water Level Data**

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore

Pumping Test: PO-30

Pumping Well: PO-30

Test Conducted by: TechnoRem Inc.

Test Date: 2013-09-19

Discharge: variable, average rate 0,68611 [U.S. gal/min]

Observation Well: PO-34

Static Water Level [m]: 7,51

Radial Distance to PW [m]: 78,56

	Time [min]	Water Level [m]	Drawdown [m]
1	0	7,51	0,00
2	56	7,48	-0,03
3	127	7,49	-0,02
4	227	7,49	-0,02
5	347	7,49	-0,02
6	407	7,49	-0,02

 <p><b>TechnoRem Inc.</b>  <b>4701 rue Louis-B.-Mayer</b>  <b>Laval, Qc, H7P 6G5</b></p> <p><b>TechnoRem</b></p>		<p><b>Pumping Test - Water Level Data</b></p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>	Page 1 of 1
Location: Dépotoir Sambault - Saint-Isidore		Pumping Test: PO-30	Pumping Well: PO-30
Test Conducted by: TechnoRem Inc.		Test Date: 2013-09-19	Discharge: variable, average rate 0,68611 [U.S. gal/min]
Observation Well: PO-35		Static Water Level [m]: 10,06	Radial Distance to PW [m]: 127,59
	Time [min]	Water Level [m]	Drawdown [m]
1	0	10,06	0,00
2	53	10,06	0,00
3	123	10,05	-0,01
4	223	10,05	-0,01
5	344	10,05	-0,01
6	411	10,05	-0,01



TechnoRem

**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**Pumping Test - Water Level Data**

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore

Pumping Test: PO-30

Pumping Well: PO-30

Test Conducted by: TechnoRem Inc.

Test Date: 2013-09-19

Discharge: variable, average rate 0,68611 [U.S. gal/min]

Observation Well: PO-36

Static Water Level [m]: 6,83

Radial Distance to PW [m]: 126,19

	Time [min]	Water Level [m]	Drawdown [m]
1	0	6,83	0,00
2	53	6,83	0,00
3	123	6,83	0,00
4	223	6,83	0,00
5	344	6,82	-0,01
6	411	6,82	-0,01



TechnoRem

**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**Pumping Test - Water Level Data**

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore

Pumping Test: PO-30

Pumping Well: PO-30

Test Conducted by: TechnoRem Inc.

Test Date: 2013-09-19

Discharge: variable, average rate 0,68611 [U.S. gal/min]

Observation Well: PO-45

Static Water Level [m]: 12,50

Radial Distance to PW [m]: 67

	Time [min]	Water Level [m]	Drawdown [m]
1	0	12,50	0,00
2	49	12,50	0,00
3	118	12,49	-0,01
4	218	12,50	0,00
5	351	12,50	0,00
6	429	12,51	0,01



TechnoRem

**TechnoRem Inc.**  
**4701 rue Louis-B.-Mayer**  
**Laval, Qc, H7P 6G5**

**Pumping Test - Water Level Data**

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore

Pumping Test: PO-30

Pumping Well: PO-30

Test Conducted by: TechnoRem Inc.

Test Date: 2013-09-19

Discharge: variable, average rate 0,68611 [U.S. gal/min]

Observation Well: PO-46

Static Water Level [m]: 6,76

Radial Distance to PW [m]: 68,09

	Time [min]	Water Level [m]	Drawdown [m]
1	0	6,76	0,00
2	49	6,76	0,00
3	118	6,75	-0,01
4	218	6,75	-0,01
5	351	6,75	-0,01
6	429	6,75	-0,01