



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-31 | Static Water Level [m]: 4,64 | Radial Distance to PW [m]: 78,7

	Time [min]	Water Level [m]	Drawdown [m]
1	0	4,64	0,00
2	54	4,64	0,00
3	93	4,64	0,00
4	173	4,64	0,00
5	264	4,64	0,00
6	350	4,64	0,00
7	413	4,64	0,00

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>		<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>	
Location: Dépotoir Sambault - Saint-Isidore		Pumping Test: PO-33	
Test Conducted by: TechnoRem Inc.		Test Date: 2013-09-18	
Observation Well: PO-30		Static Water Level [m]: 10,58	
	Time [min]	Water Level [m]	Drawdown [m]
1	0	10,58	0,00
2	54	10,57	-0,01
3	93	10,57	-0,01
4	173	10,57	-0,01
5	264	10,57	-0,01
6	350	10,56	-0,02
7	414	10,56	-0,02



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-29 | Static Water Level [m]: 11,36 | Radial Distance to PW [m]: 81,32

	Time [min]	Water Level [m]	Drawdown [m]
1	0	11,36	0,00
2	54	11,35	-0,01
3	93	11,35	-0,01
4	173	11,35	-0,01
5	264	11,34	-0,02
6	350	11,31	-0,05
7	412	11,30	-0,06



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 4

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-32 | Static Water Level [m]: 13,71 | Radial Distance to PW [m]: 3

	Time [min]	Water Level [m]	Drawdown [m]
1	0	13,71	0,00
2	0,5	13,7099	-0,0001
3	1	13,7098	-0,0002
4	1,5	13,7093	-0,0007
5	2	13,7098	-0,0002
6	2,5	13,7099	-0,0001
7	3	13,7098	-0,0002
8	3,5	13,7104	0,0004
9	4	13,71	0,00
10	4,5	13,7104	0,0004
11	5	13,7092	-0,0008
12	7	13,7098	-0,0002
13	9	13,7104	0,0004
14	11	13,7092	-0,0008
15	13	13,7089	-0,0011
16	15	13,7099	-0,0001
17	17	13,7105	0,0005
18	19	13,7101	0,0001
19	21	13,71	0,00
20	23	13,7101	0,0001
21	25	13,7106	0,0006
22	27	13,7111	0,0011
23	29	13,7105	0,0005
24	31	13,7107	0,0007
25	33	13,71	0,00
26	35	13,71	0,00
27	37	13,7098	-0,0002
28	39	13,7114	0,0014
29	41	13,711	0,001
30	43	13,7107	0,0007
31	45	13,7111	0,0011
32	47	13,7107	0,0007
33	49	13,7105	0,0005
34	51	13,7102	0,0002
35	53	13,7099	-0,0001
36	55	13,7104	0,0004
37	57	13,7103	0,0003
38	59	13,7106	0,0006
39	61	13,7109	0,0009
40	63	13,711	0,001
41	65	13,711	0,001
42	70	13,7109	0,0009
43	75	13,7106	0,0006
44	80	13,7097	-0,0003
45	85	13,7106	0,0006
46	90	13,7106	0,0006
47	95	13,7104	0,0004
48	100	13,7113	0,0013
49	105	13,711	0,001
50	110	13,7109	0,0009
51	115	13,7113	0,0013
52	120	13,7111	0,0011
53	125	13,7121	0,0021
54	130	13,7126	0,0026
55	135	13,7123	0,0023
56	140	13,7128	0,0028
57	145	13,713	0,003
58	150	13,7124	0,0024
59	155	13,713	0,003
60	160	13,7125	0,0025
61	165	13,7117	0,0017
62	170	13,7118	0,0018
63	175	13,7113	0,0013
64	180	13,7116	0,0016
65	185	13,7112	0,0012
66	190	13,7113	0,0013
67	195	13,7109	0,0009
68	200	13,7118	0,0018
69	205	13,7108	0,0008
70	210	13,7109	0,0009
71	215	13,7119	0,0019
72	220	13,7107	0,0007
73	225	13,7137	0,0037
74	230	13,7081	-0,0019
75	235	13,7076	-0,0024
76	240	13,7073	-0,0027
77	245	13,7063	-0,0037

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
	Time [min]	Water Level [m]	Drawdown [m]	
78	250	13,7066	-0,0034	
79	255	13,7061	-0,0039	
80	260	13,7049	-0,0051	
81	265	13,7053	-0,0047	
82	270	13,7049	-0,0051	
83	275	13,7045	-0,0055	
84	280	13,7046	-0,0054	
85	285	13,7035	-0,0065	
86	290	13,7032	-0,0068	
87	295	13,7037	-0,0063	
88	300	13,7027	-0,0073	
89	305	13,7013	-0,0087	
90	310	13,7021	-0,0079	
91	315	13,7019	-0,0081	
92	320	13,7003	-0,0097	
93	325	13,70	-0,01	
94	330	13,7001	-0,0099	
95	335	13,6995	-0,0105	
96	340	13,6989	-0,0111	
97	345	13,6982	-0,0118	
98	350	13,6978	-0,0122	
99	355	13,6976	-0,0124	
100	360	13,6958	-0,0142	
101	365	13,6981	-0,0119	
102	370	13,6953	-0,0147	
103	373	13,6947	-0,0153	
104	373,5	13,6958	-0,0142	
105	374	13,6945	-0,0155	
106	374,5	13,6951	-0,0149	
107	375	13,6953	-0,0147	
108	375,5	13,694	-0,016	
109	376	13,6953	-0,0147	
110	376,5	13,6946	-0,0154	
111	377	13,6946	-0,0154	
112	377,5	13,6948	-0,0152	
113	378	13,6948	-0,0152	
114	380	13,6953	-0,0147	
115	382	13,6943	-0,0157	
116	384	13,6941	-0,0159	
117	386	13,6942	-0,0158	
118	388	13,6932	-0,0168	
119	390	13,693	-0,017	
120	392	13,6931	-0,0169	
121	394	13,6935	-0,0165	
122	396	13,6924	-0,0176	
123	398	13,6926	-0,0174	
124	400	13,692	-0,018	
125	402	13,6925	-0,0175	
126	404	13,6917	-0,0183	
127	406	13,6915	-0,0185	
128	408	13,6924	-0,0176	
129	410	13,6914	-0,0186	
130	412	13,6912	-0,0188	
131	414	13,6906	-0,0194	
132	416	13,6903	-0,0197	
133	418	13,6893	-0,0207	
134	420	13,6888	-0,0212	
135	422	13,6892	-0,0208	
136	424	13,6883	-0,0217	
137	426	13,6885	-0,0215	
138	428	13,6876	-0,0224	
139	430	13,6875	-0,0225	
140	432	13,6869	-0,0231	
141	434	13,6866	-0,0234	
142	436	13,6867	-0,0233	
143	438	13,6863	-0,0237	
144	443	13,6867	-0,0233	
145	448	13,6855	-0,0245	
146	453	13,6863	-0,0237	
147	458	13,6847	-0,0253	
148	463	13,6844	-0,0256	
149	468	13,6842	-0,0258	
150	473	13,6846	-0,0254	
151	478	13,6851	-0,0249	
152	483	13,6845	-0,0255	
153	488	13,6837	-0,0263	
154	493	13,6832	-0,0268	
155	498	13,6824	-0,0276	
156	503	13,6823	-0,0277	
157	508	13,682	-0,028	
158	513	13,6809	-0,0291	
159	518	13,6806	-0,0294	
160	523	13,6807	-0,0293	
161	528	13,68	-0,03	
162	533	13,6811	-0,0289	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 3 of 4
	Time [min]	Water Level [m]	Drawdown [m]	
163	538	13,6814	-0,0286	
164	543	13,6811	-0,0289	
165	548	13,6815	-0,0285	
166	553	13,682	-0,028	
167	558	13,6811	-0,0289	
168	563	13,6819	-0,0281	
169	568	13,6808	-0,0292	
170	573	13,6806	-0,0294	
171	578	13,6797	-0,0303	
172	583	13,6805	-0,0295	
173	588	13,6802	-0,0298	
174	593	13,6805	-0,0295	
175	598	13,6808	-0,0292	
176	603	13,6809	-0,0291	
177	608	13,6811	-0,0289	
178	613	13,68	-0,03	
179	618	13,6801	-0,0299	
180	623	13,6806	-0,0294	
181	628	13,6798	-0,0302	
182	633	13,6799	-0,0301	
183	638	13,6816	-0,0284	
184	643	13,6812	-0,0288	
185	648	13,6813	-0,0287	
186	653	13,6817	-0,0283	
187	658	13,6814	-0,0286	
188	663	13,6818	-0,0282	
189	668	13,6817	-0,0283	
190	673	13,6822	-0,0278	
191	678	13,6838	-0,0262	
192	683	13,6841	-0,0259	
193	688	13,6837	-0,0263	
194	693	13,6842	-0,0258	
195	698	13,6841	-0,0259	
196	703	13,6846	-0,0254	
197	708	13,684	-0,026	
198	713	13,6852	-0,0248	
199	718	13,6863	-0,0247	
200	723	13,6863	-0,0237	
201	728	13,6869	-0,0231	
202	733	13,687	-0,023	
203	738	13,688	-0,022	
204	743	13,6885	-0,0215	
205	748	13,6894	-0,0206	
206	753	13,6897	-0,0203	
207	758	13,6903	-0,0197	
208	763	13,6906	-0,0194	
209	768	13,6918	-0,0182	
210	773	13,6909	-0,0191	
211	778	13,6912	-0,0188	
212	783	13,6914	-0,0186	
213	788	13,6908	-0,0192	
214	793	13,6914	-0,0186	
215	798	13,6915	-0,0185	
216	803	13,6922	-0,0178	
217	808	13,6929	-0,0171	
218	813	13,6931	-0,0169	
219	818	13,6945	-0,0155	
220	823	13,6955	-0,0145	
221	828	13,6955	-0,0145	
222	833	13,6945	-0,0155	
223	838	13,6961	-0,0139	
224	843	13,6957	-0,0143	
225	848	13,6971	-0,0129	
226	853	13,6966	-0,0134	
227	858	13,6956	-0,0144	
228	863	13,6956	-0,0144	
229	868	13,6963	-0,0137	
230	873	13,6952	-0,0148	
231	878	13,6959	-0,0141	
232	883	13,6963	-0,0137	
233	888	13,6959	-0,0141	
234	893	13,6966	-0,0134	
235	898	13,6963	-0,0137	
236	903	13,6962	-0,0138	
237	908	13,6961	-0,0139	
238	913	13,696	-0,014	
239	918	13,6951	-0,0149	
240	923	13,6949	-0,0151	
241	928	13,6928	-0,0172	
242	933	13,6923	-0,0177	
243	938	13,6924	-0,0176	
244	943	13,6929	-0,0171	
245	948	13,6929	-0,0171	
246	953	13,6924	-0,0176	
247	958	13,6919	-0,0181	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 4 of 4
	Time [min]	Water Level [m]	Drawdown [m]	
248	963	13,6921	-0,0179	
249	968	13,6908	-0,0192	
250	973	13,6907	-0,0193	
251	978	13,6913	-0,0187	
252	983	13,6899	-0,0201	
253	988	13,6904	-0,0196	
254	993	13,6898	-0,0202	
255	998	13,6897	-0,0203	
256	1003	13,6893	-0,0207	
257	1008	13,6899	-0,0201	
258	1013	13,6906	-0,0194	
259	1018	13,6908	-0,0192	
260	1023	13,6914	-0,0186	
261	1028	13,6904	-0,0196	
262	1033	13,6904	-0,0196	
263	1038	13,6894	-0,0206	
264	1043	13,6879	-0,0221	
265	1048	13,6878	-0,0222	
266	1053	13,6884	-0,0216	
267	1058	13,6884	-0,0216	
268	1063	13,6879	-0,0221	
269	1068	13,6888	-0,0212	
270	1073	13,6877	-0,0223	
271	1078	13,6878	-0,0222	
272	1083	13,6867	-0,0233	
273	1088	13,6877	-0,0223	
274	1093	13,6872	-0,0228	
275	1098	13,686	-0,024	
276	1103	13,6858	-0,0242	
277	1108	13,6853	-0,0247	
278	1113	13,6852	-0,0248	
279	1118	13,6844	-0,0256	
280	1123	13,6842	-0,0258	
281	1128	13,6842	-0,0258	
282	1133	13,6835	-0,0265	
283	1138	13,6832	-0,0268	
284	1143	13,6839	-0,0261	
285	1148	13,6829	-0,0271	
286	1153	13,6819	-0,0281	
287	1158	13,6808	-0,0292	
288	1163	13,681	-0,029	
289	1168	13,6802	-0,0298	
290	1173	13,6804	-0,0296	
291	1178	13,6801	-0,0299	
292	1183	13,6803	-0,0297	
293	1188	13,68	-0,03	
294	1193	13,6794	-0,0306	
295	1198	13,6791	-0,0309	
296	1203	13,6788	-0,0312	
297	1208	13,6786	-0,0314	
298	1213	13,6782	-0,0318	
299	1218	13,6772	-0,0328	
300	1223	13,6771	-0,0329	
301	1228	13,6763	-0,0337	
302	1233	13,6752	-0,0348	
303	1238	13,6755	-0,0345	
304	1243	13,6752	-0,0348	
305	1248	13,6746	-0,0354	
306	1253	13,6739	-0,0361	
307	1258	13,6733	-0,0367	
308	1263	13,6729	-0,0371	
309	1268	13,6735	-0,0365	
310	1273	13,6737	-0,0363	
311	1278	13,672	-0,038	
312	1283	13,6728	-0,0372	
313	1288	13,6736	-0,0364	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>			
			Pumping Test - Water Level Data
Project: Travaux caractérisation complémentaire			Page 1 of 4
Number: PR13-79			
Client: TPSGC			
Location: Dépotoir Sambault - Saint-Isidore		Pumping Test: PO-33	Pumping Well: PO-33
Test Conducted by: TechnoRem Inc.		Test Date: 2013-09-18	Discharge: variable, average rate 0,56668 [U.S. gal/min]
Observation Well: PO-33		Static Water Level [m]: 12,46	Radial Distance to PW [m]: -
	Time [min]	Water Level [m]	Drawdown [m]
1	0	12,46	0,00
2	0,5	12,7902	0,3302
3	1	13,3365	0,8765
4	1,5	13,7158	1,2558
5	2	13,9685	1,5085
6	2,5	14,1409	1,6809
7	3	14,2598	1,7998
8	3,5	14,3372	1,8772
9	4	14,3893	1,9293
10	4,5	14,4235	1,9635
11	5	14,4522	1,9922
12	7	14,509	2,049
13	9	14,5024	2,0424
14	11	14,5465	2,0865
15	13	14,9051	2,4451
16	15	15,078	2,618
17	17	15,1346	2,6746
18	19	15,1589	2,6989
19	21	15,1778	2,7178
20	23	15,1825	2,7225
21	25	15,205	2,745
22	27	15,2207	2,7607
23	29	15,2257	2,7657
24	31	14,6686	2,2086
25	33	14,6908	2,2308
26	35	14,7982	2,3382
27	37	15,0348	2,5748
28	39	15,0801	2,6201
29	41	15,0894	2,6294
30	43	15,094	2,634
31	45	15,0929	2,6329
32	47	15,0975	2,6375
33	49	15,1065	2,6465
34	51	15,1014	2,6414
35	53	15,0947	2,6347
36	55	15,096	2,636
37	57	15,0945	2,6345
38	59	15,1026	2,6426
39	61	15,1015	2,6415
40	63	15,1008	2,6408
41	65	15,1024	2,6424
42	70	15,0673	2,6073
43	75	18,6493	6,1893
44	80	18,6115	6,1515
45	85	18,4299	5,9699
46	90	18,419	5,959
47	95	18,4147	5,9547
48	100	18,4047	5,9447
49	105	18,3977	5,9377
50	110	18,3963	5,9363
51	115	18,3428	5,8828
52	120	18,3395	5,8795
53	125	18,3376	5,8776
54	130	18,3357	5,8757
55	135	18,342	5,882
56	140	18,346	5,886
57	145	18,3398	5,8798
58	150	18,3425	5,8825
59	155	18,3448	5,8848
60	160	18,3487	5,8887
61	165	18,3498	5,8898
62	170	18,3521	5,8921
63	175	18,3423	5,8823
64	180	18,3412	5,8812
65	185	18,3398	5,8798
66	190	18,8242	6,3642
67	195	18,8002	6,3402
68	200	18,3797	5,9197
69	205	18,3478	5,8878
70	210	18,3361	5,8761
71	215	18,3437	5,8837
72	220	18,341	5,881
73	225	18,3419	5,8819
74	230	18,3352	5,8752
75	235	18,3342	5,8742
76	240	18,3369	5,8769
77	245	18,3308	5,8708

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
	Time [min]	Water Level [m]	Drawdown [m]	
78	250	18,3449	5,8849	
79	255	18,3402	5,8802	
80	260	18,3389	5,8789	
81	265	18,3428	5,8828	
82	270	18,3459	5,8859	
83	275	18,3481	5,8881	
84	280	18,3401	5,8801	
85	285	18,3425	5,8825	
86	290	18,3409	5,8809	
87	295	18,3442	5,8842	
88	300	18,3643	5,9043	
89	305	18,3708	5,9108	
90	310	18,5145	6,0545	
91	315	18,5151	6,0551	
92	320	18,526	6,066	
93	325	18,5382	6,0782	
94	330	18,5369	6,0769	
95	335	18,534	6,074	
96	340	18,5381	6,0781	
97	345	18,7173	6,2573	
98	350	18,7667	6,3067	
99	355	18,7719	6,3119	
100	360	18,7809	6,3209	
101	365	18,9034	6,4434	
102	370	18,9059	6,4459	
103	373	18,92	6,46	
104	373,5	18,8281	6,3681	
105	374	18,3644	5,9044	
106	374,5	17,9436	5,4836	
107	375	17,5398	5,0798	
108	375,5	17,1881	4,7281	
109	376	16,8911	4,4311	
110	376,5	16,5774	4,1174	
111	377	16,2841	3,8241	
112	377,5	16,0369	3,5769	
113	378	15,7984	3,3384	
114	380	15,0639	2,6039	
115	382	14,5277	2,0677	
116	384	14,1492	1,6892	
117	386	13,8365	1,3765	
118	388	13,5746	1,1146	
119	390	13,3901	0,9301	
120	392	13,2703	0,8103	
121	394	13,1202	0,6602	
122	396	13,1065	0,6465	
123	398	13,0501	0,5901	
124	400	13,0044	0,5444	
125	402	12,9695	0,5095	
126	404	12,9407	0,4807	
127	406	12,929	0,469	
128	408	12,9076	0,4476	
129	410	12,8901	0,4301	
130	412	12,8736	0,4136	
131	414	12,8602	0,4002	
132	416	12,848	0,388	
133	418	12,8369	0,3769	
134	420	12,8275	0,3675	
135	422	12,8191	0,3591	
136	424	12,8089	0,3489	
137	426	12,803	0,343	
138	428	12,7962	0,3362	
139	430	12,7897	0,3297	
140	432	12,784	0,324	
141	434	12,7784	0,3184	
142	436	12,7736	0,3136	
143	438	12,7682	0,3082	
144	443	12,7585	0,2985	
145	448	12,7501	0,2901	
146	453	12,7428	0,2828	
147	458	12,7353	0,2753	
148	463	12,7277	0,2677	
149	468	12,721	0,261	
150	473	12,7152	0,2552	
151	478	12,7095	0,2495	
152	483	12,7038	0,2438	
153	488	12,698	0,238	
154	493	12,6928	0,2328	
155	498	12,6881	0,2281	
156	503	12,6833	0,2233	
157	508	12,6779	0,2179	
158	513	12,6735	0,2135	
159	518	12,6697	0,2097	
160	523	12,6654	0,2054	
161	528	12,6614	0,2014	
162	533	12,6576	0,1976	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 3 of 4
	Time [min]	Water Level [m]	Drawdown [m]	
163	538	12,655	0,195	
164	543	12,6512	0,1912	
165	548	12,6482	0,1882	
166	553	12,6446	0,1846	
167	558	12,6423	0,1823	
168	563	12,6388	0,1788	
169	568	12,6352	0,1752	
170	573	12,6322	0,1722	
171	578	12,6286	0,1686	
172	583	12,6257	0,1657	
173	588	12,6227	0,1627	
174	593	12,6199	0,1599	
175	598	12,617	0,157	
176	603	12,615	0,155	
177	608	12,6119	0,1519	
178	613	12,6087	0,1487	
179	618	12,6061	0,1461	
180	623	12,6038	0,1438	
181	628	12,6005	0,1405	
182	633	12,5989	0,1389	
183	638	12,5974	0,1374	
184	643	12,5951	0,1351	
185	648	12,5931	0,1331	
186	653	12,5912	0,1312	
187	658	12,5885	0,1285	
188	663	12,5859	0,1259	
189	668	12,5847	0,1247	
190	673	12,5833	0,1233	
191	678	12,5824	0,1224	
192	683	12,5802	0,1202	
193	688	12,5758	0,118	
194	693	12,5767	0,1167	
195	698	12,5746	0,1146	
196	703	12,5728	0,1128	
197	708	12,5711	0,1111	
198	713	12,5702	0,1102	
199	718	12,5685	0,1085	
200	723	12,5658	0,108	
201	728	12,5665	0,1065	
202	733	12,5656	0,1056	
203	738	12,5639	0,1039	
204	743	12,5633	0,1033	
205	748	12,5622	0,1022	
206	753	12,5602	0,1002	
207	758	12,5597	0,0997	
208	763	12,5587	0,0987	
209	768	12,5575	0,0975	
210	773	12,5562	0,0962	
211	778	12,5551	0,0951	
212	783	12,5539	0,0939	
213	788	12,5526	0,0926	
214	793	12,5514	0,0914	
215	798	12,55	0,09	
216	803	12,5493	0,0893	
217	808	12,5487	0,0887	
218	813	12,5476	0,0876	
219	818	12,5477	0,0877	
220	823	12,5469	0,0869	
221	828	12,5457	0,0857	
222	833	12,5446	0,0846	
223	838	12,5445	0,0845	
224	843	12,5442	0,0842	
225	848	12,5436	0,0836	
226	853	12,542	0,082	
227	858	12,5398	0,0798	
228	863	12,5392	0,0792	
229	868	12,5385	0,0785	
230	873	12,537	0,077	
231	878	12,5358	0,0758	
232	883	12,5353	0,0753	
233	888	12,5348	0,0748	
234	893	12,5335	0,0735	
235	898	12,5326	0,0726	
236	903	12,5321	0,0721	
237	908	12,5314	0,0714	
238	913	12,5303	0,0703	
239	918	12,5282	0,0682	
240	923	12,5268	0,0668	
241	928	12,5249	0,0649	
242	933	12,523	0,063	
243	938	12,5231	0,0631	
244	943	12,5228	0,0628	
245	948	12,5225	0,0625	
246	953	12,5212	0,0612	
247	958	12,5209	0,0609	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 4 of 4
	Time [min]	Water Level [m]	Drawdown [m]	
248	963	12,5199	0,0599	
249	968	12,5185	0,0585	
250	973	12,5176	0,0576	
251	978	12,517	0,057	
252	983	12,5156	0,0556	
253	988	12,5153	0,0553	
254	993	12,5144	0,0544	
255	998	12,514	0,054	
256	1003	12,5135	0,0535	
257	1008	12,5138	0,0538	
258	1013	12,5136	0,0536	
259	1018	12,5145	0,0545	
260	1023	12,5135	0,0535	
261	1028	12,5124	0,0524	
262	1033	12,5119	0,0519	
263	1038	12,5113	0,0513	
264	1043	12,5101	0,0501	
265	1048	12,5096	0,0496	
266	1053	12,5089	0,0489	
267	1058	12,5096	0,0496	
268	1063	12,5091	0,0491	
269	1068	12,5093	0,0493	
270	1073	12,5081	0,0481	
271	1078	12,5081	0,0481	
272	1083	12,5074	0,0474	
273	1088	12,5076	0,0476	
274	1093	12,5072	0,0472	
275	1098	12,5058	0,0458	
276	1103	12,5054	0,0454	
277	1108	12,5053	0,0453	
278	1113	12,5045	0,0445	
279	1118	12,504	0,044	
280	1123	12,5038	0,0438	
281	1128	12,5041	0,0441	
282	1133	12,5027	0,0427	
283	1138	12,5029	0,0429	
284	1143	12,5031	0,0431	
285	1148	12,5019	0,0419	
286	1153	12,5009	0,0409	
287	1158	12,5002	0,0402	
288	1163	12,5002	0,0402	
289	1168	12,499	0,039	
290	1173	12,4989	0,0389	
291	1178	12,4985	0,0385	
292	1183	12,4982	0,0382	
293	1188	12,4977	0,0377	
294	1193	12,4971	0,0371	
295	1198	12,4972	0,0372	
296	1203	12,4967	0,0367	
297	1208	12,4959	0,0359	
298	1213	12,4954	0,0354	
299	1218	12,4948	0,0348	
300	1223	12,4942	0,0342	
301	1228	12,4935	0,0335	
302	1233	12,4923	0,0323	
303	1238	12,4919	0,0319	
304	1243	12,4908	0,0308	
305	1248	12,4899	0,0299	
306	1253	12,4892	0,0292	
307	1258	12,4889	0,0289	
308	1263	12,4885	0,0285	
309	1268	12,4883	0,0283	
310	1273	12,4878	0,0278	
311	1278	12,4871	0,0271	
312	1283	12,487	0,027	
313	1288	12,486	0,026	
314	1293	12,4859	0,0259	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>	<p>Page 1 of 4</p>
Location: Dépotoir Sambault - Saint-Isidore				Pumping Test: PO-33	Pumping Well: PO-33
Test Conducted by: TechnoRem Inc.				Test Date: 2013-09-18	Discharge: variable, average rate 0,56668 [U.S. gal/min]
Observation Well: PO-34		Static Water Level [m]: 7,51		Radial Distance to PW [m]: 1,68	
	Time [min]	Water Level [m]	Drawdown [m]		
1	0	7,51	0,00		
2	0,5	7,5096	-0,0004		
3	1	7,511	0,001		
4	1,5	7,5134	0,0034		
5	2	7,5163	0,0063		
6	2,5	7,5191	0,0091		
7	3	7,5223	0,0123		
8	3,5	7,5253	0,0153		
9	4	7,5282	0,0182		
10	4,5	7,5309	0,0209		
11	5	7,5335	0,0235		
12	7	7,542	0,032		
13	9	7,548	0,038		
14	11	7,5526	0,0426		
15	13	7,5577	0,0477		
16	15	7,5664	0,0564		
17	17	7,5732	0,0632		
18	19	7,579	0,069		
19	21	7,583	0,073		
20	23	7,5868	0,0768		
21	25	7,5894	0,0794		
22	27	7,5929	0,0829		
23	29	7,5953	0,0853		
24	31	7,5947	0,0847		
25	33	7,5921	0,0821		
26	35	7,5902	0,0802		
27	37	7,5929	0,0829		
28	39	7,5952	0,0852		
29	41	7,5977	0,0877		
30	43	7,5994	0,0894		
31	45	7,60	0,09		
32	47	7,6019	0,0919		
33	49	7,6029	0,0929		
34	51	7,6047	0,0947		
35	53	7,6056	0,0956		
36	55	7,6064	0,0964		
37	57	7,6066	0,0966		
38	59	7,6074	0,0974		
39	61	7,6082	0,0982		
40	63	7,6089	0,0989		
41	65	7,6101	0,1001		
42	70	7,6115	0,1015		
43	75	7,6795	0,1695		
44	80	7,7289	0,2189		
45	85	7,7526	0,2426		
46	90	7,7702	0,2602		
47	95	7,7831	0,2731		
48	100	7,7941	0,2841		
49	105	7,8032	0,2932		
50	110	7,809	0,299		
51	115	7,8158	0,3058		
52	120	7,8218	0,3118		
53	125	7,8282	0,3182		
54	130	7,8311	0,3211		
55	135	7,8352	0,3252		
56	140	7,8392	0,3292		
57	145	7,8434	0,3334		
58	150	7,8471	0,3371		
59	155	7,8498	0,3398		
60	160	7,8528	0,3428		
61	165	7,8563	0,3463		
62	170	7,8584	0,3484		
63	175	7,8614	0,3514		
64	180	7,8644	0,3544		
65	185	7,8663	0,3563		
66	190	7,8788	0,3688		
67	195	7,8878	0,3778		
68	200	7,8857	0,3757		
69	205	7,885	0,375		
70	210	7,8849	0,3749		
71	215	7,8867	0,3767		
72	220	7,8874	0,3774		
73	225	7,8887	0,3787		
74	230	7,8907	0,3807		
75	235	7,8923	0,3823		
76	240	7,894	0,384		
77	245	7,8952	0,3852		



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 2 of 4

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

	Time [min]	Water Level [m]	Drawdown [m]
78	250	7,8961	0,3861
79	255	7,8986	0,3886
80	260	7,8995	0,3895
81	265	7,9005	0,3905
82	270	7,9019	0,3919
83	275	7,9026	0,3926
84	280	7,9053	0,3953
85	285	7,9052	0,3952
86	290	7,9053	0,3953
87	295	7,9063	0,3963
88	300	7,9061	0,3961
89	305	7,9064	0,3964
90	310	7,909	0,399
91	315	7,9126	0,4026
92	320	7,9152	0,4052
93	325	7,9147	0,4047
94	330	7,9197	0,4097
95	335	7,922	0,412
96	340	7,9231	0,4131
97	345	7,9236	0,4136
98	350	7,9237	0,4137
99	355	7,923	0,413
100	360	7,9253	0,4153
101	365	7,9268	0,4168
102	370	7,9264	0,4164
103	373	7,926	0,416
104	373,5	7,9248	0,4148
105	374	7,9249	0,4149
106	374,5	7,9241	0,4141
107	375	7,9225	0,4125
108	375,5	7,9197	0,4097
109	376	7,9154	0,4054
110	376,5	7,9114	0,4014
111	377	7,9071	0,3971
112	377,5	7,9024	0,3924
113	378	7,898	0,388
114	380	7,8772	0,3672
115	382	7,8562	0,3462
116	384	7,8382	0,3282
117	386	7,8233	0,3133
118	388	7,8071	0,2971
119	390	7,7946	0,2846
120	392	7,7824	0,2724
121	394	7,7711	0,2611
122	396	7,7609	0,2509
123	398	7,7516	0,2416
124	400	7,7437	0,2337
125	402	7,7357	0,2257
126	404	7,7295	0,2195
127	406	7,7226	0,2126
128	408	7,717	0,207
129	410	7,7105	0,2005
130	412	7,7056	0,1956
131	414	7,7014	0,1914
132	416	7,6968	0,1868
133	418	7,6923	0,1823
134	420	7,6882	0,1782
135	422	7,6844	0,1744
136	424	7,6805	0,1705
137	426	7,6786	0,1686
138	428	7,6742	0,1642
139	430	7,6732	0,1632
140	432	7,67	0,16
141	434	7,6677	0,1577
142	436	7,6649	0,1549
143	438	7,6624	0,1524
144	443	7,6563	0,1463
145	448	7,6502	0,1402
146	453	7,6476	0,1376
147	458	7,6433	0,1333
148	463	7,6377	0,1277
149	468	7,6346	0,1246
150	473	7,6306	0,1206
151	478	7,6279	0,1179
152	483	7,6251	0,1151
153	488	7,6222	0,1122
154	493	7,6199	0,1099
155	498	7,6176	0,1076
156	503	7,6151	0,1051
157	508	7,6123	0,1023
158	513	7,6104	0,1004
159	518	7,6086	0,0986
160	523	7,6068	0,0968
161	528	7,6051	0,0951
162	533	7,6045	0,0945

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
	Time [min]	Water Level [m]	Drawdown [m]	
163	538	7,6035	0,0935	
164	543	7,602	0,092	
165	548	7,601	0,091	
166	553	7,5995	0,0895	
167	558	7,5992	0,0892	
168	563	7,5979	0,0879	
169	568	7,5965	0,0865	
170	573	7,5951	0,0851	
171	578	7,5932	0,0832	
172	583	7,5922	0,0822	
173	588	7,591	0,081	
174	593	7,591	0,081	
175	598	7,5898	0,0798	
176	603	7,5882	0,0782	
177	608	7,5877	0,0777	
178	613	7,587	0,077	
179	618	7,5859	0,0759	
180	623	7,5845	0,0745	
181	628	7,5835	0,0735	
182	633	7,5829	0,0729	
183	638	7,5818	0,0718	
184	643	7,5815	0,0715	
185	648	7,5805	0,0705	
186	653	7,5797	0,0697	
187	658	7,5783	0,0683	
188	663	7,5774	0,0674	
189	668	7,5766	0,0666	
190	673	7,5764	0,0664	
191	678	7,5762	0,0662	
192	683	7,5754	0,0654	
193	688	7,5746	0,0646	
194	693	7,5743	0,0643	
195	698	7,5729	0,0629	
196	703	7,5725	0,0625	
197	708	7,5715	0,0615	
198	713	7,5715	0,0615	
199	718	7,5709	0,0609	
200	723	7,571	0,061	
201	728	7,5705	0,0605	
202	733	7,5703	0,0603	
203	738	7,5697	0,0597	
204	743	7,5698	0,0598	
205	748	7,5693	0,0593	
206	753	7,5688	0,0588	
207	758	7,5685	0,0585	
208	763	7,568	0,058	
209	768	7,5676	0,0576	
210	773	7,567	0,057	
211	778	7,5666	0,0566	
212	783	7,5662	0,0562	
213	788	7,5651	0,0551	
214	793	7,5644	0,0544	
215	798	7,5641	0,0541	
216	803	7,5634	0,0534	
217	808	7,5632	0,0532	
218	813	7,5628	0,0528	
219	818	7,5636	0,0536	
220	823	7,5634	0,0534	
221	828	7,5634	0,0534	
222	833	7,5621	0,0521	
223	838	7,5626	0,0526	
224	843	7,5624	0,0524	
225	848	7,5628	0,0528	
226	853	7,5618	0,0518	
227	858	7,5602	0,0502	
228	863	7,5601	0,0501	
229	868	7,5595	0,0495	
230	873	7,5592	0,0492	
231	878	7,5588	0,0488	
232	883	7,5585	0,0485	
233	888	7,5582	0,0482	
234	893	7,5574	0,0474	
235	898	7,5572	0,0472	
236	903	7,5565	0,0465	
237	908	7,5569	0,0469	
238	913	7,556	0,046	
239	918	7,5549	0,0449	
240	923	7,5539	0,0439	
241	928	7,5526	0,0426	
242	933	7,5514	0,0414	
243	938	7,5513	0,0413	
244	943	7,5513	0,0413	
245	948	7,5511	0,0411	
246	953	7,5506	0,0406	
247	958	7,5501	0,0401	

 <p>TechnoRem Inc. 4701 rue Louis-B.-Mayer Laval, Qc, H7P 6G5</p> <p>TechnoRem</p>				<p>Pumping Test - Water Level Data</p> <p>Project: Travaux caractérisation complémentaire</p> <p>Number: PR13-79</p> <p>Client: TPSGC</p>
				Page 4 of 4
	Time [min]	Water Level [m]	Drawdown [m]	
248	963	7,5476	0,0376	
249	968	7,547	0,037	
250	973	7,5464	0,0364	
251	978	7,546	0,036	
252	983	7,5454	0,0354	
253	988	7,5457	0,0357	
254	993	7,5455	0,0355	
255	998	7,5449	0,0349	
256	1003	7,5448	0,0348	
257	1008	7,5455	0,0355	
258	1013	7,5456	0,0356	
259	1018	7,546	0,036	
260	1023	7,5458	0,0358	
261	1028	7,5453	0,0353	
262	1033	7,5453	0,0353	
263	1038	7,5447	0,0347	
264	1043	7,5445	0,0345	
265	1048	7,544	0,034	
266	1053	7,5441	0,0341	
267	1058	7,5445	0,0345	
268	1063	7,5443	0,0343	
269	1068	7,5445	0,0345	
270	1073	7,5443	0,0343	
271	1078	7,5442	0,0342	
272	1083	7,5439	0,0339	
273	1088	7,5441	0,0341	
274	1093	7,544	0,034	
275	1098	7,5433	0,0333	
276	1103	7,5432	0,0332	
277	1108	7,5433	0,0333	
278	1113	7,5429	0,0329	
279	1118	7,5422	0,0322	
280	1123	7,5423	0,0323	
281	1128	7,5425	0,0325	
282	1133	7,5417	0,0317	
283	1138	7,5427	0,0327	
284	1143	7,5428	0,0328	
285	1148	7,5427	0,0327	
286	1153	7,5416	0,0316	
287	1158	7,5417	0,0317	
288	1163	7,5417	0,0317	
289	1168	7,5409	0,0309	
290	1173	7,5404	0,0304	
291	1178	7,5408	0,0308	
292	1183	7,5404	0,0304	
293	1188	7,5407	0,0307	
294	1193	7,5402	0,0302	
295	1198	7,5402	0,0302	
296	1203	7,5402	0,0302	
297	1208	7,5396	0,0296	
298	1213	7,5398	0,0298	
299	1218	7,5395	0,0295	
300	1223	7,5387	0,0287	
301	1228	7,5382	0,0282	
302	1233	7,5382	0,0282	
303	1238	7,5373	0,0273	
304	1243	7,5368	0,0268	
305	1248	7,5367	0,0267	
306	1253	7,5359	0,0259	
307	1258	7,5358	0,0258	
308	1263	7,5353	0,0253	
309	1268	7,5352	0,0252	
310	1273	7,5351	0,0251	
311	1278	7,5345	0,0245	
312	1283	7,5347	0,0247	
313	1288	7,5332	0,0232	
314	1293	7,5331	0,0231	



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-35 | Static Water Level [m]: 10,10 | Radial Distance to PW [m]: 86,65

	Time [min]	Water Level [m]	Drawdown [m]
1	0	10,10	0,00
2	6	10,10	0,00
3	60	10,09	-0,01
4	102	10,09	-0,01
5	179	10,09	-0,01
6	271	10,09	-0,01
7	356	10,08	-0,02
8	419	10,09	-0,01



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-36 | Static Water Level [m]: 6,86 | Radial Distance to PW [m]: 85,18

	Time [min]	Water Level [m]	Drawdown [m]
1	0	6,86	0,00
2	6	6,86	0,00
3	60	6,85	-0,01
4	102	6,86	0,00
5	179	6,86	0,00
6	271	6,85	-0,01
7	356	6,84	-0,02
8	419	6,84	-0,02



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-45 | Static Water Level [m]: 12,66 | Radial Distance to PW [m]: 71,52

	Time [min]	Water Level [m]	Drawdown [m]
1	0	12,66	0,00
2	3	12,66	0,00
3	58	12,65	-0,01
4	96	12,64	-0,02
5	176	12,63	-0,03
6	268	12,62	-0,04
7	353	12,60	-0,06
8	416	12,61	-0,05



TechnoRem Inc.
4701 rue Louis-B.-Mayer
Laval, Qc, H7P 6G5

TechnoRem

Pumping Test - Water Level Data

Page 1 of 1

Project: Travaux caractérisation complémentaire

Number: PR13-79

Client: TPSGC

Location: Dépotoir Sambault - Saint-Isidore | Pumping Test: PO-33 | Pumping Well: PO-33

Test Conducted by: TechnoRem Inc. | Test Date: 2013-09-18 | Discharge: variable, average rate 0,56668 [U.S. gal/min]

Observation Well: PO-46 | Static Water Level [m]: 6,82 | Radial Distance to PW [m]: 71,66

	Time [min]	Water Level [m]	Drawdown [m]
1	0	6,82	0,00
2	3	6,82	0,00
3	58	6,81	-0,01
4	96	6,81	-0,01
5	176	6,80	-0,02
6	268	6,78	-0,04
7	353	6,77	-0,05
8	417	6,78	-0,04