



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Admin Building Enclosure Renewal	
Solicitation No. - N° de l'invitation EZ899-180045/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client	Date 2017-09-08
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8145	
File No. - N° de dossier PWY-7-40124 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-13	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - Gulf of Georgia Cannery - Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-180045/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
007
File No. - N° du dossier
pwy-7-40124

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 007 is raised to incorporate Addendum No. 5.

Please find following Addendum No. 5.

All other terms and conditions remain unchanged.

*The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents*

Amend/revise the Standard Contract Documents as follows:

1.0 CHANGES AND CLARIFICATIONS

1.1 The electrical drawings show power lines and transformer work going into the cannery but it appears the routing indicated is not correctly shown – can this be clarified?

The existing 480 Volt splitter is located within the museum immediately adjacent to the theatre area.

On the opposite side of the theatre, and accessible through the mechanical room, is an electrical room that houses several transformers.

The clearance shall be 5.1 meters over ground areas and 5.8 meters over the road section. Allow 600 mm for sag in these calculations.

As for hazardous material, we are using an existing routing. We did not complete an assessment of the building materials. All cables shall be surface run within the buildings. Bidders may exclude any costs associated with hazardous building materials.

1.2 DELETE sentence 2.5.2.1 in section 08 53 13 – Plastic Windows and Doors – of the technical specifications and replace with the following sentences:

- .1 Laminated Foil Exterior / White uPVC interior.
- .1 Application of foil on profiles: Laminate foil on uPVC profiles as per the Directive for Quality Assurance of vinyl windows RAL-GZ 716, that, when applying the foil to a vinyl profile, a PUR hot-melt adhesive (moisture hardening and solvent free) shall be exclusively used as an adhesive. Prior to the application of PUR adhesive, the profiles shall be cleaned and a Primer 10-15 g/m² applied to the surface of the profile. Primer to be completely dried by means of hot-air blowers prior to applying the PUR adhesive. Apply PUR adhesive through a special nozzle evenly distributed over the surface of the profile at temperature 120-130°C at a rate of 35-50 g/m², at the same time protecting the hot melt from being directly exposed to humidity. A series of rubberized rollers of different shapes, configuration and hardness press the foil to the uPVC profile, creating a tight bond.
- .2 Foil to be Skai Techprofil multi-layer foil, weather resistant and UV resistant for outdoor use. Alternative products will not be excluded, as approved by Departmental Representative.
- .3 Film thickness: 190-220µm +/- 10% per DIN EN ISO 2286-3.
- .4 Acrylic top foil thickness: ≥50-60µm.
- .5 Gloss level: 14-23 +/-3 gloss as per standard.

- .6 Surface: when magnified 10-fold, the surface of the film should show no trace of cracks or damage.
- .7 Weather resistance: ≥ 3 level colour change of the grey scale as per ISO 4582, analysis ISO 105-A02 under total radiation exposure of 20GJ/m² in accordance with method 1 DIN EN 513.
- .8 Tensile strength: >20 N/mm² as per ISO 527-3.
- .9 Elongation at break: longitudinal $\geq 60\%$, transversal $\geq 40\%$ (ISO 527-3).
- .10 Dimensional stability: $> \pm 2.5\%$ (10min at 60°C) (DIN 53377).
- .11 Abrasion resistance: Grade 5 (ISO 105-X12; ISO 105-A03).
- .12 Moisture resistance: permissible change of colour in condensation water – alternating climate after 14 days, \geq level 3 as per grey scale ISO 105-A03 (DIN EN ISO 6270-2, AHT).
- .13 Mar resistance: >20 cN tested with ERICHSEN 435.
- .14 Embossing stability: No change to embossing result, gloss and colour when subjected to brief temperature stress (tested for 10 minutes at 80°C).
- .15 Cleaning and maintenance: Clean with mild detergent/soap solution in luke warm water. No polishing.

- 1.3 **DELETE section 2.5.3 in section 08 53 13 – Plastic Windows and Doors – of the technical specifications.**

END OF ADDENDUM No. 5