



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Admin Building Enclosure Renewal	
<b>Solicitation No. - N° de l'invitation</b> EZ899-180045/A	<b>Amendment No. - N° modif.</b> 008
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-09-11
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-019-8145	
<b>File No. - N° de dossier</b> PWY-7-40124 (019)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-09-13</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ngan, Ken (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy019
<b>Telephone No. - N° de téléphone</b> (604) 671-0219 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada (PCA) - Gulf of Georgia Cannery - Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-180045/A  
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.  
008  
File No. - N° du dossier  
pwy-7-40124

Buyer ID - Id de l'acheteur  
pwy019  
CCC No./N° CCC - FMS No/ N° VME

---

This Solicitation Amendment 008 is raised to incorporate Addendum No. 6.

Please find following Addendum No. 6.

All other terms and conditions remain unchanged.

*The following changes in the Tender Documents are effective IMMEDIATELY.  
This addendum will form part of the Contract Documents*

**Amend/revise the Standard Contract Documents as follows:**

## **1.0 CHANGES AND CLARIFICATIONS**

**1.1 DELETE section 2.1.1 in section 07 52 16 – Conventional SBS Roofing Combustible Substrates – of the technical specifications and replace with the following sentences:**

- .1 Vapour Barrier Base Ply: Self-adhered roofing membrane composed of homogeneous SBS modified bitumen with no oxidized asphalt content – reinforcement to be impregnated with SBS modified bitumen. The membrane must also meet the following criteria:
  - .1 Thickness (avg) 2.6 mm (ASTM D 5147)
  - .2 SBS content: 11-13%
  - .3 Maximum filler content in elastomeric blend: 35% by weight
  - .4 Low Temperature flexibility at -26°C Pass (ASTM D 5147)
  - .5 Ultimate Elongation (avg) @ 23°C: 50% (ASTM D 5147)
  - .6 Dimensional Stability (max) 0.1% (ASTM 5147)
  - .7 Reinforcement: random fiberglass mat or other meeting the performance and dimensional stability criteria.
  - .8 Top and bottom surfaces: sand/ polyolefin release film
  - .9 Selvage surface: 76 mm, polyolefin release tape
  - .10 Compound Stability (Min): 121°C (ASTM 5147)

**END OF ADDENDUM No. 6**