



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Admin Building Enclosure Renewal	
Solicitation No. - N° de l'invitation EZ899-180045/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client	Date 2017-09-11
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-8145	
File No. - N° de dossier PWY-7-40124 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-13	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 671-0219 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada (PCA) - Gulf of Georgia Cannery - Richmond, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-180045/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
008
File No. - N° du dossier
pwy-7-40124

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 008 is raised to incorporate Addendum No. 6.

Please find following Addendum No. 6.

All other terms and conditions remain unchanged.

*The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents*

Amend/revise the Standard Contract Documents as follows:

1.0 CHANGES AND CLARIFICATIONS

1.1 DELETE section 2.1.1 in section 07 52 16 – Conventional SBS Roofing Combustible Substrates – of the technical specifications and replace with the following sentences:

- .1 Vapour Barrier Base Ply: Self-adhered roofing membrane composed of homogeneous SBS modified bitumen with no oxidized asphalt content – reinforcement to be impregnated with SBS modified bitumen. The membrane must also meet the following criteria:
 - .1 Thickness (avg) 2.6 mm (ASTM D 5147)
 - .2 SBS content: 11-13%
 - .3 Maximum filler content in elastomeric blend: 35% by weight
 - .4 Low Temperature flexibility at -26°C Pass (ASTM D 5147)
 - .5 Ultimate Elongation (avg) @ 23°C: 50% (ASTM D 5147)
 - .6 Dimensional Stability (max) 0.1% (ASTM 5147)
 - .7 Reinforcement: random fiberglass mat or other meeting the performance and dimensional stability criteria.
 - .8 Top and bottom surfaces: sand/ polyolefin release film
 - .9 Selvage surface: 76 mm, polyolefin release tape
 - .10 Compound Stability (Min): 121°C (ASTM 5147)

END OF ADDENDUM No. 6