



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

002

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada
 Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address
 Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Icefields Parkway Gate Redevelopment Banff National Park	
Solicitation No. - No. de l'invitation 5P420-17-5249/A	Date: September 12, 2017
GETS Reference No. - No de reference de SEAG PW-17-00791986	Amendment No. - N° de la modif. 002
Solicitation Closes:	
at - á 02:00 PM	on - le September 15, 2017
Time Zone - Fuseau horaire MDT - HAR	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :	
Jen Maheu	
Telephone No. - No de téléphone (403) 292-8502	Fax No. - No de FAX: (403) 292-4475
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:	
See Herein - Voir ici	

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone: _____	
Facsimile No. - N° de télécopieur: _____	
Signature	Date

Amendment 02

This amendment is being raised to answer bidder questions and make changes to the tender package.

A) SITE VISIT QUESTIONS

Q1 Will the issues with printing the drawings size be resolved?

A1 Yes, The issue has been resolved and new drawings will be posted shortly

Q2 Where will asphalt for Niblock Gate be provided from?

A2 Asphalt for Niblock Gate will be the responsibility of the contractor

Q3 There will be a discrepancy if some asphalt for Niblock can come from within the Park?

A3 Asphalt must come from outside the National Park for Niblock

Q4 How will timing for getting asphalt to the David Thompson Gate work?

A4 The Asphalt will be available during the project window. It will be the responsibility of the contractor to coordinate the paving.

Q5 Where is the pit nearest to the David Thompson Gate Located?

A5 David Thompson Pit is located within 3km of David Thompson Gate area along Highway 11.

Q6 Is the design of the Gate Similar to the Banff East Gate?

A6 The new small Gate buildings were designed very similar to those at the Banff East Gate. The larger gates are a new design.

B) BIDDER QUESTIONS

Q7 Does this project require a trenchless method or is a trenchless method preferred?

A7 PCA would prefer a Trenched Method, but won't reject a Trenchless Method.

Q8 This opportunity closes on Sept 12 2017, and the solicitation document specifies a completion date of April 1 2018. The winter is unpredictable in this area, and it can come early and stay late. There is a possibility that winter conditions (including temperatures consistently below 0°C) could come as early as October 1 in these locations, and remain until April 1 2018 or later. A significant amount of the work including paving, concrete work, excavation/backfill, and handling the granular materials is temperature sensitive. The very nature of this work is such that once the temperatures are consistently below 0°C, the work cannot move forward or proceed until winter is over and consistent suitable conditions have returned. Would you consider moving the Contract completion date until sometime a bit later in 2018, such as the end of June. It is highly likely that due to temperature limitations, work such as paving will not be possible in these locations until June 2018.

A8:

Project Completion Date Change

- David Thompson - July 13th, 2018

Deliverables contingent with Date Change:

With this change of date, the contractor will be responsible to have a temporary kiosk operational by May 8, 2018 until the new kiosk is fully operational. The contractor may move one of the existing kiosks from Niblock to the old kiosk location shown on drawing L-DDP-01 (David Thompson). The kiosk requirements are electrical, operational phone and internet line, and an operational washroom (porta-potty). Note: the old David Thompson kiosk location has a live phone and internet line; the contractor would be responsible to have it hooked back up.

- Niblock - June 25th, 2018

Deliverables contingent with Date Change:

The contractor will be responsible to have one (1) kiosk operational from May 7, 2018 till completion. Two (2) kiosks and a through lane controlled by PCA staff needs to be operational from May 23, 2018 until completion. The two kiosks can be in-line and utilise one of the existing kiosks currently at Niblock. The through lane will need to be operational during peak traffic hours on high traffic days (Thursday, Friday, Saturday and on long weekends) (11am - 3pm). The temporary kiosk requirements are electrical, operational phone and internet line, and an operational washroom (porta-potty). The contractor will be able to close all kiosks to traffic for a maximum of 3 days for paving and concrete works. This will have to be scheduled one (1) month in advance with PCA. During this time, traffic must be able pass through the work area freely.

Q9 Upon reviewing your Specification for the above mentioned project, we would appreciate your consideration in approving CGC (Canadian Gypsum Company) for the following Specification Section:

A9 Approved

Q10 I am having an issue printing out some of the Icefield Parkway Gates IFT Drawings for this tender.

The drawings in question are: Page 38 (1) GI-05 (Drawing # T-MD-04)
Page 39 (1) C-DSP-01 (Drawing # C-DSP-01)
Page 40 (1) D-CD-01 (Drawing # C-DD-01)

A10 The following pages have been reformatted and posted as an amendment.

Q11 Can Hammond Manufacturing be included in the spec. for Cabinets and Racks.

A11 See item 4 in TENDER PACKAGE CHANGES

Q12 Is PWGSC interested in receiving alternate proposals and pricing for the geomembrane on this tender

A12 Do to the short time frame and holiday the successful contractor may submit any alternate products for review by the Departmental Representative once the project has been awarded.

D) BA06 CONSTRUCTION TIME

Remove: The Contractor shall perform and complete all onsite Work by **April 1, 2018**.

Replace with: The Contractor shall perform and complete all onsite Work for **Niblock by June 25, 2018** and all onsite Work for **David Thompson by July 13, 2018**.

E) TENDER PACKAGE CHANGES

1. Add the following folder: *DSP2_17-5249.zip*

2. Section 09 21 16 GYPSUM BOARD ASSEMBLIES (Page 2)

Remove: 2.3.4 Product: Dens Shield Fireguard Type X by Georgia Pacific

Replace with: 2.3.4 Product:

1. Dens Shield Fireguard Type X by Georgia Pacific
2. Canadian Gypsum Company Durock Glass Mat Tile Backer Board
3. Or equivalent as approved by the Departmental Representative meeting the above specifications.

3. Section 27 10 00 STRUCTURED CABLING (Page 7)

Remove: 2.6.5 Acceptable manufacturers are:

- .1 Listed structured cabling system manufacturers;
- .2 Devtek;
- .3 Cable-talk;
- .4 Hoffman;
- .5 Cannon

Replace with: 2.6.5 Acceptable manufacturers are:

- .1 Listed structured cabling system manufacturers;

Solicitation No. - N° de l'invitation
5P420-17-5249/A

Amd. No. - N° de la modif.
002

Buyer - l'acheteur
Jen Maheu

Client Ref. No. - N° de réf. du client
907/908

File Name - Nom du dossier
Icefields Parkway Gate Redevelopment - Banff National Park

- .2 Devtek;
- .3 Cable-talk;
- .4 Hoffman;
- .5 Cannon
- .6 Hammond Manufacturing
- .7 Or equivalent as approved by the Departmental Representative meeting the above specifications.

All other terms and conditions remain unchanged.