



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Fire Pump Replacement	
Solicitation No. - N° de l'invitation EP922-180126/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client CSC-EP922-180126	Date 2017-09-12
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-11164	
File No. - N° de dossier PWU-7-40031 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-09-29	Time Zone Fuseau horaire Mountain Daylight Saving Time MDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pwu201
Telephone No. - N° de téléphone (780) 901-0989 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EP922-180126/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwu201

Client Ref. No. - N° de réf. du client
CSC- EP922-180126











File No. - N° du dossier
PWU-7-40031

CCC No./N° CCC - FMS No./N° VME

Please see English version of Amendment #001

**CSC Drumheller Institution Central Heating Plant Fire Pump Replacement Project
ATTENDANCE REGISTER**

PLACE: CSC Drumheller Institution, Drumheller AB
 SOLICITATION NO: EP922-180126/A PROJECT NO: R.060837.001 DATE: September 11, 2017
 TITLE: RFP for Consultant - Mandatory Site Walk

Company Name	Signature	Print Name	Phone No.	Email Address	Bus. Card
Korbush Engineering Inc		Roman Korbush	403-612-1423	KORBUSH@TELUS.NET	✓
Korbush Engineering		Anton Vinoburo	403-978-3692	korbus@telus.net	
DCIT ENGINEERING		HANNA (JEWELL)	403 514 014	hank@eastkewebbing.com	
BERRY ARCHITECT		STEVE PHYPERS	403-586-1091	stevephypers@1125.ca	
CSC - JERRY AUJLA		JERRY AUJLA			
CSC Wescott Jasoari		Jason Wescott	403-820-6071	Jason.Wescott@CSC-SC-BC.ca	
PSPC		SHAWN LUMSDEN			
WSP		Jason McCauley	403-275-7525	Jason.McCauley@WSP.COM	
Tetra Tech		Brian Lussager	306-361-5086	Brian.lussager@tetratech.com	
Vipond Inc.		Evan McLellan	780-689-2645	evan.mclellan@vipond.ca	




REMINDERS:

1. ALL Attendees of this walk MUST SIGN IN.
2. IF YOU DO NOT SIGN IN, ANY TENDER BID RECEIVED FROM YOUR COMPANY FOR THIS CURRENT TENDER, WILL NOT BE ACCEPTED.
3. If you do not fill out this questionnaire, ALL questions MUST be sent to RPC as per the tender online.
4. NO answers to your questions will be given during the Mandatory site walk.
5. All responses/answers will be posted on <https://buyandsell.gc.ca> for all to review.
6. Tender Closing Date: September 29th, 2017 at 14:00 Mountain Daylight Time (MDT)

PSPC Project Manager: Shawn Lumsden
 CSC NHQ Client: Jerry Aujla

**CSC Drumheller Institution Central Heating Plant Fire Pump Replacement Project
ATTENDANCE REGISTER**

PLACE: CSC Drumheller Institution, Drumheller AB PROJECT NO: R.060837.001 DATE: September 11, 2017
 SOLICITATION NO: EP922-180126/A
 TITLE: RFP for Consultant - Mandatory Site Walk

Company Name	Signature	Print Name	Phone No.	Email Address	Bus. Card
TRAY FPS LTD		GARY DASE	403.981.8779	gary.dase@trayfps.com	
PGH ENGINEERING		PETER LLEWELLYN	403.872.4335	pllewellyn@pghengineering.ca	
VIPOND		JEFF BANDA	(507) 583-7476	jeff.banda@vipond.ca	

REMINDERS:

1. ALL Attendees of this walk MUST SIGN IN.
2. IF YOU DO NOT SIGN IN, ANY TENDER BID RECEIVED FROM YOUR COMPANY FOR THIS CURRENT TENDER, WILL NOT BE ACCEPTED.
3. If you do not fill out this questionnaire, ALL questions MUST be sent to RPC as per the tender online.
4. NO answers to your questions will be given during the Mandatory site walk.
5. All responses/answers will be posted on <https://buyandsell.gc.ca> for all to review.
6. Tender Closing Date: September 29th, 2017 at 14:00 Mountain Daylight Time (MDT)

PSPC Project Manager: Shawn Lumsden
 CSC NHQ Client: Jerry Aujla