



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
Room 100,  
167 Lombard Ave.  
Winnipeg  
Manitoba  
R3B 0T6  
Bid Fax: (204) 983-0338

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Western Region  
Room 100,  
167 Lombard Ave.  
Winnipeg  
Manitoba  
R3B 0T6

<b>Title - Sujet</b> Mechanical Upgrade PNWRC	
<b>Solicitation No. - N° de l'invitation</b> K4A22-180296/A	<b>Amendment No. - N° modif.</b> 005
<b>Client Reference No. - N° de référence du client</b> EC K4A22-180296	<b>Date</b> 2017-09-12
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWZ-117-10301	
<b>File No. - N° de dossier</b> PWZ-7-40062 (117)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-09-15</b>	
<b>Time Zone</b> Fuseau horaire Central Daylight Saving Time CDT	
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Holt, Judy	<b>Buyer Id - Id de l'acheteur</b> pwz117
<b>Telephone No. - N° de téléphone</b> (306) 241-6148 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Environnement Canada Prairie and Northern Wildlife Research Centre 115 Perimeter Road Saskatoon, SK	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
K4A22-180296/A

Amd. No. - N° de la modif.  
005

Buyer ID - Id de l'acheteur  
pwz117

Client Ref. No. - N° de réf. du client  
K4A22-180296/A

File No. - N° du dossier  
PWZ-7-40062

CCC No./N° CCC - FMS No./N° VME

## **NOTICE TO TENDERERS**

**Amendment 005 to Solicitation No. K4A22-180296/A is being issued for the following:**

**1) See Addendum No. 3 attached as “PNWRC Mechanical Upgrades K4A22-180296\_Addendum 3”**

*If your bid has already been forwarded and you wish to revise the same, this revision should reach the Bid Receiving Unit identified before the closing date. The bid number and closing date are to be clearly identified.*

**END OF AMENDMENT 005**

**GENERAL**

**The following changes in the Tender Documents are effective IMMEDIATELY. This addendum will form part of the Contract Documents**

**DRAWINGS**

None

**SPECIFICATIONS**

None

**QUESTIONS**

Question 1 (Received 2017-09-08)

Q: Is there any schedule for heating, cooling coils for multi-zone Air Handling Unit (AHU)?

A: See specifications and drawings for all AHU details.

Question 2 (Received 2017-09-08)

Q: Is there any drawing showing the configuration of multi-zone Air Handling Unit (AHU)?

A: See specifications and drawings for all AHU details.

Question 3 (Received 2017-09-11)

Q: Where are we placing the temporary Make-Up Air (MUA) Unit?

A: The temporary Air Handling Unit / Make-Up Air Unit can be placed on ground level on the east side of the building (between gridlines B and E) or on the north side of the building (between gridlines 9 and 10) represented on drawing G01. Final location shall be coordinated with Environment Canada Facility Manager.

Question 4 (Received 2017-09-11)

Q: Are we installing new supply and return heating lines for the new baseboard heaters or just the heaters and branch pipe on the main floor and 2<sup>nd</sup> floor?

A: Just the heaters and branch piping modifications on the main and 2<sup>nd</sup> floor to accommodate the new heaters.

Question 5 (Received 2017-09-11)

Q: Are the existing lines in the crawl space being removed?

A: No.

Question 6 (Received 2017-09-11)

Q: Do we need to ask for approved equals or we just need to meet the specification?

A: All equals to be approved.

**END OF ADDENDUM 3**