



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
Room 100,  
167 Lombard Ave.  
Winnipeg  
Manitoba  
R3B 0T6  
Bid Fax: (204) 983-0338

**SOLICITATION AMENDMENT**  
**MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Western Region  
Room 100,  
167 Lombard Ave.  
Winnipeg  
Manitoba  
R3B 0T6

<b>Title - Sujet</b> Mechanical Upgrade PNWRC	
<b>Solicitation No. - N° de l'invitation</b> K4A22-180296/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> EC K4A22-180296	<b>Date</b> 2017-09-13
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWZ-117-10301	
<b>File No. - N° de dossier</b> PWZ-7-40062 (117)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-09-15</b>	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Holt, Judy	<b>Buyer Id - Id de l'acheteur</b> pwz117
<b>Telephone No. - N° de téléphone</b> (306) 241-6148 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Environnement Canada Prairie and Northern Wildlife Research Centre 115 Perimeter Road Saskatoon, SK	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
K4A22-180296/A

Amd. No. - N° de la modif.  
006

Buyer ID - Id de l'acheteur  
pwz117

Client Ref. No. - N° de réf. du client  
K4A22-180296/A

File No. - N° du dossier  
PWZ-7-40062

CCC No./N° CCC - FMS No./N° VME

## **NOTICE TO TENDERERS**

**Amendment 006 to Solicitation No. K4A22-180296/A is being issued for the following:**

**1) See Addendum No. 4 attached as “PNWRC Mechanical Upgrades K4A22-180296\_Addendum 4”**

*If your bid has already been forwarded and you wish to revise the same, this revision should reach the Bid Receiving Unit identified before the closing date. The bid number and closing date are to be clearly identified.*

**END OF AMENDMENT 006**

**GENERAL**

The following changes in the Tender Documents are effective IMMEDIATELY. This addendum will form part of the Contract Documents

**DRAWINGS**

None

**SPECIFICATIONS**

None

**QUESTIONS**

Question 1 (Received 2017-09-13)

Q: Is the cooling coil direct expansion (DX) or chilled water?

A: The cooling coil for the new Air Handling Unit (AHU) is DX. Refer to specifications Section 23 73 11 Air Handling Units - Packaged, Paragraph 2.8 Coils. Acceptable Packaged AHU: **Daikin Vision AHU – Model CAH014 GMAC**

Question 2 (Received 2017-09-13)

Q: What is the info on the DX condensing unit for this associated cooling coil?

A: **North Wing condensing unit** associated with the new AHU and new cooling coil **is supplied separate from this construction tender**. The north wing condensing unit will be a separate contract, tendered in the upcoming weeks. North Wing Condensing Unit as follows:

CONDENSING UNIT CU-1

- .1 YORK MODEL YCUL0031EE58, AIR COOLED SCROLL CONDENSING UNIT, R410A, 89.81 KW (306.72 MBH) CAPACITY AT 5.55 C (42 F) SUCTION TEMPERATURE, 35 C (95 F) OUTDOOR AMBIENT TEMPERATURE, HIGH EFFICIENCY c/w ULTRA QUIET FANS, COMPRESSOR ACOUSTIC SOUND BLANKET, HOT GAS-BY-PASS, SINGLE POINT NON FUSED DISCONNECT SWITCH, FACTORY INSTALLED CONTROL TRANSFORMER, LOW AND HIGH AMBIENT KIT, SUCTION AND DISCHARGE PRESSURE READOUT KITS, SERVICE ISOLATION VALVES, COMPRESSOR CRANK CASE HEATER, POWER FACTOR CORRECTION CAPACITORS, MOTOR CURRENT MODULE, LOUVERED FULL UNIT ENCLOSURE PANELS, AND ELASTOMERIC VIBRATION ISOLATORS. UNIT SHALL BE SUITABLE FOR DIRECT INTEGRATION INTO JOHNSON CONTROLS METASYS SYSTEM, INCLUDE FOR ANY REQUIRED PROTOCOL GATEWAY. 575/3/60, 55.3 MCA, 30.43 TOTAL UNIT KW, 10.08 TOTAL UNIT EER.

**END OF ADDENDUM 4**