

High Level SITE VISIT Questions

Employee Housing M5000-18-1476/A

House 2 KBU257

| | |
|----|---|
| 1. | Is there a preference between a standard tub surround in all three residences, or a renovator tub/shower unit (3 to 4 piece higher quality for rental units)? |
| | The product requirement is for a tub/ shower renovator |
| 2. | The SOW says the AC unit for all three houses to be approved by Project Authority. Is there a preference in the tonnage and seer rating for them? |
| | Supply new high efficiency central air conditioning unit sufficient to control the temperature of the entire residence. Air conditioner must be 13 SEER or greater, carry a minimum 10 year manufacturer's warranty and must meet Energy Star requirements. Acceptable product is the Trane XR13 or equivalent. |