


1
M2 1:50

- | DESCRIPTION OF WORK – DEMOLITION WORK | |
|---------------------------------------|---|
| ① | REMOVE EXISTING AC UNITS C/W ASSOCIATED CONTROLS & ACCESSORIES, REMOVE & CAP EXISTING CHILLED & DOMESTIC WATER PIPING BACK TO MAIN. REMOVE EXISTING DRIP TRAY & CONDENSATE PIPING & ASSOCIATED ACCESSORIES. |
| ② | REMOVE EXISTING SPRINKLERS C/W ASSOCIATED SPRINKLER PIPING TO ACCOMMODATE NEW AC UNIT LAYOUT. |
| ③ | REMOVE EXISTING LEAK DETECTION PANEL & CABLE C/W ASSOCIATED ACCESSORIES. ALLOW FOR ACCESSIBLE FLOOR REMOVAL & REINSTALLATION AS REQUIRED. |

B137 - FIRE PROTECTION, PLUMBING & UTILITIES
NEW WORK



B137 - PLUMBING & UTILITIES
SCHEMATIC - EXISTING



- ## DESCRIPTION OF WORK – NEW WORK
- ① PROVIDE NEW AC UNITS /C/ ASSOCIATED CONTROLS & ACCESSORIES. EXTEND NEW CHILLED & DOMESTIC WATER PIPING FROM EXISTING MAINS. REFER TO DETAIL 12.4. PROVIDE NEW DWP & C/DW/ CONDUIT, PER MANUFACTURER'S INSTRUCTIONS. EXTEND RETURN AIR PLenum UP TO CEILING SPACE. CEILING RETURNED BY GENERAL TRADES. COORDINATE CEILING PLACEMENT ON SITE WITH DEPARTMENTAL REPRESENTATIVE AND GENERAL TRADES.
 - ② PROVIDE NEW CONCEALED SPRINKLERS /C/ ASSOCIATED SPRINKLER PIPING. COORDINATE CEILING LOCATIONS ON SITE TO SUIT EXISTING & NEW EQUIPMENT.
 - ③ PROVIDE NEW LEAK DETECTION CONTROL PANEL /C/ LEAK DETECTION CABLE & ACCESSORIES. INSTALL AS PER MANUFACTURER'S INSTRUCTIONS. NEW CABLES EXTEND DOWN TO ACCESSIBLE FLOOR REMOVAL & REINSTALLATION ROOM. ALLOW FOR ACCESSIBLE FLOOR REMOVAL & REINSTALLATION AS REQUIRED.
 - ④ DETAIN TWO(2) HATCH REJECTION DUCT CEILING PANELS /C/ 400K CULOR (SUPPLIED BY DEPARTMENTAL REPRESENTATIVE) AND INSTALL AS INDICATED. PROVIDER 400K APS AT FLANGES BELOW CEILING, FASTEN WITH TWO (2) SHEET METAL SCREWS. DETAIN TWO (2) ADDITIONAL 400K CONNECTORS FOR FLEXIBLE DUCTWORK (SUPPLIED BY DEPARTMENTAL REPRESENTATIVE) INCLUDING GEAR CLAMPS.
 - ⑤ PROVIDE 1000x500 DEEP PLENUM /C/ CONDUIT, SECURITY BAR, FIRE DAMPER AND NEW GRISS. COORDINATE W/ OPENING/PATCHING W/ GENERAL TRADES. ROUTE 400K HATCH REJECTION DUCTS FROM CEILING PANELS TO PLENUM AS INDICATED. SEE FIRE DAMPER WITH SECURITY BAR DETAIL 1 & 2/M1.

This drawing shall not be used for construction purposes until the seal appearing hereon is signed and dated by the Architect or Engineer.



Contractor to verify all dimensions
& conditions on site and immediately
notify the engineer of all discrepancies.

4	ISSUED FOR TENDER	2017/09/01
3	ISSUED FOR 95% REVIEW	2017/06/13
2	ISSUED FOR 50% REVIEW	2017/05/10
1	ISSUED FOR 25% REVIEW	2017/03/27

REV	ISSUED	YYY/MM/DD
<div style="display: flex; justify-content: space-around; align-items: flex-start;"> <div style="text-align: center;">  <p>A detail no. no. du detail</p> </div> <div style="text-align: center;">  <p>B location drawing no. sur dessin no.</p> </div> </div> <div style="text-align: center; margin-top: 20px;"> <p>C drawing no. dessin no.</p> </div>		

project	projet
---------	--------

CBUS A/C UNIT & LEAK
DETECTION SYSTEM
REPLACEMENT

OTTAWA, ONTARIO

OTTAWA, ONTARIO	
drawing	dessin

**MECHANICAL
DATA CENTRE B-137
FIRE PROTECTION, PLUMBING
& UTILITIES
DEMOLITION & NEW WORK**

Designed By	S.FERGUSON 2017/03/27	Çoğu par (yyyy/mm/dd)
Drawn By	S.FERGUSON 2017/03/27	Deşinir par (yyyy/mm/dd)
Reviewed By	E.PERUSSE 2017/03/27	Examinir par (yyyy/mm/dd)
Approved By		Approuv� par (yyyy/mm/dd)
Tender		Soumission

Project Manager	Administrateur de projets
Project no.	No. du projet
R.010219.020	

Drawing no.	M2	No. du dessin	OF 4
-------------	-----------	---------------	-------------