

PROJECT TITLE

SAULT STE. MARIE, ONTARIO
NATURAL RESOURCES CANADA
THE GREAT LAKES FORESTRY CENTRE
1219 QUEEN ST. EAST
NRCAN-GLFC REPAVE/REPAINT SERVICE ROAD AND PARKING
LOTS

Addendum No.2, dated 2017-09-19

QUESTIONS AND ANSWERS

1. "Is there to be weeper in the subgrade under the new curb and gutter?"

Answer: The design specification and tender package as provided does not provide for the supply and installation of sub-drain (weepers) under the new curb and gutter. As a point of clarification, OPSD 216.021 shown on Drawing Number C401 is interpreted to show possible existing sub-drain in the original construction

END OF ADDENDUM NO.1