


SEQUENCE OF OPERATION:

1. SF AND EF TO MODULATE BASED ON CO₂ LEVELS. SET POINT = 1200 PPM.

1 M2 **DETAIL - ERV-1**
SCALE : N.T.S.




SEQUENCE OF OPERATION:

1. INDOOR HEAT PUMP UNIT IS TO MAINTAIN SPACE TEMPERATURE SET POINT BY PROVIDING EITHER COOLING OR HEATING AS REQUIRED.

2. AUXILIARY ELECTRIC HEATING IS TO BE ENABLED AS REQUIRED WHEN HEAT PUMPS CANNOT MAINTAIN SPACE TEMP SET POINT.

3. HEAT PUMP FAN SHALL NOT RUN WHEN SET POINT IS SATISFIED.

2 M2 **DETAIL - HEAT PUMP SYSTEM ZONE CONTROL**
SCALE : N.T.S.



SEQUENCE OF OPERATION:

1. UNIT TO RECEIVE ITS OWN INDIVIDUAL FULLY MODIFIABLE SCHEDULE C/W SETBACK SETPOINT.


2. OCCUPIED MODE: UNIT SHALL OPERATE AND THE HEATING AND COOLING SECTIONS SHALL MODULATE/STAGE TO MAINTAIN SETPOINT

3. UNOCCUPIED MODE: UNIT SHALL BE NORMALLY OFF AND SHALL BE ENERGIZED TO MAINTAIN SETPOINT.

4. COOLING: DX COOLING SHALL STAGE AS REQUIRED TO ACHIEVE SETPOINTS. ECONOMIZER COOLING TO BE ENABLED AND CONTROLLED WHEN OUTDOOR AIR TEMPERATURE PERMITS AND SHALL OVERRIDE DX COOLING.

5. HEATING: HEATING SHALL BE PROVIDED BY HEAT PUMP WITH ELECTRIC COIL PROVIDING SECOND STAGE OF HEAT AS REQUIRED

3 M2 **DETAIL RTU-1,-2 CONTROLS**
SCALE : N.T.S.



4 M2 **DETAIL - ROOF PLAN**
SCALE : 1:20

0mm 500mm 1000mm 1500mm 2000mm 2500mm

| AIR CONDITIONING SCHEDULE - INDOOR UNITS | | | | | | | |
|--|----------------|------------------|-----------------------|-----------------------|-------------------|------------------------|-----------------|
| TAG | AREA SERVED | TYPE | COOLING CAPACITY (KW) | HEATING CAPACITY (KW) | MAX AIRFLOW (L/S) | POWER SUPPLY (V/HZ/PH) | ZONE CONTROLLER |
| HP-1 | SITUATION ROOM | CEILING CASSETTE | 7.03 (24 MBH) | 8.21 (28 MBH) | 302 | 208-230/60/1 | START WIRED |

NOTES:
- COMPLETE WITH CONDENSATE LIFT PUMPS, WASHABLE FILTER AS REQUIRED
- COMPLETE WALL MOUNTED CONTROLLERS


| AIR CONDITIONING SCHEDULE - OUTDOOR UNITS | | | | | | | |
|---|----------|-----------------------|-----------------------|------------------------|------------------|----------------------|---------|
| TAG | LOCATION | COOLING CAPACITY (KW) | HEATING CAPACITY (KW) | POWER SUPPLY (V/HZ/PH) | REFRIGERANT TYPE | SOUND PRESSURE (DBA) | REMARKS |
| CU-1 | WALL | 7.03 (24 MBH) | 8.21 (28 MBH) | 208-230/60/1 | R-410A | 48/50 | |

NOTES:
- ALL UNITS TO BE PROVIDED SUPPLIED WITH A WEATHERPROOF DISCONNECT
- COOLING CAP BASED ON 81°F DB, 71.1°F WB OUTDOOR SUMMER
- ALL UNITS c/w SINGLE POINT POWER SUPPLY
- ALL UNITS c/w WIND BAFFLE AND ALUMINUM WALL BRACKET

| GRILLE / DIFFUSER SCHEDULE | | | | | |
|----------------------------|------------------|-----------|----------------|----------------|-----------------------------------|
| SYMBOL | TYPE | SIZE (MM) | NECK SIZE (MM) | CAPACITY (L/S) | REMARKS |
| S-1 | ROUND ADJUSTABLE | 150 | 75 | AS SHOWN | COLOR: WHITE. ADJUSTABLE DIFFUSER |

| ERV SCHEDULE | | | | | | | | | | | |
|--------------|--------------|----------------|--|------------------------------|---------------------------|----------------------------|---------------------------------------|-----------------------|-------------|------------------------|--|
| TAG | LOCATION | AREA SERVED | TYPE | EFFICIENCY SUMMER/WINTER (%) | SUPPLY AIR CAPACITY (L/S) | EXHAUST AIR CAPACITY (L/S) | EXTERNAL STATIC PRESSURE EXHAUST (PA) | SUPPLY FAN MOTOR (KW) | FILTERS | POWER SUPPLY (V/HZ/PH) | REMARKS |
| ERV-1 | STORAGE ROOM | SITUATION ROOM | ENERGY RECOVERY VENTILATOR; LATENT AND SENSIBLE RECOVERYCORE | 60/75 | 113 | 113 | 19.85 | 0.373 | 50 MM MERV8 | 120/60/1 | c/w ECM MOTORS AND CO2 WALL SENSOR STORAGE ROOM DOES NOT CONTAIN FLOOR DRAIN. ERV WITH DRAIN CONNECTION IS NOT ACCEPTABLE. c/w HANGING BRACKETS OR MOUNTING FLANGE AND HANGING BAR TO MOUNT THE UNIT AS PER MANUFACTURER'S INSTALLATION MANUAL |

| AIR CONDITIONING SCHEDULE - ROOF TOP HEAT PUMP | | | | | | | | | | | | |
|--|-----------------|----------------------------|----------------|---------------------------|---------------------|--------------|--------------------------------------|---|------------------------------------|-------------------------------------|------------------------|--|
| TAG | AREA SERVED | TYPE | AIR FLOW (L/S) | MINIMUM OUTSIDE AIR (L/S) | AHU SUPPLY ESP (PA) | COOLING TYPE | COOLING TOTAL CAPACITY (NOMINAL TON) | HEAT PUMP HEATING/COOLING CAPACITY (KW) | HEATING TYPE | ELECTRIC HEATING COIL CAPACITY (KW) | POWER SUPPLY (V/HZ/PH) | REMARKS |
| RTU-1 | OFFICE SPACE | HEAT PUMP w/ ELECTRIC HEAT | 566 | 57 | 375 | DX | 3 | 11.69/10.55 (36/39.9 MBH) | HEAT PUMP W/ ELECTRIC HEATING COIL | 15 | 575/60/3 | ECONOMIZER. ELECTRIC HEATING COIL. 7-DAY PROGRAMMABLE THERMOSTAT. COORDINATE BREAKER SIZE WITH ELECTRICAL. MAXIMUM RTU LENGTH: 2200 MM |
| RTU-2 | OPERATIONS ROOM | HEAT PUMP w/ ELECTRIC HEAT | 378 | 38 | 375 | DX | 2 | 7.82/7.06 (24.1/26.7 MBH) | HEAT PUMP W/ ELECTRIC HEATING COIL | 15 | 208-230/60/1 | ECONOMIZER. ELECTRIC HEATING COIL. 7-DAY PROGRAMMABLE THERMOSTAT. COORDINATE BREAKER SIZE WITH ELECTRICAL. MAXIMUM RTU LENGTH: 1400 MM |



| revisions | date | project |
|-----------|-------------------|-------------|
| 2 | ISSUED FOR TENDER | SEP 8 2017 |
| 1 | ISSUED FOR TENDER | AUG 10 2017 |
| 0 | ISSUED FOR TENDER | JUL 28 2017 |
| B | ISSUED FOR REVIEW | MAY 16 2017 |
| A | ISSUED FOR REVIEW | MAR 31 2017 |

project: **CANSO CANAL PORT HASTINGS, INVERNESS COUNTY, NS HEAT PUMPS**

drawing: **ADMINISTRATION BUILDING ROOF PLAN, DETAILS AND SCHEDULES**

| | |
|-----------------------|---------------------------------|
| designed MC | conqu |
| date SEP 8 2017 | |
| drawn DA | desin4 |
| date SEP 8 2017 | |
| approved | approve6 |
| date | |
| Tender | Submission |
| PWOSC Project Manager | Administrateur de projets TPSCC |
| project number | no. du projet |
| R.090672.001 | |
| drawing no. | no. du dessin |
| M2 | |