



Invitation to Tender (ITT)
Main Entrance/Colonnade Glazing/Roof Replacement
Reference #: NGC110697
Buy and Sell Reference #: PW-17-00789081
September 20, 2017

ADDENDA # 4

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. Acknowledge receipt of this Addendum by inserting its number and date on the Tender Form, specifically article G.2.

1. Appendix L – Drawing E-1 – General Note 13; Please confirm Note 13 does not apply to this project
 - a. Does not apply.
2. Appendix L – Drawing E-3 - Conduit Specification Items 4-9; Please confirm standard wiring methods (BX, Teck) can be used to feed the new temporary lighting
 - a. Conduit to be used in public areas where visible. Bx/Teck, acceptable within hidden and non-public areas.
3. Appendix L – Drawing E-2; Please confirm there is no requirement for temporary exit lighting within the public walkway
 - a. No additional exit signage will be added by this project. Existing to remain.
4. Appendix L – Drawing E-3; Specification – Scope of Work – Item 1; Please confirm all modifications and additions to the raceway system for the telecommunication system including the cable TB system are not part of this contract.
 - a. Correct, not applicable to project.