



APEGA  
PERMIT TO PRACTICE  
P 3979

Revision/Revision	Description/Description	Date/Date
0	ISSUED FOR TENDER	2017.08.16


Client/client  
**PUBLIC WORKS & GOVERNMENT SERVICES CANADA**

Project title/Titre du projet  
**EDMONTON MAXIMUM SECURITY INSTITUTION**

Approved by/Approuvé par  
JM  
Designed by/Concept par  
JS/KD  
Drawn by/Dessiné par  
RJN  
PWGSC Project Manager/Administrateur de Projets TP/SGC  
ANDREW GILLESE  
PWGSC, Architectural and Engineering Resources Manager/  
Ressources Architectural et de Directeur d'ingénierie, TP/SGC

Client/client  
PUBLIC WORKS & GOVERNMENT SERVICES CANADA  
Drawing title/Titre du dessin  
**SINGLE LINE DIAGRAM  
MCC #8 & MCC #10  
(INFIRMARY, DISSOCIATION, GYM  
AND SG AREAS)**

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.078013.001	E14 OF 103	0



**LEGEND**

REPLACE LOADS BEING REPLACED. BREAKER AND STARTER TO BE REPLACED.

DEMOLISH LOADS BEING DEMOLISHED. DEMOLISH BREAKER AND STARTER.

NEW LOADS BEING ADDED. BREAKER AND STARTER TO BE INSTALLED.

- NOTES:**
- ALL LOADS SHOWN OTHER THAN THOSE INCLUDED IN THE SCOPE OF THIS PROJECT ARE UNVERIFIED.
  - EXISTING MCC BUCKETS TO BE SENT TO MANUFACTURE FOR TESTING. ALL BUCKETS PASSING TESTING WILL BE RETURNED TO OWNER.
  - RE-USE EXISTING WIRE AND CONDUIT. VERIFY EXISTING WIRE SIZE AND CONDITION PRIOR TO RE-USE.
  - MOVED FROM PANEL MR4. DEMOLISH EXISTING MOTOR STARTER AND BREAKER.
  - MCC-10 SINGLE LINE DIAGRAM ONLY REPRESENTS PORTION CONTAINED IN SCOPE OF PROJECT.

DIAGRAM NTS  
MCC 10 (SG)

DIAGRAM NTS  
MCC 8 (INFIRMARY,  
DISSOCIATION & GYM)