



- 1 REMOVE RETURN GRILLE, DUCT WORK AND CAP AS SHOWN. PATCH AND REPAIR OPENING.
- 2 REMOVE RETURN GRILLE, DUCT WORK AS SHOWN. DO NOT CAP. PATCH AND REPAIR OPENING. COORDINATE PATCH AND REPAIR WITH NEW DUCTWORK SCOPE.
- 3 DISCONNECT AND REMOVE DUCTWORK TO RETURN GRILLE AS SHOWN. RETURN GRILLE TO REMAIN.

1	EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
2	CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
3	PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.