

KEY PLAN

APEGA
PERMIT TO
PRACTICE
P 3979

DO NOT SCALE DRAWINGS

Revision/	Description/Description	Date/Date
0	ISSUED FOR TENDER	2017.08.16


Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Project title/Titre du projet
EDMONTON MAXIMUM SECURITY INSTITUTION

Approved by/Approuvé par
J. MAH
Designed by/Concepté par
J. MAH
Drawn by/Dessiné par
J. CHOA
PWSC Project Manager/Administrateur de Projets TPSGC
ANDREW GILLESSE
PWSC, Architectural and Engineering Resources Manager/
Ressources Architecturales et de Directeur d'Ingénierie, TPSGC

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA
Drawing title/Titre du dessin
FOOD SERVICES VENTILATION PLAN

Project No./No. du projet R.078013.001	Sheet/Feuille M48 OF 103	Revision no./ La Révision no. 0
---	---------------------------------------	--



- SHEET KEY NOTES**
- REBALANCE EXISTING SUPPLY DIFFUSER.
 - INSTALL DRYWALL MOUNTED DIFFUSER 600mm FROM WALL.
 - SET ASIDE EXISTING SUPPLY GRILLE. INSTALL NEW DUCT WORK EXTENSION AS SHOWN. RE-PLACE EXISTING SUPPLY GRILLE AND REBALANCE.

- GENERAL NOTES**
- EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
 - CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
 - PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.

1 PLAN 1:100
M48 FOOD SERVICES VENTILATION

