

1 PLAN
M34 CORCAN HEATING AND CONTROLS



1:100

SHEET KEY NOTES

- 1 REMOVE AND REPLACE PNEUMATIC CONTROL VALVE WITH NEW ELECTRIC CONTROL VALVE. INSTALL NEW CONTROL WIRING AND TEMPERATURE SENSOR OR THERMOSTAT AS SHOWN.
- 2 REMOVE AND REPLACE ALL PNEUMATIC CONTROLS FOR AIR HANDLER HEATING LINE CONTROL VALVE, DAMPER ACTUATORS, MIXING VALVES WITH NEW ELECTRIC TIED TO BMS.

GENERAL NOTES

- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
- 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
- 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.
- 4 COORDINATE ALL REQUIRED OPENINGS IN WALLS TO PERFORM HEATING AND CONTROLS WORK. PATCH AND REPAIR WALLS. REFER TO ARCHITECTURAL PLANS FOR SPECIFIC REQUIREMENTS



KEY PLAN

APEGA
PERMIT TO
PRACTICE
P 3979

DO NOT SCALE DRAWINGS

0	ISSUED FOR TENDER	2017.08.16
Revision/	Description/Description	Date/Date

Client/client

PUBLIC WORKS &
GOVERNMENT SERVICES
CANADA

Project title/Titre du projet

EDMONTON MAXIMUM
SECURITY INSTITUTION

Approved by/Approuvé par
J. MAH

Designed by/Concept par
J. MAH

Drawn by/Dessiné par
J. CHOA

PWGSC Project Manager/Administrateur de Projets TPSGC
ANDREW GILLESSE

PWGSC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'Ingénierie, TPSGC

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin

CORCAN AREA
HEATING AND CONTROLS

Project No./No. du projet R.078013.001	Sheet/Feuille M34 OF 103	Revision no./ La Révision no. 0
---	--------------------------------	---------------------------------------