


1 PLAN  
M29 1:100  
HEALTHCARE HEATING AND CONTROLS

### SHEET KEY NOTES

- 1 REMOVE AND REPLACE PNEUMATIC CONTROL VALVE WITH NEW ELECTRONIC CONTROL VALVE. INSTALL NEW CONTROL WIRING AND TEMPERATURE SENSOR AS SHOWN. TEMPERATURE SENSOR TO BE INSTALLED HIDDEN INSIDE TAMPER PROOF ENCLOSURE.

### GENERAL NOTES

- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
- 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
- 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.
- 4 FLOW VALUES NOTED FOR CONTROL VALVES ARE BASED ON EXISTING TERMINAL CAPACITIES FROM ORIGINAL RECORDS BASED ON 11°C TEMPERATURE DROP.
- 5 PROVIDE NEW TEMPERATURE SENSOR FOR BMS MONITORING AND CONTROL.
- 6 COORDINATE ALL REQUIRED OPENINGS IN WALLS TO PERFORM HEATING AND CONTROLS WORK. PATCH AND REPAIR WALLS. REFER TO ARCHITECTURAL PLANS FOR SPECIFIC REQUIREMENTS



KEY PLAN

APEGA  
PERMIT TO  
PRACTICE  
P 3979

### DO NOT SCALE DRAWINGS

0	ISSUED FOR TENDER	2017.08.16
Revision/ Révision	Description/Description	Date/Date

Client/client

PUBLIC WORKS &  
GOVERNMENT SERVICES  
CANADA

Project title/Titre du projet

EDMONTON MAXIMUM  
SECURITY INSTITUTION

Approved by/Approuvé par  
J. MAH

Designed by/Concept par  
J. MAH

Drawn by/Dessiné par  
J. CHOA

PWSC Project Manager/Administrateur de Projets TPSGC  
ANDREW GILLESE

PWSC, Architectural and Engineering Resources Manager/  
Ressources Architectural et de Directeur d'Ingénierie, TPSGC

Client/client  
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin

HEALTHCARE  
HEATING AND CONTROLS

Project No./No. du  
projet

R.078013.001

Sheet/Feuille

M30

OF 103

Revision no./  
La Révision  
no.

0