


- ### SHEET KEY NOTES
- 1 REMOVE GYM DIFFUSER AS SHOWN.
 - 2 OUTLINE OF CATWALK ABOVE SHOWN FOR CLARITY.
 - 3 REMOVE RADIATION ELEMENT AND CAP HEATING PIPE CONNECTIONS DOWNSTREAM OF EACH ISOLATION VALVE. RE-INSTALL ENCLOSURE.
 - 4 REMOVE DIFFUSER AND CAP DUCTWORK AS SHOWN. PATCH AND REPAIR CEILING TO MATCH EXISTING.

- ### GENERAL NOTES
- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
 - 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
 - 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.



KEY PLAN

APEGA
PERMIT TO
PRACTICE
P 3979

DO NOT SCALE DRAWINGS

0	ISSUED FOR TENDER	2017.08.16

Revision/	Description/Description	Date/Date
Client/client		

PUBLIC WORKS &
GOVERNMENT SERVICES
CANADA

Project title/Titre du projet

EDMONTON MAXIMUM
SECURITY INSTITUTION

Approved by/Approuvé par
J. MAH

Designed by/Concept par
J. MAH

Drawn by/Dessiné par
J. CHOA

PWGC Project Manager/Administrateur de Projets TPSGC
ANDREW GILLESSE

PWGC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'Ingénierie, TPSGC

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin

GYM AREA AND PILL ROOM
DEMOLITION PLAN

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.078013.001	M10 OF 103	0