

KEY PLAN

APEGA
PERMIT TO
PRACTICE
P 3979

DO NOT SCALE DRAWINGS

Revision/	Description/Description	Date/Date
0	ISSUED FOR TENDER	2017.08.16

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Project title/Titre du projet
EDMONTON MAXIMUM SECURITY INSTITUTION

Approved by/Approuvé par
J. MAH

Designed by/Conçu par
J. MAH

Drawn by/Dessiné par
J. CHOA

PWSC Project Manager/Administrateur de Projets TPSCG
ANDREW GILLESSE


PWSC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'Ingénierie, TPSCG

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin
FOOD SERVICES HEATING AND CONTROLS

FOOD SERVICES HEATING AND CONTROLS

Project No./No. du projet	Sheet/Feuille	Revision no./La Révision no.
R.078013.001	M33 OF 103	0



1 PLAN 1:100
M33 FOOD SERVICES HEATING AND CONTROLS

- SHEET KEY NOTES**
- REMOVE AND REPLACE PNEUMATIC CONTROL VALVE WITH NEW ELECTRIC CONTROL VALVE. INSTALL NEW CONTROL WIRING AND TEMPERATURE SENSOR OR THERMOSTAT AS SHOWN.
 - TEMPERATURE SENSOR TO BE FULLY CONCEALED AND INSTALLED FLUSH IN WALL. INSTALL USING TAMPER PROOF SECURITY SCREWS. COORDINATE SECURITY SCREW TYPE WITH DEPARTMENTAL REPRESENTATIVE.

- GENERAL NOTES**
- EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
 - CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
 - PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.
 - NUMBERS NEXT TO CONTROL VALVES FOR BALANCING PURPOSES.
 - COORDINATE ALL REQUIRED OPENINGS IN WALLS TO PERFORM HEATING AND CONTROLS WORK. PATCH AND REPAIR WALLS. REFER TO ARCHITECTURAL PLANS FOR SPECIFIC REQUIREMENTS