



1 PLAN
M11
1:100
ADMISSION, DISCHARGE, CONTACT AND VISITING AREA DEMOLITION

- ### SHEET KEY NOTES
- 1 REMOVE AND CAP DUCT WORK AS SHOWN.
 - 2 REMOVE EXISTING DIFFUSER FROM UPPER DRYWALL CEILING.
 - 3 REMOVE AND CAP DUCT WORK AS SHOWN.
 - 4 REMOVE SUPPLY DIFFUSER BELONGING TO AH-27 AND CAP CONNECTION. PATCH AND REFINISH DRYWALL CEILING TO MATCH EXISTING.
 - 5 REMOVE LOWER TBAR CEILING TO ALLOW ACCESS TO ORIGINAL UPPER LEVEL GYPSUM CEILING SPACE TO FACILITATE DUCTWORK SCOPE FOUND ON DWG M47. REPLACE LOWER LEVEL TBAR CEILING AFTER.
- ### GENERAL NOTES
- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
 - 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
 - 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.



KEY PLAN

APEGA
PERMIT TO
PRACTICE
P 3979

DO NOT SCALE DRAWINGS

Revision/	Description/Description	Date/Date
0	ISSUED FOR TENDER	2017.08.16

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Project title/Titre du projet
EDMONTON MAXIMUM SECURITY INSTITUTION

Approved by/Approuvé par
J. MAH

Designed by/Concept par
J. MAH

Drawn by/Dessiné par
J. CHOA

PWGC Project Manager/Administrateur de Projets TPSGC
ANDREW GILLESE

PWGC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'Ingénierie, TPSGC

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin
ADMISSION, DISCHARGE,
CONTACT AND VISITATION
DEMOLITION PLAN

Project No./No. du projet
R.078013.001

Sheet/Feuille
M11
OF 103

Revision no./
La Révision
no.
0

