



KEY PLAN

APEGA  
PERMIT TO  
PRACTICE  
P 3979

DO NOT SCALE DRAWINGS

0	ISSUED FOR TENDER	2017.08.16

Revision/ Révision	Description/Description	Date/Date
Client/client		

PUBLIC WORKS &  
GOVERNMENT SERVICES  
CANADA

Project title/Titre du projet

EDMONTON MAXIMUM  
SECURITY INSTITUTION

Approved by/Approuvé par  
J. MAH

Designed by/Concept par  
J. MAH

Drawn by/Dessiné par

PWSC Project Manager/Administrateur de Projets TPSCG  
ANDREW GILLESE

PWSC, Architectural and Engineering Resources Manager/  
Ressources Architectural et de Directeur d'Ingénierie, TPSCG

Client/client  
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin

SEGREGATION AND  
DISASSOCIATION BLOCK  
SECOND FLOOR VENTILATION PLAN

Project No./No. du  
projet  
R.078013.001

Sheet/Feuille  
M55  
OF 103

Revision no./  
La Révision  
no.  
0

### SHEET KEY NOTES

- 1 REBALANCE EXISTING DIFFUSER AS SHOWN. CONFIRM EXISTING LOCATION OF BALANCING DAMPERS ON SITE.
- 2 INSTALL CONCEALED TEMPERATURE SENSOR IN EXISTING FIRE ALARM INFRASTRUCTURE. COORDINATE FINAL LOCATION WITH BUILDING OPERATOR PRIOR TO INSTALLATION.

### GENERAL NOTES

- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
- 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
- 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.

BLOCK 'S'  
UPPER

BLOCK 'D'  
UPPER(SG)

UNIT OFFICES  
(GROUND FLOOR BELOW)

1 PLAN  
M55  
SEGREGATION AND DISASSOCIATION  
SECOND FLOOR VENTILATION

1:100