



- 1 INSTALL NEW HYDRONIC DUCT HEATER (TYPICAL OF 2). SEE
HEATING DRAWING FOR PIPING INFORMATION. MATCH
EXISTING DUCTWORK SIZE.
- 2 INSTALL RETURN AIR DUCTWORK ABOVE AIR HANDLER.
- 3 NEW IN DUCT REHEAT COILS FOR UNIT OFFICES AIR
HANDLER. REFER TO HEATING DRAWINGS FOR PIPING
INFORMATION AND REHEAT COIL TAGS. REFER TO DETAIL 7
ON M61 FOR LOCATION OF REHEAT COIL.
- 4 ALTERNATE ZONE DUCT WORK TO RISE AS SHOWN.
RECONNECT TO EXISTING.
- 5 CONNECT EXISTING DUCTWORK TO NEW MAINS.
- 6 NEW OA DUCTWORK TO RUN BELOW EXISTING TIGHT TO
WALL.
- 7 EXISTING CONTROL PANEL AND FIRE CONTROL VALVE &
PIPING. FIRE CONTROL VALVE AND PIPING MUST REMAIN
UNOBSTRUCTED AND FULLY ACCESSIBLE. REROUTE
DUCTWORK AS REQUIRED. CONTRACTOR TO ALLOW FOR
RELOCATION OF CONTROL PANEL TO FACILITATE
MAINTENANCE CLEARANCE IN COORDINATION WITH
DEPARTMENTAL REPRESENTATIVE.
- 8 EACH DUCT SERVES 2 CELLS ON EACH FLOOR. BALANCE
EACH DUCT TO THE REQUIRED VOLUMES AS REQUIRED BY
THE VENTILATION PLANS.

- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
- 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
- 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.
- 4 REFER TO SECTION 1 ON M61 FOR TYPICAL CELL AIR HANDLER PAIR DETAILS.
- 5 PLACEMENTS OF EXISTING AIR HANDLERS SHALL NOT COVER EXISTING FLOOR DRAINS OR CLEANOUTS.