

KEY PLAN

APEGA
PERMIT TO
PRACTICE
P 3979

DO NOT SCALE DRAWINGS

0	ISSUED FOR TENDER	2017.08.16

Revision/ Révision	Description/Description	Date/Date
Client/client		

PUBLIC WORKS &
GOVERNMENT SERVICES
CANADA

Project title/Titre du projet

EDMONTON MAXIMUM
SECURITY INSTITUTION

Approved by/Approuvé par
J. MAH

Designed by/Concept par
J. MAH

Drawn by/Dessiné par
J. CHOA

PWSC Project Manager/Administrateur de Projets TPSCG
ANDREW GILLESE

PWSC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'Ingénierie, TPSCG

Client/client
PUBLIC WORKS & GOVERNMENT SERVICES CANADA

Drawing title/Titre du dessin

SEGREGATION AND
DISASSOCIATION BLOCK
MAIN FLOOR VENTILATION PLAN

Project No./No. du
projet
R.078013.001

Sheet/Feuille
M54
OF 103


Revision no./
La Révision
no.
0

SHEET KEY NOTES

- 1 REBALANCE EXISTING DIFFUSER AS SHOWN. CONFIRM LOCATIONS OF EXISTING BALANCING DAMPERS ON SITE.
- 2 INSTALL CONCEALED TEMPERATURE SENSOR IN EXISTING FIRE ALARM INFRASTRUCTURE. COORDINATE FINAL LOCATION WITH BUILDING OPERATOR PRIOR TO INSTALLATION.

GENERAL NOTES

- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
- 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
- 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.



1 PLAN
M54
SEGREGATION AND DISASSOCIATION
MAIN FLOOR VENTILATION

1:100

