



- ### SHEET KEY NOTES
- 1 CONNECT TO EXISTING HEATING WATER SUPPLY AND RETURN PIPE MAINS. INSTALL ISOLATION VALVES ON BOTH SUPPLY AND RETURN LINES.
 - 2 INSTALL HEATING WATER LINES TIGHT TO CEILING OF CRAWLSPACE.
 - 3 CORE AND SEAL PIPE PENETRATION TO MAINTAIN FIRE RATING.
 - 4 EACH REHEAT COIL TO BE INSTALLED WITH INDIVIDUAL CONTROL VALVES, BALANCING AND ISOLATIONS, PER DETAIL 5/6 ON M64.
 - 5 REFER TO VENTILATION PLANS FOR REHEAT COIL LOCATION.
 - 6 PRESSURE BYPASS. INSTALL DIFFERENTIAL PRESSURE SENSOR.
- ### GENERAL NOTES
- 1 EXISTING DRAWING INFORMATION IS NOT AS-BUILT. CONTRACTOR TO CONFIRM EXISTING CONDITIONS AND ROUTING PRIOR TO COMMENCING WORK.
 - 2 CONSTRUCTION ACTIVITIES SHALL BE COORDINATED AND STAGED WITH THE BUILDING OPERATOR TO MINIMIZE INTERRUPTION TO OPERATIONS.
 - 3 PATCH AND REPAIR OPENINGS TO MAINTAIN FIRE SEAL.

