



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Building Envelope Remediation	
<b>Solicitation No. - N° de l'invitation</b> EZ899-181195/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-09-26
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-8168	
<b>File No. - N° de dossier</b> PWY-7-40197 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-10-04</b>	<b>Time Zone Fuseau horaire Pacific Daylight Saving Time PDT</b>
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (778) 919-3273 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:</b> CBSA - Pacific Highway POE - Surrey, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-181195/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier  
PWY-7-40197

CCC No./N° CCC - FMS No./N° VME

---

This Amendment #001 is raised to post the site visit attendees list and to issue Addendum #1.

**Site Visit Attendees**

Pacific Building Envelope Maintenance Ltd.  
Cascade Roofing

Please see attached Addendum #1.

**All other terms and conditions remain unchanged.**



Owner: **Public Works & Government Services Canada**  
 Project: **Pacific Hwy Port of Entry – Partial Building Envelope Remediation**  
 Address: **28 – 176 Street, Surrey BC**  
 Date: **Monday, September 25, 2017**  
 BGIS Project: **R.087821.001**  
 No. of Pages: **02** BCAI Project No.: **21713**

### Addendum No. 01

This addendum is issued prior to the closing date in order to revise the Tender Documents: value of all items shall be included in the final tender price. After acceptance of all final prices, claims cost will not be considered by reason of failure by contractor to have read the Addendum.

#### 1.0 Tender Documents:

.1	<b>Not applicable.</b>
----	------------------------

#### 2.0 Specifications:

.1	<b>Not applicable.</b>
----	------------------------

#### 3.0 Drawings: refer to attached drawings:

.1	<b>Drawing A301 – Plan, Commercial Building ‘A’:</b> <b>Loading Dock (4 overhead doors between Gridlines CT and CM):</b> <b>Delete Keynote 01-2 associated with this phase. There are no restrictive hours for work pertaining to this work at the warehouse area.</b>
----	--

#### 4.0 Response to questions received from contractors as follows:

.1	<b>Commercial Building – (Gridlines 12 &amp; CC): Louvre installation:</b> Q: What is the purpose of this opening? How would you like the louvre installed (recessed or surface mounted)? <b>A: This opening enters the existing Janitor Room. Contractor to propose installation method however removal and reinstallation of the existing single wall panel will likely be required.</b>
.2	<b>Traffic Building (Stairwell) and Export Office:</b> Q: Are curved flashings to be formed to match those of the curved wall panels or may these flashings be radiused? <b>A: Curved flashings are required (to follow profile of wall panels).</b>
.3	<b>Commercial Building (east elevation at between Gridlines CM and CE2):</b> Q: Some lower panels (approximately 4) have fasteners on the face of the panel to hold the temporary flashing in place. Please confirm how the contractor is to address the existing penetrations once the new flashing is

## ADDENDUM

---

installed.

**A: Contractor to reinstall existing panels in accordance with drawings and fill each existing fastener penetration with a neoprene washer and new aluminum fastener.**

*End of Addendum #01*

J:\Bcat\2017\21713 PWGSC CBSA Pac Hwy Envelope\Project Documents\Tender\Addenda\ADD# 01 - R.087821.001 PAC HWY Bldg Envelope.docx